

Acoustic Assessment Report HAF Wind Energy Project Township of West Lincoln, Ontario


Prepared for:

Vineland Power Inc.
222 Martindale Road
St. Catharines, Ontario
L2R 7A3


Prepared by:



Ian R. Bonsma, PEng



And



Brian Howe, MEng, MBA, PEng

March 25, 2013

VERSION CONTROL

HAF Wind Energy Project, Township of West Lincoln, Ontario

| Ver. | Date | Version Description | Prepared By |
|------|-------------------|--|-------------|
| 1 | December 9, 2010 | Original Acoustic Assessment Report supporting an application for a Renewable Energy Approval. | M. Munro |
| 2 | September 9, 2011 | Acoustic Assessment Report Updated to reflect minor changes to the location of WTG1, WTG2 and WTG3. | M. Munro |
| 3 | February 1, 2013 | Acoustic Assessment Report updated to add additional receptors and to reflect comments from the MOE. | I. Bonsma |
| 4 | March 25, 2013 | Acoustic Assessment Report updated to reflect comments from the MOE. | I. Bonsma |
| | | | |

TABLE OF CONTENTS

| | |
|---|-----------|
| EXECUTIVE SUMMARY | iv |
| ACOUSTIC ASSESSMENT REPORT CHECK-LIST..... | v |
| 1 INTRODUCTION..... | 1 |
| 2 GENERAL DESCRIPTION OF WIND TURBINE INSTALLATION SITE AND SURROUNDING ENVIRONMENT..... | 2 |
| 3 DESCRIPTION OF SOUND SOURCES..... | 3 |
| 4 WIND TURBINE NOISE EMISSION RATINGS..... | 4 |
| 5 POINT OF RECEPTION SUMMARY..... | 4 |
| 6 ASSESSMENT CRITERIA..... | 6 |
| 7 IMPACT ASSESSMENT | 6 |
| 8 CONCLUSIONS AND RECOMMENDATIONS | 9 |

Figure 1a: Wind Turbine Generator Siting Map

Figure 1b: Scaled Location Map

Figure 2: Proposed Wind Turbine Generator and Receptor Locations

Figure 3: Predicted Sound Levels, Leq [dBA] Calculated at 4.5m Above Ground Level

Appendix A: Assessment Summary Tables

Appendix B: Township of West Lincoln Zoning Map

Appendix C: General Vestas V100-1.8 MW Wind Turbine Generator Information

Appendix D: Sound Power Data for Vestas V100-1.8 MW Wind Turbine Generators

Appendix E: Calculation Details

Appendix F: Wind Shear Coefficient Summary

EXECUTIVE SUMMARY

Howe Gastmeier Chapnik Limited (“HGC Engineering”) was retained by IPC Energy on behalf of Vineland Power Inc. to assess the acoustic impact of the proposed HAF Wind Energy Project to be located in the Township of West Lincoln, Ontario. The project will consist of five Vestas V100 wind turbine generators, each rated at 1.8 MW. HGC Engineering has assessed the acoustic impact against the acoustic criteria of the Ontario Ministry of Environment (“MOE”). This report comprises a summary of our assessment and is intended as supporting documentation for an application for a Renewable Energy Approval.

The wind farm site is within the Township of West Lincoln, in the Niagara Region. There are a number of residences located in the vicinity of the project. From an acoustic perspective the area is rural with relatively low ambient sound levels during nighttime hours at all locations.

Unattended and attended sound level monitoring were conducted by HGC Engineering from August 26 until September 9, 2010 to gain an understanding of the existing background sound levels at several representative noise sensitive receptors. The criteria of the MOE’s publication NPC-232 *Sound Level Limits for Stationary Sources in Class 3 Areas (Rural)* are thus relevant. Supplementary guidance is also provided by MOE publication *Interpretation for Applying MOE NPC Publications to Wind Power Generation Facilities*.

The sound power data for the Vestas wind turbine generators has been obtained through IPC Energy. This data has been used in a computer model to predict the sound level impact at the closest residential receptors. The results of the modelling demonstrate compliance with the MOE guidelines when all five turbines are operating over their entire speed range, at all but four receptors locations. These receptor locations have entered into lease agreements with the proponent.

Details of our assessment are provided in the main body of this report. The report is structured around the report format suggested by the MOE for Renewable Energy Approval applications for wind farms, with the required summary tables included as Appendix A.

ACOUSTIC ASSESSMENT REPORT CHECK-LIST

Company Name: Vineland Power Inc.

Company Address: 222 Martindale Road
St. Catharines, Ontario, L2R 7A3

Location of Facility: Township of West Lincoln, Ontario

The attached Acoustic Assessment Report was prepared in accordance with the guidance in the ministry document "Information to be Submitted for Approval of Stationary Source of Sound" (NPC 233) dated October 1995 and the minimum required information identified in the check-list on the reverse of this sheet has been submitted.

Company Contact:

Name: Jordan Beekhuis

Title: Project Engineer

Phone Number: 905-684-1111

Signature: 

Date: March 25, 2013

Technical Contact:

Name: Ian Bonsma, PEng

Representing: HGC Engineering

Phone Number: 905-826-4044

Signature: 

Date: March 25, 2013

ACOUSTIC ASSESSMENT REPORT CHECK-LIST

| Required Information | | Submitted | Explanation/Reference |
|----------------------|---|---|---|
| 1.0 | Introduction (Project Background and Overview) | <input checked="" type="checkbox"/> Yes | Section 1 |
| 2.0 | Facility Description | | |
| | 2.1 Operating hours of facility and significant Noise Sources | <input checked="" type="checkbox"/> Yes | |
| | 2.2 Site Plan identifying all significant Noise Sources | <input checked="" type="checkbox"/> Yes | Figure 2 |
| 3.0 | Noise Source Summary | | |
| | 3.1 Noise Source Summary Table | <input checked="" type="checkbox"/> Yes | Appendix A |
| | 3.2 Source noise emissions specifications | <input checked="" type="checkbox"/> Yes | Appendix D |
| | 3.3 Source power/capacity ratings | <input checked="" type="checkbox"/> Yes | Appendix D |
| | 3.4 Noise control equipment description and acoustical specifications | <input type="checkbox"/> No | N/A |
| 4.0 | Point of Reception Noise Impact Calculations | | |
| | 4.1 Point of Reception Noise Impact Table | <input checked="" type="checkbox"/> Yes | Appendix A |
| | 4.2 Point(s) of Reception (POR) list and description | <input checked="" type="checkbox"/> Yes | Table A3, A4 |
| | 4.3 Land-use Zoning Plan | <input checked="" type="checkbox"/> Yes | Appendix B |
| | 4.4 Scaled Area Location Plan | <input checked="" type="checkbox"/> Yes | Figure 1 |
| | 4.5 Procedure used to assess noise impacts at each POR | <input checked="" type="checkbox"/> Yes | Section 7, Appendix E |
| | 4.6 List of parameters/assumptions used in calculations | <input checked="" type="checkbox"/> Yes | Section 7, Appendix E |
| 5.0 | Acoustic Assessment Summary | | |
| | 5.1 Acoustic Assessment Summary Table | <input checked="" type="checkbox"/> Yes | Appendix A |
| | 5.2 Rationale for selecting applicable noise guideline limits | <input checked="" type="checkbox"/> Yes | Section 6 |
| | 5.3 Predictable Worst Case Impacts Operating Scenario | <input checked="" type="checkbox"/> Yes | Figure 4, Table A5 & A6 |
| 6.0 | Conclusions | | |
| | 6.1 Statement of compliance with selected noise performance limits | <input checked="" type="checkbox"/> Yes | |
| 7.0 | Appendices (provide details such as) | <input checked="" type="checkbox"/> Yes | |
| | Listing of Insignificant Noise Sources | <input checked="" type="checkbox"/> Yes | |
| | Manufacturer's Noise Specifications | <input checked="" type="checkbox"/> Yes | Appendix D |
| | Calculations | <input checked="" type="checkbox"/> Yes | Appendix E |
| | Instrumentation | <input checked="" type="checkbox"/> Yes | |
| | Meteorology during Sound Level Measurements | <input checked="" type="checkbox"/> Yes | |
| | Raw Data from Measurements | <input checked="" type="checkbox"/> Yes | N/A |
| | Drawings (Facility / Equipment) | <input checked="" type="checkbox"/> Yes | Appendix C |

1 INTRODUCTION

Howe Gastmeier Chapnik Limited (“HGC Engineering”) was retained by IPC Energy on behalf of Vineland Power Inc. to assess the acoustic impact of the proposed HAF Wind Energy Project. The purpose of this report is to determine the acceptability of the predicted sound levels at the nearby residential receptors resulting from the operation of five, 95 metre hub height, Vestas V100 wind turbine generators, rated at 1.8 MW, in relation to the guidelines of the Ontario Ministry of the Environment (“MOE”) including Ontario Regulation 359/09. Based on Ontario Regulation 359/09, the project is considered a Class 4 wind facility.

HGC Engineering conducted background sound level monitoring at a number of representative residences within the influence area of the proposed HAF Wind Energy Project. Unattended sound level monitoring was conducted between August 26 and September 9, 2010. Attended sound level measurements were also conducted during this period.

This report is intended as supporting documentation for a Renewable Energy Approval application for the facility.

UPDATES ADDRESSED IN THIS ASSESSMENT REPORT

This report replaces the *Acoustic Assessment Report HAF Wind Energy Project*, Version 3 dated February 1, 2012 [1]. This update has been prepared to address comments from the MOE. Version 2 of the Acoustic Assessment Report included modifications to and the addition of, a number of receptor locations. Table 1 shows the receptor locations and ID’s which were modified as part of Version 2.

Table 1: Receptor Modifications

| Old Point of Reception ID | UTM Coordinates | | New Point of Reception ID | UTM Coordinates | | Difference between UTM Coordinates (m) |
|---------------------------|-----------------|----------|---------------------------|-----------------|----------|--|
| | Easting | Northing | | Easting | Northing | |
| V10 | 607871 | 4774877 | R242 | 607843 | 4774953 | 81 |
| V13 | 608174 | 4773364 | R243 | 608164 | 4773488 | 124 |
| V14 | 608014 | 4773320 | R244 | 608024 | 4773318 | 11 |
| V15 | 608076 | 4773293 | R245 | 608072 | 4773301 | 9 |
| V17 | 607367 | 4772299 | R246 | 607464 | 4772330 | 102 |
| V19 | 607479 | 4772131 | R247 | 607470 | 4772078 | 54 |
| V21 | 607117 | 4772302 | R248 | 607124 | 4772293 | 12 |
| V22 | 607067 | 4772342 | R249 | 607055 | 4772362 | 23 |
| V23 | 607008 | 4772370 | R250 | 607002 | 4772362 | 10 |
| V24 | 607016 | 4772266 | R251 | 607055 | 4772245 | 44 |
| V25 | 607033 | 4771952 | R252 | 607134 | 4771769 | 209 |
| V26 | 606867 | 4772428 | R253 | 606898 | 4772235 | 196 |
| V34 | 605062 | 4771905 | R254 | 605124 | 4771909 | 62 |
| V35 | 605275 | 4771781 | R255 | 605299 | 4771766 | 28 |
| V36 | 605342 | 4771759 | R256 | 605349 | 4771741 | 19 |
| V37 | 605462 | 4771727 | R257 | 605460 | 4771805 | 78 |
| V38 | 606246 | 4771380 | R258 | 606059 | 4771413 | 190 |

2 GENERAL DESCRIPTION OF WIND TURBINE INSTALLATION SITE AND SURROUNDING ENVIRONMENT

The wind project consists of five wind turbine generators to be located in the Township of West Lincoln, south of Grimsby and east of Hamilton. All of the wind turbine generators will be sited east of Westbrook Road, west of Caistor Centre Road and Abingdon Road, south of 20 Road and north of Concession Road 5. Figure 1a, a wind turbine generator siting drawing prepared by IPC Energy, illustrates the location of the five wind turbine generators, and the location of the nearest residential receptors. Figure 1b, is a scaled location map of the surrounding area.

The area is rural in nature, both acoustically and in general character, with agricultural land uses widely in evidence, including scattered dwellings near the major roadways. Zoning maps obtained from the Township of West Lincoln are included as Appendix B, which illustrate that the project

site areas are zoned for Agricultural use, and that small residential and commercial parcels exist, generally near Abingdon along Regional Road 65.

3 DESCRIPTION OF SOUND SOURCES

Five 1.8 MW Vestas V100 wind turbine generators are proposed for the site. They are three bladed, upwind, horizontal axis wind turbines with a rotor diameter of 100 m. The turbine rotor and nacelle are mounted on top of a 95 m high tubular tower. The turbines are anticipated to operate continuously whenever wind conditions allow. Additional details are contained in Appendix C, with acoustic information contained in Appendix D. Electronic topology mapping for the area suggests that the turbines will generally be based at an elevation of between about 195 to 200 metres above sea level. Table 2 provides the UTM coordinates (Zone 17) of the five wind turbine generators.

Table 2: Locations of Wind Turbine Generators (WTG) [m]

| Source | Easting | Northing |
|---------------|----------------|-----------------|
| WTG 1 | 604718 | 4775553 |
| WTG 2 | 604889 | 4775173 |
| WTG 3 | 606291 | 4774905 |
| WTG 4 | 604359 | 4774307 |
| WTG 5 | 606233 | 4773420 |

Please note that the Vestas V100 wind turbines have nacelle mounted transformers and therefore there will be no ground level transformers part of this project. The sound power level of the wind turbines includes the sound power of the nacelle mounted transformer. This project does not include a larger step-up transformer. The electrical connection for this project will be at a switching station with UTM coordinates presented in Table 3.

Table 3: Location of Switching Station [m]

| Source | Easting | Northing |
|-------------------|----------------|-----------------|
| Switching Station | 606822 | 4773919 |

4 WIND TURBINE NOISE EMISSION RATINGS

Overall sound power data for the Vestas V100 wind turbines as determined in accordance with IEC 61400-11:2002 [2], are provided by Vestas in the document *Sound Power Level Data for the V100-1.8 MW* [3] and in the form of a letter issued to IPC Energy [4]. CAN/CSA-C61400-11-07 standard, referenced by the MOE, is an adoption without modification of the identically titled IEC Standard IEC 61400-11 (edition 2:2002 consolidated with amendment 1:2006). Additionally, a test report completed by DNV Renewables (USA) Inc., *Acoustic Noise Test Report for a Vestas V100 1.8 MW Turbine at Pueblo, Colorado* [5], is also included under Appendix D. The overall A-weighted sound power levels as a function of 10 meter height wind speed are shown in Table 4.

Table 4: 10 Metre Height Wind Speed vs Turbine Sound Power Level, Based on IEC Sound Power Determination Methodology and Wind Shear of 0.2

| Wind Speed [m/s] at 10m Height | 6 | 7 | 8 | 9 | 10 – cutout |
|--------------------------------------|-------|-------|-------|-------|-------------|
| Wind Turbine Sound Power Level [dBA] | 103.3 | 105.0 | 105.0 | 105.0 | 105.0 |

Sound power level data determined under IEC 61400-11 is normalized to a standard “roughness length” value of 0.05 m. The roughness length concept is used to take into account the effect of friction at the ground, which results in lower wind speeds near the ground than at higher elevations. The wind shear exponent quantifies the same concept by describing the rate of change of windspeed with elevation. A roughness length of 0.05 m is generally held to be equivalent to a wind shear value of about 0.2. Meteorological data near the proposed wind project provided by IPC Energy indicates that the average summer nighttime wind shear was found to be on the order of 0.6 (see Appendix F). This means that a 10 m height wind speed of 1.8 m/s can occur simultaneously with a 7 m/s wind speed at the hub height of 95 m, indicating that maximum sound power output may occur during relatively low 10 m level wind speeds. Consequently the maximum sound power level for the wind turbine (corresponding to a hub height wind speed of 7 m/s) has been used in this analysis.

Table 5 presents the typical octave band spectrum for various 10 m height wind speeds received from Vestas, also included in Appendix D. The spectral shape shown for the 10 m height 7 m/s wind speed has been used in the analysis.

Table 5: Wind Turbine Acoustic Emissions Summary

| Make and Model: | Vestas V100 | | | | | | | | | |
|--------------------------------|---|----------|----------|----------|-----------|-------------------------|----------|----------|----------|-----------|
| Electrical Rating: | 1800 kW | | | | | | | | | |
| Hub Height (m): | 95m | | | | | | | | | |
| Wind Shear Coefficient: | Maximum sound power level utilized to account for average summer nighttime wind shear value of 0.6. | | | | | | | | | |
| | Octave Band Sound Power Level [dB] | | | | | | | | | |
| | Manufacturer's Emission Levels | | | | | Adjusted Emission Level | | | | |
| Wind Speed [m/s] | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| Frequency [Hz] | | | | | | | | | | |
| 63 | 111.4 | 113.6 | 113.3 | 112.9 | 112.8 | 113.6 | 113.6 | 113.6 | 113.6 | 113.6 |
| 125 | 105.7 | 108.1 | 107.8 | 107.4 | 107.5 | 108.1 | 108.1 | 108.1 | 108.1 | 108.1 |
| 250 | 101.6 | 103.3 | 102.8 | 102.2 | 102.1 | 103.3 | 103.3 | 103.3 | 103.3 | 103.3 |
| 500 | 98.6 | 100.3 | 99.9 | 99.3 | 99.3 | 100.3 | 100.3 | 100.3 | 100.3 | 100.3 |
| 1000 | 98.2 | 99.7 | 99.5 | 99.0 | 99.1 | 99.7 | 99.7 | 99.7 | 99.7 | 99.7 |
| 2000 | 95.4 | 97.0 | 97.2 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 |
| 4000 | 93.6 | 95.6 | 96.2 | 97.7 | 97.6 | 95.6 | 95.6 | 95.6 | 95.6 | 95.6 |
| 8000 | 86.5 | 90.9 | 91.4 | 92.5 | 93.4 | 90.9 | 90.9 | 90.9 | 90.9 | 90.9 |
| Overall A-Weighted | 103.3 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 |

Vestas has indicated that the tonal audibility value for these wind turbines, as per IEC 61400-11-ed2:2002, will be less than 2 dBA. A tonal penalty has not been applied in this assessment.

Additionally, Vestas has also indicated that the sound power levels provided have a measurement uncertainty of +/- 2 dBA. The sound level predictions herein are subject to the degree of uncertainty related to the sound power of the turbine, in addition to the uncertainty related to the fluctuations of atmospheric conditions and the accuracy and limitations inherent in the modelling methodology.

5 POINT OF RECEPTION SUMMARY

As shown in Figure 2, there are several residences in the vicinity of the project, generally sited along the major roadways. The closest noise sensitive receptors have been identified on Figure 2. A table of UTM co-ordinates for 294 receptors, including vacant lots, located near the proposed wind turbine generators was received from Vineland Power Inc.. The existing receptors and vacant lots, together with their coordinates are listed in Tables A3 and A4. For the purposes of this report, each of the 294 receptors was represented by a discrete sound prediction location at the dwelling coordinate, with an assumed height of 4.5 metres above the local grade to represent potential second-story windows. Where vacant lots were identified, the assumed future location of the dwelling was selected to be consistent with the typical building pattern in the area. Vineland Power Inc. has indicated all receptors within the study area are two storey's or less.

A number of the receptors identified have agreements with the developer. These receptors are identified as participating receptors by the MOE. According to the publication *Interpretation for Applying MOE NPC Publications to Wind Power Generation Facilities*, October 2008 (*"Interpretation"*) [6], a participating receptor "means a property that is associated with the Wind Farm by means of a legal agreement with the property owner for the installation and operation of wind turbines or related equipment located on that property."

Table A3 includes non-participating receptors while Table A4 includes the details of the participating receptors.

6 ASSESSMENT CRITERIA

The MOE publication NPC-232 *Sound Level Limits for Stationary Sources in Class 3 Areas (Rural)* [7] indicates that the applicable sound level limit for a stationary source of sound is the background sound level. However, where background sound levels are low, exclusionary minimum criteria apply, with an exclusionary limit of 40 dBA specified for quiet night time periods, and 45 dBA specified for quiet daytime periods. To determine if the minimum criteria should apply, an ambient baseline sound study was conducted from August 26 to September 9,

2010. Typical L_{EQ} sound levels on the order of 50 dBA were recorded with ninetieth percentile sound levels (L_{90}) falling as low as 37 dBA during nighttime hours. The L_{90} sound levels indicate that the area is acoustically rural, and that the minimum limits apply.

Because wind turbines generate more sound as the wind speeds increase, and because increasing wind speeds tend to cause greater background sound levels, wind turbine generators have been identified by the MOE as a unique case, and the MOE has provided supplementary guidance for the assessment of wind turbine noise in *Interpretation*. This publication provides criteria for the combined impact of all turbines in an area as a function of 10 metre height wind speed. The criteria are presented in A-weighted decibels, as shown in Table 6.

Table 6: Wind Turbine Noise Criteria [dBA]

| Wind Speed [m/s] at 10 m Height | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|---|------|------|------|------|------|------|------|
| Wind Turbine Sound Level Limits Class 3 Area, [dBA] | 40.0 | 40.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

It should be noted that the MOE guidelines, including NPC-232 and *Interpretation* do not require or imply that a noise source should be inaudible at a point of reception, and inaudibility should not be expected. In fact, even when the sound levels from a source are less than the numeric guideline limits, spectral and temporal characteristics of a sound regularly result in audibility at points of reception. To be clear, wind turbines may be audible at residences even when sound levels are below MOE guidelines noise criteria.

In the case of this assessment, the sound power output is assumed to be constant at the maximum value of 105.0 dBA over the full range of hub height wind speeds due to the summer nighttime wind shear exponent. Thus, this assessment is based on the minimum criteria of 40 dBA and the maximum wind turbine sound power level.

7 IMPACT ASSESSMENT

An acoustic model of the site was created on a computer using Cadna/A (version 4.3.143), a commercial acoustic modeling system. Cadna/A uses the computational procedures of ISO 9613-2, *Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation* [8], which accounts for reduction in sound level with distance due to geometrical spreading, air absorption, ground attenuation and acoustical shielding by intervening structures (or by topography and foliage where applicable). This is the standard that is specified by *Interpretation* to be used in the assessment of wind project noise.

Topographical data for the site and surrounding area was provided by IPC Energy. Ground attenuation was assumed to be spectral for all sources, with the ground factor (G) assumed to be 0.7 globally. The temperature and relative humidity were assumed to be 10° C and 70%, respectively. Stands of foliage were not modelled. There are no known wind projects, outside of the proposed, within 5 km.

All wind turbine generators were modeled as point sources at a height of 95 metres above grade. Figure 2 presents the acoustic model, with the source and receptor locations shown. Figure 3 is a noise contour map of the area surrounding the facility produced by Cadna/A based on the octave band sound power levels corresponding to the overall 105.0 dBA sound power, at a 10 m height wind speed of 7 m/s. The required summary tables are contained in Appendix A of this report.

Tables A5 and A6 list the sound pressure levels calculated at each of the identified receptor locations. In general, sound levels are predicted to be at or below the 40.0 dBA minimum criterion at all but four participating receptor locations. At these participating receptors, sound levels of up to 42.9 dBA are predicted. The owners of these properties have entered into lease agreements with the proponent and include a wind turbine or related infrastructure on the properties. These receptors are considered herein to be part of the project (i.e. participating receptors) and not sensitive receptors for the purposes of sound level impact. Details of the

calculations are provided in Appendix E. The Cadna/A computer model can be provided upon request.


When conducting an acoustic audit of a conventional stationary industrial sound source, the MOE guidelines direct that periods of high wind be excluded. Typically, the noise output of industrial sound sources is independent of wind speed. However, this is not the case for wind plants and there is an intrinsic relationship between wind speed (and therefore ambient noise) and increased sound power levels associated with the wind turbine generators. Complicating matters, there is a large degree of variability related to environmental factors within the wind plant area including, among others, local ground level wind speeds, wind speeds affecting the wind turbine generator blades, the associated wind shear, and the sound power of the wind turbine generators, all of which affect the measured sound levels. Thus, it is not realistic to expect that in practice a single repeatable sound level can or will be measured for a given wind speed at a given setback distance; a simple comparison of single numbers is not sufficient or possible.

8 CONCLUSIONS AND RECOMMENDATIONS


The analysis, performed in accordance with the methods prescribed by the Ontario Ministry of the Environment in publication *Interpretation for Applying MOE NPC Publications to Wind Power Generation Facilities*, October 2008, indicates that the operation of the proposed wind project will comply with the requirements of the MOE publication NPC-232 *Sound Level Limits for Stationary Sources in Class 3 Areas (Rural)* for all identified non-participating receptor locations.

REFERENCES

1. Howe Gastmeier Chapnik Limited, *Acoustic Assessment Report, HAF Wind Energy Project*, Version 2, February 1, 2013.
2. CAN/CSA-C61400-11-07, *Wind Turbine Generator Systems – Part 11: Acoustic noise measurement techniques*, Edition 2.1, 2006-11.
3. Vestas, *Sound Power Level Data for the V100-1.8MW*
4. Vestas, *Warranted Sound Power Level and Tonality for the Vestas V100-1.8MW for the Vineland Power Inc. and Wainfleet Wind Energy Inc. Projects*, dated December 1, 2010.
5. DNV Renewables (USA) Inc., *Acoustic Noise Test Report for a Vestas V100 1.8MW Turbine at Pueblo, Colorado*, May 11, 2011.
6. Ontario Ministry of the Environment Publication *Noise Guidelines for Wind Farms, Interpretation for Applying MOE NPC Publications to Wind Power Generation Facilities*, October, 2008.
7. Ontario Ministry of the Environment Publication NPC-232, *Sound Level Limits for Stationary Sources in Class 3 Areas (Rural)*, October, 1995.
8. International Organization for Standardization, “Acoustics – Attenuation of Sound during Propagation Outdoors – Part 2: General Method of Calculation,” ISO-9613-2, Switzerland, 1996.
9. Google Maps Aerial Imagery, Internet Application: *maps.google.com*



- ### Legend
- Turbines
 - AccessRoads
 - TapLine
 - Streams
 - Lakes
 - Forests
 - Roads
 - OptionedProperties
 - Switching Station
 - Maintenance Building



Project Name:
HAF Energy Wind Power

Project Title:
**Alternative Site Plan A
(Draft Representation)**

Map Scale:
1:15,000

0 125 250 500 750 1,000 Meters

Version 7 dated March 26, 2012
Created by Geoff Bell, IPC Energy
All coordinates are expressed in UTM 17N NAD83






Figure 1b: Key Location Plan





Legend

- Proposed Turbine Location
- 40 dBA Sound Contour
- Participating Property

0 0.25 0.5 km
Scale 1:7,500

Figure 3: Predicted Sound Levels, Leq [dBA]
Vineland Power HAF Wind Energy Project
Sound Level Grid Height Calculated at 4.5m

Map © 2013 HCC ENGINEERING

**APPENDIX A:
ASSESSMENT SUMMARY TABLES**

ACOUSTIC ASSESSMENT SUMMARY TABLES
VERSION CONTROL

HAF Wind Energy Project, Township of West Lincoln, Ontario

| Ver. | Date | Issued as Part of AAR? | Revision Description | Prepared By |
|-------------|----------------------|---------------------------------------|---|--------------------|
| 1 | December 9, 2010 | Y | Original version of tables as part of Ver. 1 of Acoustic Assessment Report | M. Munro |
| 2 | September 9, 2011 | Y | Updated tables as part of Ver. 2 of the Acoustic Assessment Report | M. Munro |
| 3 | February 1, 2013 | Y | Updated tables as part of Ver. 3 of the Acoustic Assessment Report | I. Bonsma |
| 4 | March 25, 2013 | Y | Updated tables as part of Ver. 4 of the Acoustic Assessment Report | I. Bonsma |
| | | | | |

**Table A1: Vestas V100 Wind Turbine Acoustic Emissions Summary
Vineland Power, HAF Wind Energy Project**

| Make and Model: | Vestas V100 | | | | | | | | | |
|--------------------------------|--|----------|----------|----------|-----------|-------------------------|----------|----------|----------|-----------|
| Electrical Rating: | 1800 kW | | | | | | | | | |
| Hub Height (m): | 95m | | | | | | | | | |
| Wind Shear Coefficient: | Maximum sound power level utilized to account for average summer nighttime wind shear value of 0.6 | | | | | | | | | |
| | Octave Band Sound Power Level [dB] | | | | | | | | | |
| | Manufacturer's Emission Levels | | | | | Adjusted Emission Level | | | | |
| Wind Speed [m/s] | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| Frequency [Hz] | | | | | | | | | | |
| 63 | 111.4 | 113.6 | 113.3 | 112.9 | 112.8 | 113.6 | 113.6 | 113.6 | 113.6 | 113.6 |
| 125 | 105.7 | 108.1 | 107.8 | 107.4 | 107.5 | 108.1 | 108.1 | 108.1 | 108.1 | 108.1 |
| 250 | 101.6 | 103.3 | 102.8 | 102.2 | 102.1 | 103.3 | 103.3 | 103.3 | 103.3 | 103.3 |
| 500 | 98.6 | 100.3 | 99.9 | 99.3 | 99.3 | 100.3 | 100.3 | 100.3 | 100.3 | 100.3 |
| 1000 | 98.2 | 99.7 | 99.5 | 99.0 | 99.1 | 99.7 | 99.7 | 99.7 | 99.7 | 99.7 |
| 2000 | 95.4 | 97.0 | 97.2 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 | 97.0 |
| 4000 | 93.6 | 95.6 | 96.2 | 97.7 | 97.6 | 95.6 | 95.6 | 95.6 | 95.6 | 95.6 |
| 8000 | 86.5 | 90.9 | 91.4 | 92.5 | 93.4 | 90.9 | 90.9 | 90.9 | 90.9 | 90.9 |
| Overall A-Weighted | 103.3 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 | 105.0 |

Table A2: Wind Turbine Locations
Vineland Power, HAF Wind Energy Project

| Identifier | Equipment Make & Model | UTM Coordinates | |
|------------|------------------------------|-----------------|----------|
| | | Easting | Northing |
| WTG 1 | Vestas V100, 95 m Hub Height | 604718 | 4775553 |
| WTG 2 | Vestas V100, 95 m Hub Height | 604889 | 4775173 |
| WTG 3 | Vestas V100, 95 m Hub Height | 606291 | 4774905 |
| WTG 4 | Vestas V100, 95 m Hub Height | 604359 | 4774307 |
| WTG 5 | Vestas V100, 95 m Hub Height | 606233 | 4773420 |

Table A3: Non-Participating Receptor Locations
Vineland Power, HAF Wind Energy Project

| Point of Reception ID | Description | UTM Coordinates | |
|-----------------------|----------------------------|-----------------|---------|
| | | Easting | Westing |
| R001 | Non-Participating Receptor | 605650 | 4773240 |
| R002 | Non-Participating Receptor | 603247 | 4772605 |
| R003 | Non-Participating Receptor | 603254 | 4772672 |
| R004 | Non-Participating Receptor | 603301 | 4773589 |
| R005 | Non-Participating Receptor | 603306 | 4773633 |
| R006 | Non-Participating Receptor | 603634 | 4773998 |
| R007 | Non-Participating Receptor | 603365 | 4773808 |
| R008 | Non-Participating Receptor | 603386 | 4773180 |
| R009 | Non-Participating Receptor | 603374 | 4773842 |
| R010 | Non-Participating Receptor | 607486 | 4773574 |
| R011 | Non-Participating Receptor | 603409 | 4772552 |
| R012 | Non-Participating Receptor | 603413 | 4772587 |
| R013 | Non-Participating Receptor | 603457 | 4772569 |
| R014 | Non-Participating Receptor | 603527 | 4772509 |
| R015 | Non-Participating Receptor | 603580 | 4775203 |
| R016 | Non-Participating Receptor | 603594 | 4772427 |
| R017 | Non-Participating Receptor | 603634 | 4774736 |
| R018 | Non-Participating Receptor | 603639 | 4774864 |
| R019 | Non-Participating Receptor | 605987 | 4772878 |
| R020 | Non-Participating Receptor | 603654 | 4772358 |
| R021 | Non-Participating Receptor | 603655 | 4772473 |
| R022 | Non-Participating Receptor | 603681 | 4774892 |
| R023 | Non-Participating Receptor | 603691 | 4775182 |
| R024 | Non-Participating Receptor | 603787 | 4775428 |
| R025 | Non-Participating Receptor | 604657 | 4776539 |
| R026 | Non-Participating Receptor | 603813 | 4775415 |
| R027 | Non-Participating Receptor | 604160 | 4775998 |
| R028 | Non-Participating Receptor | 603834 | 4776027 |
| R029 | Non-Participating Receptor | 603842 | 4775407 |
| R030 | Non-Participating Receptor | 603860 | 4772369 |
| R031 | Non-Participating Receptor | 603876 | 4772600 |
| R032 | Non-Participating Receptor | 603885 | 4772362 |
| R033 | Non-Participating Receptor | 604268 | 4773661 |
| R034 | Non-Participating Receptor | 603891 | 4775200 |
| R035 | Non-Participating Receptor | 603631 | 4775471 |
| R036 | Non-Participating Receptor | 603967 | 4775619 |
| R037 | Non-Participating Receptor | 603674 | 4775789 |
| R038 | Non-Participating Receptor | 604020 | 4772236 |
| R039 | Non-Participating Receptor | 604024 | 4772292 |
| R040 | Non-Participating Receptor | 604101 | 4775955 |
| R041 | Non-Participating Receptor | 604095 | 4772175 |
| R042 | Non-Participating Receptor | 604109 | 4776608 |
| R043 | Non-Participating Receptor | 604050 | 4775904 |
| R044 | Non-Participating Receptor | 603741 | 4772522 |
| R045 | Non-Participating Receptor | 604307 | 4772252 |
| R046 | Non-Participating Receptor | 604351 | 4772223 |

| Point of Reception ID | Description | UTM Coordinates | |
|-----------------------|----------------------------|-----------------|---------|
| | | Easting | Westing |
| R047 | Non-Participating Receptor | 604392 | 4772210 |
| R048 | Non-Participating Receptor | 604433 | 4772192 |
| R049 | Non-Participating Receptor | 604450 | 4772079 |
| R050 | Non-Participating Receptor | 604481 | 4772159 |
| R051 | Non-Participating Receptor | 604670 | 4776353 |
| R052 | Non-Participating Receptor | 604981 | 4776234 |
| R053 | Non-Participating Receptor | 605034 | 4776201 |
| R054 | Non-Participating Receptor | 607019 | 4773125 |
| R055 | Non-Participating Receptor | 606902 | 4774665 |
| R056 | Non-Participating Receptor | 605020 | 4776145 |
| R057 | Non-Participating Receptor | 605305 | 4776000 |
| R058 | Non-Participating Receptor | 604805 | 4776430 |
| R059 | Non-Participating Receptor | 604999 | 4773621 |
| R060 | Non-Participating Receptor | 605060 | 4774364 |
| R061 | Non-Participating Receptor | 605410 | 4776037 |
| R062 | Non-Participating Receptor | 605568 | 4775888 |
| R063 | Non-Participating Receptor | 605590 | 4774451 |
| R064 | Non-Participating Receptor | 605657 | 4775882 |
| R065 | Non-Participating Receptor | 605708 | 4775943 |
| R066 | Non-Participating Receptor | 605710 | 4772959 |
| R067 | Non-Participating Receptor | 605882 | 4774457 |
| R068 | Non-Participating Receptor | 605726 | 4774519 |
| R069 | Non-Participating Receptor | 605833 | 4775945 |
| R070 | Non-Participating Receptor | 605819 | 4774490 |
| R071 | Non-Participating Receptor | 605832 | 4774384 |
| R072 | Non-Participating Receptor | 606537 | 4775561 |
| R073 | Non-Participating Receptor | 605907 | 4775894 |
| R074 | Non-Participating Receptor | 605996 | 4774315 |
| R075 | Non-Participating Receptor | 606977 | 4773918 |
| R076 | Non-Participating Receptor | 606997 | 4773430 |
| R077 | Non-Participating Receptor | 606402 | 4774198 |
| R078 | Non-Participating Receptor | 606473 | 4775589 |
| R079 | Non-Participating Receptor | 606410 | 4775612 |
| R080 | Non-Participating Receptor | 606111 | 4775809 |
| R081 | Non-Participating Receptor | 606335 | 4775728 |
| R082 | Non-Participating Receptor | 606243 | 4775609 |
| R083 | Non-Participating Receptor | 606492 | 4775703 |
| R084 | Non-Participating Receptor | 606988 | 4775394 |
| R085 | Non-Participating Receptor | 606557 | 4772527 |
| R086 | Non-Participating Receptor | 606736 | 4775546 |
| R087 | Non-Participating Receptor | 606815 | 4772555 |
| R088 | Non-Participating Receptor | 606965 | 4774631 |
| R089 | Non-Participating Receptor | 606965 | 4774686 |
| R090 | Non-Participating Receptor | 606756 | 4772576 |
| R091 | Non-Participating Receptor | 607037 | 4775217 |
| R092 | Non-Participating Receptor | 606699 | 4772616 |
| R093 | Non-Participating Receptor | 607071 | 4774252 |
| R094 | Non-Participating Receptor | 606479 | 4772736 |

| Point of Reception ID | Description | UTM Coordinates | |
|--------------------------|----------------------------|-----------------|---------|
| | | Easting | Westing |
| R095 | Non-Participating Receptor | 606874 | 4772513 |
| R096 | Non-Participating Receptor | 606905 | 4774043 |
| R097 | Non-Participating Receptor | 606965 | 4772481 |
| R098 | Non-Participating Receptor | 607195 | 4775123 |
| R099 | Non-Participating Receptor | 606960 | 4774755 |
| R100 | Non-Participating Receptor | 607281 | 4775309 |
| R101 | Non-Participating Receptor | 607301 | 4775057 |
| R102 | Non-Participating Receptor | 607288 | 4773683 |
| R103 | Non-Participating Receptor | 607207 | 4775216 |
| R104 | Non-Participating Receptor | 607517 | 4772128 |
| R105 | Non-Participating Receptor | 607787 | 4775239 |
| R106 | Non-Participating Receptor | 607405 | 4775291 |
| R107 | Non-Participating Receptor | 607726 | 4772109 |
| R108 | Non-Participating Receptor | 607747 | 4772086 |
| R109 | Non-Participating Receptor | 607796 | 4775050 |
| R110 | Non-Participating Receptor | 607774 | 4772088 |
| R111 | Non-Participating Receptor | 607774 | 4775154 |
| R112 | Non-Participating Receptor | 607627 | 4774954 |
| R113 | Non-Participating Receptor | 607043 | 4773799 |
| R114 | Non-Participating Receptor | 607673 | 4773299 |
| R115 | Non-Participating Receptor | 606963 | 4774380 |
| R116 | Non-Participating Receptor | 606409 | 4772743 |
| R117 | Non-Participating Receptor | 605556 | 4773065 |
| R118 | Non-Participating Receptor | 606021 | 4772661 |
| R119 | Non-Participating Receptor | 603898 | 4773715 |
| R120 | Non-Participating Receptor | 606031 | 4774379 |
| R121 | Non-Participating Receptor | 606992 | 4773820 |
| R122 | Non-Participating Receptor | 606891 | 4773887 |
| R123 | Non-Participating Receptor | 607011 | 4773349 |
| R124 | Non-Participating Receptor | 606301 | 4775649 |
| R125 | Non-Participating Receptor | 604552 | 4777564 |
| R126 | Non-Participating Receptor | 604554 | 4777529 |
| R127 | Non-Participating Receptor | 604427 | 4777504 |
| R128 | Non-Participating Receptor | 604543 | 4777503 |
| R129 | Non-Participating Receptor | 604535 | 4777473 |
| R130 | Non-Participating Receptor | 604522 | 4777444 |
| R131 | Non-Participating Receptor | 604525 | 4777408 |
| R132 | Non-Participating Receptor | 604415 | 4777382 |
| R133 | Non-Participating Receptor | 604409 | 4777355 |
| R134 | Non-Participating Receptor | 604401 | 4777326 |
| R135 | Non-Participating Receptor | 604479 | 4777297 |
| R136 | Non-Participating Receptor | 604389 | 4777296 |
| R137 | Non-Participating Receptor | 604067 | 4777238 |
| R138 | Non-Participating Receptor | 604364 | 4777236 |
| R139 | Non-Participating Receptor | 604107 | 4777216 |
| R140 | Non-Participating Receptor | 604178 | 4777205 |
| R141 | Non-Participating Receptor | 604143 | 4777203 |
| R142 | Non-Participating Receptor | 604207 | 4777193 |

| Point of Reception ID | Description | UTM Coordinates | |
|--------------------------|----------------------------|-----------------|---------|
| | | Easting | Westing |
| R143 | Non-Participating Receptor | 604273 | 4777181 |
| R144 | Non-Participating Receptor | 604235 | 4777181 |
| R145 | Non-Participating Receptor | 603565 | 4777166 |
| R146 | Non-Participating Receptor | 604329 | 4777163 |
| R147 | Non-Participating Receptor | 604452 | 4777135 |
| R148 | Non-Participating Receptor | 604322 | 4777092 |
| R149 | Non-Participating Receptor | 605548 | 4776935 |
| R150 | Non-Participating Receptor | 605650 | 4776892 |
| R151 | Non-Participating Receptor | 604432 | 4776882 |
| R152 | Non-Participating Receptor | 606391 | 4776835 |
| R153 | Non-Participating Receptor | 604250 | 4776823 |
| R154 | Non-Participating Receptor | 604404 | 4776811 |
| R155 | Non-Participating Receptor | 604172 | 4776799 |
| R156 | Non-Participating Receptor | 604246 | 4776785 |
| R157 | Non-Participating Receptor | 604163 | 4776773 |
| R158 | Non-Participating Receptor | 604298 | 4776751 |
| R159 | Non-Participating Receptor | 604396 | 4776743 |
| R160 | Non-Participating Receptor | 604158 | 4776719 |
| R161 | Non-Participating Receptor | 604639 | 4776529 |
| R162 | Non-Participating Receptor | 607923 | 4776049 |
| R163 | Non-Participating Receptor | 607839 | 4776021 |
| R164 | Non-Participating Receptor | 607801 | 4775831 |
| R165 | Non-Participating Receptor | 604109 | 4775818 |
| R166 | Non-Participating Receptor | 607849 | 4775780 |
| R167 | Non-Participating Receptor | 607960 | 4775761 |
| R168 | Non-Participating Receptor | 602774 | 4775603 |
| R169 | Non-Participating Receptor | 604031 | 4775587 |
| R170 | Non-Participating Receptor | 602790 | 4775563 |
| R171 | Non-Participating Receptor | 602672 | 4775545 |
| R172 | Non-Participating Receptor | 602850 | 4775540 |
| R173 | Non-Participating Receptor | 602707 | 4775533 |
| R174 | Non-Participating Receptor | 602751 | 4775531 |
| R175 | Non-Participating Receptor | 602895 | 4775506 |
| R176 | Non-Participating Receptor | 602927 | 4775486 |
| R177 | Non-Participating Receptor | 602956 | 4775479 |
| R178 | Non-Participating Receptor | 603000 | 4775466 |
| R179 | Non-Participating Receptor | 603040 | 4775452 |
| R180 | Non-Participating Receptor | 607995 | 4775436 |
| R181 | Non-Participating Receptor | 603072 | 4775427 |
| R182 | Non-Participating Receptor | 603103 | 4775417 |
| R183 | Non-Participating Receptor | 602815 | 4775417 |
| R184 | Non-Participating Receptor | 603128 | 4775413 |
| R185 | Non-Participating Receptor | 603181 | 4775397 |
| R186 | Non-Participating Receptor | 602895 | 4775397 |
| R187 | Non-Participating Receptor | 602943 | 4775389 |
| R188 | Non-Participating Receptor | 603206 | 4775388 |
| R189 | Non-Participating Receptor | 602972 | 4775386 |
| R190 | Non-Participating Receptor | 602849 | 4775373 |

| Point of Reception ID | Description | UTM Coordinates | |
|-----------------------|----------------------------|-----------------|---------|
| | | Easting | Westing |
| R191 | Non-Participating Receptor | 603015 | 4775367 |
| R192 | Non-Participating Receptor | 608029 | 4775362 |
| R193 | Non-Participating Receptor | 603063 | 4775353 |
| R194 | Non-Participating Receptor | 608017 | 4775300 |
| R195 | Non-Participating Receptor | 603371 | 4775265 |
| R196 | Non-Participating Receptor | 608022 | 4775251 |
| R197 | Non-Participating Receptor | 607957 | 4775000 |
| R198 | Non-Participating Receptor | 608019 | 4774960 |
| R199 | Non-Participating Receptor | 603672 | 4774958 |
| R200 | Non-Participating Receptor | 608302 | 4774881 |
| R201 | Non-Participating Receptor | 603410 | 4774567 |
| R202 | Non-Participating Receptor | 602782 | 4773478 |
| R203 | Non-Participating Receptor | 602524 | 4773450 |
| R204 | Non-Participating Receptor | 602575 | 4773430 |
| R205 | Non-Participating Receptor | 602618 | 4773418 |
| R206 | Non-Participating Receptor | 602722 | 4773300 |
| R207 | Non-Participating Receptor | 602888 | 4773238 |
| R208 | Non-Participating Receptor | 603001 | 4773201 |
| R209 | Non-Participating Receptor | 602973 | 4773198 |
| R210 | Non-Participating Receptor | 602980 | 4773007 |
| R211 | Non-Participating Receptor | 603098 | 4772925 |
| R212 | Non-Participating Receptor | 603068 | 4772801 |
| R213 | Non-Participating Receptor | 603182 | 4772793 |
| R214 | Non-Participating Receptor | 603065 | 4772774 |
| R215 | Non-Participating Receptor | 603053 | 4772748 |
| R216 | Non-Participating Receptor | 603139 | 4772728 |
| R217 | Non-Participating Receptor | 603123 | 4772704 |
| R218 | Non-Participating Receptor | 603180 | 4772703 |
| R219 | Non-Participating Receptor | 603284 | 4772656 |
| R220 | Non-Participating Receptor | 603802 | 4772366 |
| R221 | Non-Participating Receptor | 603733 | 4772357 |
| R222 | Non-Participating Receptor | 603984 | 4772315 |
| R223 | Non-Participating Receptor | 607077 | 4772150 |
| R224 | Non-Participating Receptor | 604975 | 4771842 |
| R225 | Non-Participating Receptor | 605013 | 4771824 |
| R226 | Non-Participating Receptor | 605139 | 4771768 |
| R227 | Non-Participating Receptor | 605760 | 4771658 |
| R228 | Non-Participating Receptor | 607032 | 4771618 |
| R229 | Non-Participating Receptor | 605598 | 4771613 |
| R230 | Non-Participating Receptor | 605620 | 4771606 |
| R231 | Non-Participating Receptor | 605673 | 4771576 |
| R232 | Non-Participating Receptor | 605525 | 4771567 |
| R233 | Non-Participating Receptor | 605700 | 4771563 |
| R234 | Non-Participating Receptor | 605759 | 4771535 |
| R235 | Non-Participating Receptor | 605594 | 4771535 |
| R236 | Non-Participating Receptor | 605625 | 4771517 |
| R237 | Non-Participating Receptor | 605860 | 4771491 |
| R238 | Non-Participating Receptor | 606843 | 4771471 |

| Point of Reception ID | Description | UTM Coordinates | |
|-----------------------|------------------------------|-----------------|---------|
| | | Easting | Westing |
| R239 | Non-Participating Receptor | 605910 | 4771458 |
| R240 | Non-Participating Receptor | 605936 | 4771451 |
| R241 | Non-Participating Receptor | 605987 | 4771436 |
| R242 | Non-Participating Receptor | 607843 | 4774953 |
| R243 | Non-Participating Receptor | 608164 | 4773488 |
| R244 | Non-Participating Receptor | 608024 | 4773318 |
| R245 | Non-Participating Receptor | 608072 | 4773301 |
| R246 | Non-Participating Receptor | 607464 | 4772330 |
| R247 | Non-Participating Receptor | 607470 | 4772078 |
| R248 | Non-Participating Receptor | 607124 | 4772293 |
| R249 | Non-Participating Receptor | 607055 | 4772362 |
| R250 | Non-Participating Receptor | 607002 | 4772362 |
| R251 | Non-Participating Receptor | 607055 | 4772245 |
| R252 | Non-Participating Receptor | 607134 | 4771769 |
| R253 | Non-Participating Receptor | 606898 | 4772235 |
| R254 | Non-Participating Receptor | 605124 | 4771909 |
| R255 | Non-Participating Receptor | 605299 | 4771766 |
| R256 | Non-Participating Receptor | 605349 | 4771741 |
| R257 | Non-Participating Receptor | 605460 | 4771805 |
| R258 | Non-Participating Receptor | 606059 | 4771413 |
| V01 | Non-Participating Vacant Lot | 604522 | 4773620 |
| V02 | Non-Participating Vacant Lot | 607016 | 4773841 |
| V03 | Non-Participating Vacant Lot | 604570 | 4776376 |
| V04 | Non-Participating Vacant Lot | 605739 | 4775832 |
| V05 | Non-Participating Vacant Lot | 606566 | 4775508 |
| V06 | Non-Participating Vacant Lot | 606686 | 4775426 |
| V07 | Non-Participating Vacant Lot | 606571 | 4774188 |
| V08 | Non-Participating Vacant Lot | 603750 | 4774656 |
| V09 | Non-Participating Vacant Lot | 606924 | 4772994 |
| V11 | Non-Participating Vacant Lot | 608134 | 4774824 |
| V12 | Non-Participating Vacant Lot | 607960 | 4773440 |
| V16 | Non-Participating Vacant Lot | 608161 | 4771919 |
| V18 | Non-Participating Vacant Lot | 607088 | 4772438 |
| V20 | Non-Participating Vacant Lot | 607274 | 4772215 |
| V27 | Non-Participating Vacant Lot | 606381 | 4772607 |
| V28 | Non-Participating Vacant Lot | 606210 | 4772699 |
| V29 | Non-Participating Vacant Lot | 606963 | 4771641 |
| V30 | Non-Participating Vacant Lot | 606963 | 4771578 |
| V31 | Non-Participating Vacant Lot | 604648 | 4773485 |
| V32 | Non-Participating Vacant Lot | 605204 | 4773227 |
| V33 | Non-Participating Vacant Lot | 604087 | 4772382 |
| V39 | Non-Participating Vacant Lot | 605435 | 4775876 |
| V40 | Non-Participating Vacant Lot | 605491 | 4774678 |
| V41 | Non-Participating Vacant Lot | 606406 | 4776900 |
| V42 | Non-Participating Vacant Lot | 607644 | 4775446 |
| V43 | Non-Participating Vacant Lot | 608122 | 4773280 |

**Table A4: Non-Participating Receptor Locations
Vineland Power, HAF Wind Energy Project**

| Point of Reception ID | Description | UTM Coordinates | |
|--------------------------|--------------------------|-----------------|---------|
| | | Easting | Westing |
| PR01 | Participating Receptor | 606123 | 4773010 |
| PR02 | Participating Receptor | 606895 | 4773470 |
| PR03 | Participating Receptor | 604926 | 4776096 |
| PR04 | Participating Receptor | 606129 | 4774317 |
| PR05 | Participating Receptor | 606543 | 4773695 |
| PR06 | Participating Receptor | 604361 | 4773804 |
| PR07 | Participating Receptor | 604466 | 4774951 |
| PR08 | Participating Receptor | 604092 | 4774034 |
| PR09 | Participating Receptor | 604426 | 4775303 |
| PV01 | Participating Vacant Lot | 606319 | 4774265 |

Table A5: Wind Turbine Noise Impact Summary - Points of Reception
Vineland Power, HAF Wind Energy Project

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | | Sound Level Limit [dBA] | | | | |
|-----------------------|----------------------------|------------|-------------------------------------|--------------------|--|------|------|------|------|-------------------------|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| R001 | Non-Participating Receptor | 4.5 | 610 | WTG5 | 36.6 | 36.6 | 36.6 | 36.6 | 36.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R002 | Non-Participating Receptor | 4.5 | 2033 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R003 | Non-Participating Receptor | 4.5 | 1973 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R004 | Non-Participating Receptor | 4.5 | 1279 | WTG4 | 29.5 | 29.5 | 29.5 | 29.5 | 29.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R005 | Non-Participating Receptor | 4.5 | 1250 | WTG4 | 29.7 | 29.7 | 29.7 | 29.7 | 29.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R006 | Non-Participating Receptor | 4.5 | 788 | WTG4 | 34.2 | 34.2 | 34.2 | 34.2 | 34.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R007 | Non-Participating Receptor | 4.5 | 1112 | WTG4 | 30.9 | 30.9 | 30.9 | 30.9 | 30.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R008 | Non-Participating Receptor | 4.5 | 1489 | WTG4 | 28.1 | 28.1 | 28.1 | 28.1 | 28.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R009 | Non-Participating Receptor | 4.5 | 1089 | WTG4 | 31.1 | 31.1 | 31.1 | 31.1 | 31.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R010 | Non-Participating Receptor | 4.5 | 1262 | WTG5 | 29.8 | 29.8 | 29.8 | 29.8 | 29.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R011 | Non-Participating Receptor | 4.5 | 1996 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R012 | Non-Participating Receptor | 4.5 | 1963 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R013 | Non-Participating Receptor | 4.5 | 1958 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R014 | Non-Participating Receptor | 4.5 | 1981 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R015 | Non-Participating Receptor | 4.5 | 1187 | WTG4 | 33.2 | 33.2 | 33.2 | 33.2 | 33.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R016 | Non-Participating Receptor | 4.5 | 2030 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R017 | Non-Participating Receptor | 4.5 | 842 | WTG4 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R018 | Non-Participating Receptor | 4.5 | 910 | WTG4 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R019 | Non-Participating Receptor | 4.5 | 595 | WTG5 | 36.5 | 36.5 | 36.5 | 36.5 | 36.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R020 | Non-Participating Receptor | 4.5 | 2073 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R021 | Non-Participating Receptor | 4.5 | 1964 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R022 | Non-Participating Receptor | 4.5 | 895 | WTG4 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R023 | Non-Participating Receptor | 4.5 | 1101 | WTG4 | 34.1 | 34.1 | 34.1 | 34.1 | 34.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R024 | Non-Participating Receptor | 4.5 | 1131 | WTG2 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R025 | Non-Participating Receptor | 4.5 | 1386 | WTG2 | 32.8 | 32.8 | 32.8 | 32.8 | 32.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R026 | Non-Participating Receptor | 4.5 | 1103 | WTG2 | 34.8 | 34.8 | 34.8 | 34.8 | 34.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R027 | Non-Participating Receptor | 4.5 | 1101 | WTG2 | 35.9 | 35.9 | 35.9 | 35.9 | 35.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R028 | Non-Participating Receptor | 4.5 | 1357 | WTG2 | 32.9 | 32.9 | 32.9 | 32.9 | 32.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R029 | Non-Participating Receptor | 4.5 | 1073 | WTG2 | 35.1 | 35.1 | 35.1 | 35.1 | 35.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R030 | Non-Participating Receptor | 4.5 | 2001 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R031 | Non-Participating Receptor | 4.5 | 1774 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R032 | Non-Participating Receptor | 4.5 | 2002 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R033 | Non-Participating Receptor | 4.5 | 652 | WTG4 | 36.0 | 36.0 | 36.0 | 36.0 | 36.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R034 | Non-Participating Receptor | 4.5 | 998 | WTG2 | 35.8 | 35.8 | 35.8 | 35.8 | 35.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R035 | Non-Participating Receptor | 4.5 | 1293 | WTG2 | 33.1 | 33.1 | 33.1 | 33.1 | 33.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R036 | Non-Participating Receptor | 4.5 | 1024 | WTG2 | 36.0 | 36.0 | 36.0 | 36.0 | 36.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R037 | Non-Participating Receptor | 4.5 | 1362 | WTG2 | 32.6 | 32.6 | 32.6 | 32.6 | 32.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R038 | Non-Participating Receptor | 4.5 | 2099 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R039 | Non-Participating Receptor | 4.5 | 2043 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R040 | Non-Participating Receptor | 4.5 | 1110 | WTG2 | 35.7 | 35.7 | 35.7 | 35.7 | 35.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R041 | Non-Participating Receptor | 4.5 | 2148 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R042 | Non-Participating Receptor | 4.5 | 1633 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R043 | Non-Participating Receptor | 4.5 | 1113 | WTG2 | 35.5 | 35.5 | 35.5 | 35.5 | 35.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R044 | Non-Participating Receptor | 4.5 | 1889 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R045 | Non-Participating Receptor | 4.5 | 2056 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R046 | Non-Participating Receptor | 4.5 | 2084 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R047 | Non-Participating Receptor | 4.5 | 2097 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R048 | Non-Participating Receptor | 4.5 | 2116 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R049 | Non-Participating Receptor | 4.5 | 2230 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R050 | Non-Participating Receptor | 4.5 | 2151 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R051 | Non-Participating Receptor | 4.5 | 1200 | WTG2 | 34.7 | 34.7 | 34.7 | 34.7 | 34.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R052 | Non-Participating Receptor | 4.5 | 1065 | WTG2 | 35.8 | 35.8 | 35.8 | 35.8 | 35.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R053 | Non-Participating Receptor | 4.5 | 1038 | WTG2 | 36.0 | 36.0 | 36.0 | 36.0 | 36.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R054 | Non-Participating Receptor | 4.5 | 840 | WTG5 | 33.2 | 33.2 | 33.2 | 33.2 | 33.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R055 | Non-Participating Receptor | 4.5 | 656 | WTG3 | 36.0 | 36.0 | 36.0 | 36.0 | 36.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R056 | Non-Participating Receptor | 4.5 | 981 | WTG2 | 36.8 | 36.8 | 36.8 | 36.8 | 36.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R057 | Non-Participating Receptor | 4.5 | 926 | WTG2 | 36.4 | 36.4 | 36.4 | 36.4 | 36.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R058 | Non-Participating Receptor | 4.5 | 1260 | WTG2 | 33.9 | 33.9 | 33.9 | 33.9 | 33.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R059 | Non-Participating Receptor | 4.5 | 938 | WTG4 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R060 | Non-Participating Receptor | 4.5 | 703 | WTG4 | 37.8 | 37.8 | 37.8 | 37.8 | 37.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R061 | Non-Participating Receptor | 4.5 | 1009 | WTG2 | 35.4 | 35.4 | 35.4 | 35.4 | 35.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R062 | Non-Participating Receptor | 4.5 | 986 | WTG2 | 35.4 | 35.4 | 35.4 | 35.4 | 35.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R063 | Non-Participating Receptor | 4.5 | 835 | WTG3 | 36.6 | 36.6 | 36.6 | 36.6 | 36.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R064 | Non-Participating Receptor | 4.5 | 1045 | WTG2 | 34.9 | 34.9 | 34.9 | 34.9 | 34.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R065 | Non-Participating Receptor | 4.5 | 1124 | WTG2 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | | Sound Level Limit [dBA] | | | | |
|-----------------------|----------------------------|------------|-------------------------------------|--------------------|--|------|------|------|------|-------------------------|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| R066 | Non-Participating Receptor | 4.5 | 697 | WTG5 | 35.2 | 35.2 | 35.2 | 35.2 | 35.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R067 | Non-Participating Receptor | 4.5 | 607 | WTG3 | 37.9 | 37.9 | 37.9 | 37.9 | 37.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R068 | Non-Participating Receptor | 4.5 | 684 | WTG3 | 37.3 | 37.3 | 37.3 | 37.3 | 37.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R069 | Non-Participating Receptor | 4.5 | 1136 | WTG3 | 33.8 | 33.8 | 33.8 | 33.8 | 33.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R070 | Non-Participating Receptor | 4.5 | 628 | WTG3 | 37.7 | 37.7 | 37.7 | 37.7 | 37.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R071 | Non-Participating Receptor | 4.5 | 694 | WTG3 | 37.1 | 37.1 | 37.1 | 37.1 | 37.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R072 | Non-Participating Receptor | 4.5 | 701 | WTG3 | 35.4 | 35.4 | 35.4 | 35.4 | 35.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R073 | Non-Participating Receptor | 4.5 | 1061 | WTG3 | 33.9 | 33.9 | 33.9 | 33.9 | 33.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R074 | Non-Participating Receptor | 4.5 | 660 | WTG3 | 37.4 | 37.4 | 37.4 | 37.4 | 37.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R075 | Non-Participating Receptor | 4.5 | 895 | WTG5 | 33.8 | 33.8 | 33.8 | 33.8 | 33.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R076 | Non-Participating Receptor | 4.5 | 764 | WTG5 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R077 | Non-Participating Receptor | 4.5 | 716 | WTG3 | 37.1 | 37.1 | 37.1 | 37.1 | 37.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R078 | Non-Participating Receptor | 4.5 | 708 | WTG3 | 35.4 | 35.4 | 35.4 | 35.4 | 35.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R079 | Non-Participating Receptor | 4.5 | 717 | WTG3 | 35.3 | 35.3 | 35.3 | 35.3 | 35.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R080 | Non-Participating Receptor | 4.5 | 922 | WTG3 | 34.0 | 34.0 | 34.0 | 34.0 | 34.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R081 | Non-Participating Receptor | 4.5 | 824 | WTG3 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R082 | Non-Participating Receptor | 4.5 | 706 | WTG3 | 35.7 | 35.7 | 35.7 | 35.7 | 35.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R083 | Non-Participating Receptor | 4.5 | 823 | WTG3 | 34.0 | 34.0 | 34.0 | 34.0 | 34.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R084 | Non-Participating Receptor | 4.5 | 851 | WTG3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R085 | Non-Participating Receptor | 4.5 | 950 | WTG5 | 31.8 | 31.8 | 31.8 | 31.8 | 31.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R086 | Non-Participating Receptor | 4.5 | 780 | WTG3 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R087 | Non-Participating Receptor | 4.5 | 1043 | WTG5 | 30.9 | 30.9 | 30.9 | 30.9 | 30.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R088 | Non-Participating Receptor | 4.5 | 728 | WTG3 | 35.1 | 35.1 | 35.1 | 35.1 | 35.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R089 | Non-Participating Receptor | 4.5 | 709 | WTG3 | 35.3 | 35.3 | 35.3 | 35.3 | 35.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R090 | Non-Participating Receptor | 4.5 | 993 | WTG5 | 31.4 | 31.4 | 31.4 | 31.4 | 31.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R091 | Non-Participating Receptor | 4.5 | 809 | WTG3 | 33.8 | 33.8 | 33.8 | 33.8 | 33.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R092 | Non-Participating Receptor | 4.5 | 929 | WTG5 | 32.0 | 32.0 | 32.0 | 32.0 | 32.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R093 | Non-Participating Receptor | 4.5 | 1017 | WTG3 | 33.1 | 33.1 | 33.1 | 33.1 | 33.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R094 | Non-Participating Receptor | 4.5 | 727 | WTG5 | 34.5 | 34.5 | 34.5 | 34.5 | 34.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R095 | Non-Participating Receptor | 4.5 | 1111 | WTG5 | 30.2 | 30.2 | 30.2 | 30.2 | 30.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R096 | Non-Participating Receptor | 4.5 | 916 | WTG5 | 34.2 | 34.2 | 34.2 | 34.2 | 34.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R097 | Non-Participating Receptor | 4.5 | 1191 | WTG5 | 29.5 | 29.5 | 29.5 | 29.5 | 29.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R098 | Non-Participating Receptor | 4.5 | 930 | WTG3 | 32.5 | 32.5 | 32.5 | 32.5 | 32.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R099 | Non-Participating Receptor | 4.5 | 686 | WTG3 | 35.5 | 35.5 | 35.5 | 35.5 | 35.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R100 | Non-Participating Receptor | 4.5 | 1069 | WTG3 | 31.1 | 31.1 | 31.1 | 31.1 | 31.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R101 | Non-Participating Receptor | 4.5 | 1021 | WTG3 | 31.6 | 31.6 | 31.6 | 31.6 | 31.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R102 | Non-Participating Receptor | 4.5 | 1087 | WTG5 | 31.4 | 31.4 | 31.4 | 31.4 | 31.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R103 | Non-Participating Receptor | 4.5 | 967 | WTG3 | 32.1 | 32.1 | 32.1 | 32.1 | 32.1 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R104 | Non-Participating Receptor | 4.5 | 1822 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R105 | Non-Participating Receptor | 4.5 | 1533 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R106 | Non-Participating Receptor | 4.5 | 1179 | WTG3 | 30.2 | 30.2 | 30.2 | 30.2 | 30.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R107 | Non-Participating Receptor | 4.5 | 1987 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R108 | Non-Participating Receptor | 4.5 | 2018 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R109 | Non-Participating Receptor | 4.5 | 1512 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R110 | Non-Participating Receptor | 4.5 | 2037 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R111 | Non-Participating Receptor | 4.5 | 1504 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R112 | Non-Participating Receptor | 4.5 | 1337 | WTG3 | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R113 | Non-Participating Receptor | 4.5 | 894 | WTG5 | 33.4 | 33.4 | 33.4 | 33.4 | 33.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R114 | Non-Participating Receptor | 4.5 | 1445 | WTG5 | 28.2 | 28.2 | 28.2 | 28.2 | 28.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R115 | Non-Participating Receptor | 4.5 | 853 | WTG3 | 34.2 | 34.2 | 34.2 | 34.2 | 34.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R116 | Non-Participating Receptor | 4.5 | 700 | WTG5 | 34.9 | 34.9 | 34.9 | 34.9 | 34.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R117 | Non-Participating Receptor | 4.5 | 764 | WTG5 | 34.5 | 34.5 | 34.5 | 34.5 | 34.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R118 | Non-Participating Receptor | 4.5 | 788 | WTG5 | 33.8 | 33.8 | 33.8 | 33.8 | 33.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R119 | Non-Participating Receptor | 4.5 | 750 | WTG4 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R120 | Non-Participating Receptor | 4.5 | 587 | WTG3 | 38.0 | 38.0 | 38.0 | 38.0 | 38.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R121 | Non-Participating Receptor | 4.5 | 858 | WTG5 | 33.9 | 33.9 | 33.9 | 33.9 | 33.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R122 | Non-Participating Receptor | 4.5 | 807 | WTG5 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R123 | Non-Participating Receptor | 4.5 | 781 | WTG5 | 34.0 | 34.0 | 34.0 | 34.0 | 34.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R124 | Non-Participating Receptor | 4.5 | 744 | WTG3 | 35.2 | 35.2 | 35.2 | 35.2 | 35.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R125 | Non-Participating Receptor | 4.5 | 2415 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R126 | Non-Participating Receptor | 4.5 | 2380 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R127 | Non-Participating Receptor | 4.5 | 2376 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R128 | Non-Participating Receptor | 4.5 | 2356 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R129 | Non-Participating Receptor | 4.5 | 2327 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R130 | Non-Participating Receptor | 4.5 | 2300 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R131 | Non-Participating Receptor | 4.5 | 2264 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R132 | Non-Participating Receptor | 4.5 | 2259 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | | Sound Level Limit [dBA] | | | | |
|-----------------------|----------------------------|------------|-------------------------------------|--------------------|--|------|------|------|------|-------------------------|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| R133 | Non-Participating Receptor | 4.5 | 2234 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R134 | Non-Participating Receptor | 4.5 | 2208 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R135 | Non-Participating Receptor | 4.5 | 2163 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R136 | Non-Participating Receptor | 4.5 | 2181 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R137 | Non-Participating Receptor | 4.5 | 2223 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R138 | Non-Participating Receptor | 4.5 | 2129 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R139 | Non-Participating Receptor | 4.5 | 2188 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R140 | Non-Participating Receptor | 4.5 | 2153 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R141 | Non-Participating Receptor | 4.5 | 2163 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R142 | Non-Participating Receptor | 4.5 | 2132 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R143 | Non-Participating Receptor | 4.5 | 2100 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R144 | Non-Participating Receptor | 4.5 | 2112 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R145 | Non-Participating Receptor | 4.5 | 2393 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R146 | Non-Participating Receptor | 4.5 | 2067 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R147 | Non-Participating Receptor | 4.5 | 2010 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R148 | Non-Participating Receptor | 4.5 | 2001 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R149 | Non-Participating Receptor | 4.5 | 1881 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R150 | Non-Participating Receptor | 4.5 | 1880 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R151 | Non-Participating Receptor | 4.5 | 1769 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R152 | Non-Participating Receptor | 4.5 | 1933 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R153 | Non-Participating Receptor | 4.5 | 1769 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R154 | Non-Participating Receptor | 4.5 | 1708 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R155 | Non-Participating Receptor | 4.5 | 1777 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R156 | Non-Participating Receptor | 4.5 | 1736 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R157 | Non-Participating Receptor | 4.5 | 1757 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R158 | Non-Participating Receptor | 4.5 | 1685 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R159 | Non-Participating Receptor | 4.5 | 1646 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R160 | Non-Participating Receptor | 4.5 | 1710 | WTG2 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R161 | Non-Participating Receptor | 4.5 | 1379 | WTG2 | 32.8 | 32.8 | 32.8 | 32.8 | 32.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R162 | Non-Participating Receptor | 4.5 | 1993 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R163 | Non-Participating Receptor | 4.5 | 1908 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R164 | Non-Participating Receptor | 4.5 | 1771 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R165 | Non-Participating Receptor | 4.5 | 1012 | WTG2 | 36.7 | 36.7 | 36.7 | 36.7 | 36.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R166 | Non-Participating Receptor | 4.5 | 1787 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R167 | Non-Participating Receptor | 4.5 | 1876 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R168 | Non-Participating Receptor | 4.5 | 2047 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R169 | Non-Participating Receptor | 4.5 | 953 | WTG2 | 36.8 | 36.8 | 36.8 | 36.8 | 36.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R170 | Non-Participating Receptor | 4.5 | 2010 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R171 | Non-Participating Receptor | 4.5 | 2093 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R172 | Non-Participating Receptor | 4.5 | 1949 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R173 | Non-Participating Receptor | 4.5 | 2057 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R174 | Non-Participating Receptor | 4.5 | 2021 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R175 | Non-Participating Receptor | 4.5 | 1892 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R176 | Non-Participating Receptor | 4.5 | 1855 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R177 | Non-Participating Receptor | 4.5 | 1828 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R178 | Non-Participating Receptor | 4.5 | 1786 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R179 | Non-Participating Receptor | 4.5 | 1747 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R180 | Non-Participating Receptor | 4.5 | 1785 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R181 | Non-Participating Receptor | 4.5 | 1706 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R182 | Non-Participating Receptor | 4.5 | 1676 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R183 | Non-Participating Receptor | 4.5 | 1902 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R184 | Non-Participating Receptor | 4.5 | 1655 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R185 | Non-Participating Receptor | 4.5 | 1605 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R186 | Non-Participating Receptor | 4.5 | 1825 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R187 | Non-Participating Receptor | 4.5 | 1782 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R188 | Non-Participating Receptor | 4.5 | 1580 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R189 | Non-Participating Receptor | 4.5 | 1757 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R190 | Non-Participating Receptor | 4.5 | 1848 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R191 | Non-Participating Receptor | 4.5 | 1712 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R192 | Non-Participating Receptor | 4.5 | 1797 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R193 | Non-Participating Receptor | 4.5 | 1665 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R194 | Non-Participating Receptor | 4.5 | 1771 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R195 | Non-Participating Receptor | 4.5 | 1376 | WTG4 | 31.5 | 31.5 | 31.5 | 31.5 | 31.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R196 | Non-Participating Receptor | 4.5 | 1765 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R197 | Non-Participating Receptor | 4.5 | 1669 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R198 | Non-Participating Receptor | 4.5 | 1729 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R199 | Non-Participating Receptor | 4.5 | 946 | WTG4 | 34.4 | 34.4 | 34.4 | 34.4 | 34.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | | Sound Level Limit [dBA] | | | | |
|-----------------------|------------------------------|------------|-------------------------------------|--------------------|--|------|------|------|------|-------------------------|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| R200 | Non-Participating Receptor | 4.5 | 2011 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R201 | Non-Participating Receptor | 4.5 | 984 | WTG4 | 32.7 | 32.7 | 32.7 | 32.7 | 32.7 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R202 | Non-Participating Receptor | 4.5 | 1782 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R203 | Non-Participating Receptor | 4.5 | 2025 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R204 | Non-Participating Receptor | 4.5 | 1988 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R205 | Non-Participating Receptor | 4.5 | 1955 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R206 | Non-Participating Receptor | 4.5 | 1922 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R207 | Non-Participating Receptor | 4.5 | 1818 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R208 | Non-Participating Receptor | 4.5 | 1751 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R209 | Non-Participating Receptor | 4.5 | 1775 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R210 | Non-Participating Receptor | 4.5 | 1895 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R211 | Non-Participating Receptor | 4.5 | 1871 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R212 | Non-Participating Receptor | 4.5 | 1984 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R213 | Non-Participating Receptor | 4.5 | 1918 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R214 | Non-Participating Receptor | 4.5 | 2006 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R215 | Non-Participating Receptor | 4.5 | 2034 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R216 | Non-Participating Receptor | 4.5 | 1995 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R217 | Non-Participating Receptor | 4.5 | 2024 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R218 | Non-Participating Receptor | 4.5 | 1991 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R219 | Non-Participating Receptor | 4.5 | 1970 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R220 | Non-Participating Receptor | 4.5 | 2019 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R221 | Non-Participating Receptor | 4.5 | 2048 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R222 | Non-Participating Receptor | 4.5 | 2027 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R223 | Non-Participating Receptor | 4.5 | 1525 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R224 | Non-Participating Receptor | 4.5 | 2018 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R225 | Non-Participating Receptor | 4.5 | 2009 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R226 | Non-Participating Receptor | 4.5 | 1981 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R227 | Non-Participating Receptor | 4.5 | 1824 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R228 | Non-Participating Receptor | 4.5 | 1971 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R229 | Non-Participating Receptor | 4.5 | 1915 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R230 | Non-Participating Receptor | 4.5 | 1915 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R231 | Non-Participating Receptor | 4.5 | 1927 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R232 | Non-Participating Receptor | 4.5 | 1984 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R233 | Non-Participating Receptor | 4.5 | 1932 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R234 | Non-Participating Receptor | 4.5 | 1944 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R235 | Non-Participating Receptor | 4.5 | 1990 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R236 | Non-Participating Receptor | 4.5 | 1998 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R237 | Non-Participating Receptor | 4.5 | 1965 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R238 | Non-Participating Receptor | 4.5 | 2042 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R239 | Non-Participating Receptor | 4.5 | 1988 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R240 | Non-Participating Receptor | 4.5 | 1991 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R241 | Non-Participating Receptor | 4.5 | 1999 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R242 | Non-Participating Receptor | 4.5 | 1553 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R243 | Non-Participating Receptor | 4.5 | 1932 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R244 | Non-Participating Receptor | 4.5 | 1794 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R245 | Non-Participating Receptor | 4.5 | 1843 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R246 | Non-Participating Receptor | 4.5 | 1644 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R247 | Non-Participating Receptor | 4.5 | 1825 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R248 | Non-Participating Receptor | 4.5 | 1437 | WTG5 | 27.6 | 27.6 | 27.6 | 27.6 | 27.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R249 | Non-Participating Receptor | 4.5 | 1340 | WTG5 | 28.3 | 28.3 | 28.3 | 28.3 | 28.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R250 | Non-Participating Receptor | 4.5 | 1308 | WTG5 | 28.6 | 28.6 | 28.6 | 28.6 | 28.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R251 | Non-Participating Receptor | 4.5 | 1434 | WTG5 | 27.6 | 27.6 | 27.6 | 27.6 | 27.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R252 | Non-Participating Receptor | 4.5 | 1881 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R253 | Non-Participating Receptor | 4.5 | 1359 | WTG5 | 28.2 | 28.2 | 28.2 | 28.2 | 28.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R254 | Non-Participating Receptor | 4.5 | 1874 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R255 | Non-Participating Receptor | 4.5 | 1899 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R256 | Non-Participating Receptor | 4.5 | 1897 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R257 | Non-Participating Receptor | 4.5 | 1790 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| R258 | Non-Participating Receptor | 4.5 | 2015 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V01 | Non-Participating Vacant Lot | 4.5 | 706 | WTG4 | 35.5 | 35.5 | 35.5 | 35.5 | 35.5 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V02 | Non-Participating Vacant Lot | 4.5 | 889 | WTG5 | 33.6 | 33.6 | 33.6 | 33.6 | 33.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V03 | Non-Participating Vacant Lot | 4.5 | 1245 | WTG2 | 34.3 | 34.3 | 34.3 | 34.3 | 34.3 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V04 | Non-Participating Vacant Lot | 4.5 | 1076 | WTG2 | 34.8 | 34.8 | 34.8 | 34.8 | 34.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V05 | Non-Participating Vacant Lot | 4.5 | 662 | WTG3 | 35.9 | 35.9 | 35.9 | 35.9 | 35.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V06 | Non-Participating Vacant Lot | 4.5 | 654 | WTG3 | 35.9 | 35.9 | 35.9 | 35.9 | 35.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V07 | Non-Participating Vacant Lot | 4.5 | 770 | WTG3 | 36.4 | 36.4 | 36.4 | 36.4 | 36.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V08 | Non-Participating Vacant Lot | 4.5 | 702 | WTG4 | 36.0 | 36.0 | 36.0 | 36.0 | 36.0 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | | Sound Level Limit [dBA] | | | | |
|-----------------------|------------------------------|------------|-------------------------------------|--------------------|--|------|------|------|------|-------------------------|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 | 6 | 7 | 8 | 9 | 10 |
| V09 | Non-Participating Vacant Lot | 4.5 | 812 | WTG5 | 33.4 | 33.4 | 33.4 | 33.4 | 33.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V11 | Non-Participating Vacant Lot | 4.5 | 1844 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V12 | Non-Participating Vacant Lot | 4.5 | 1727 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V16 | Non-Participating Vacant Lot | 4.5 | 2443 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V18 | Non-Participating Vacant Lot | 4.5 | 1302 | WTG5 | 28.6 | 28.6 | 28.6 | 28.6 | 28.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V20 | Non-Participating Vacant Lot | 4.5 | 1592 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V27 | Non-Participating Vacant Lot | 4.5 | 826 | WTG5 | 33.2 | 33.2 | 33.2 | 33.2 | 33.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V28 | Non-Participating Vacant Lot | 4.5 | 721 | WTG5 | 34.6 | 34.6 | 34.6 | 34.6 | 34.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V29 | Non-Participating Vacant Lot | 4.5 | 1923 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V30 | Non-Participating Vacant Lot | 4.5 | 1982 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V31 | Non-Participating Vacant Lot | 4.5 | 871 | WTG4 | 33.9 | 33.9 | 33.9 | 33.9 | 33.9 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V32 | Non-Participating Vacant Lot | 4.5 | 1047 | WTG5 | 32.8 | 32.8 | 32.8 | 32.8 | 32.8 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V33 | Non-Participating Vacant Lot | 4.5 | 1944 | WTG4 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V39 | Non-Participating Vacant Lot | 4.5 | 890 | WTG2 | 36.4 | 36.4 | 36.4 | 36.4 | 36.4 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V40 | Non-Participating Vacant Lot | 4.5 | 779 | WTG2 | 37.6 | 37.6 | 37.6 | 37.6 | 37.6 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V41 | Non-Participating Vacant Lot | 4.5 | 1998 | WTG3 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V42 | Non-Participating Vacant Lot | 4.5 | 1457 | WTG3 | 28.2 | 28.2 | 28.2 | 28.2 | 28.2 | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |
| V43 | Non-Participating Vacant Lot | 4.5 | 1894 | WTG5 | - | - | - | - | - | 40.0 | 43.0 | 45.0 | 49.0 | 51.0 |

^: Receptors greater than 1500m from project wind turbine generators.

Table A6: Wind Turbine Noise Impact Summary - Participating Receptor Locations
Vineland Power, HAF Wind Energy Project

| Point of Reception ID | Description | Height [m] | Distance to Nearest HAF Turbine [m] | Nearest Turbine ID | Calculated Sound Level [dBA] at Selected Wind Speeds (m/s) | | | | |
|--------------------------|--------------------------|---------------|---|-----------------------|---|------|------|------|------|
| | | | | | 6 | 7 | 8 | 9 | 10 |
| PR01 | Participating Receptor | 4.5 | 424 | WTG5 | 39.8 | 39.8 | 39.8 | 39.8 | 39.8 |
| PR02 | Participating Receptor | 4.5 | 664 | WTG5 | 35.6 | 35.6 | 35.6 | 35.6 | 35.6 |
| PR03 | Participating Receptor | 4.5 | 924 | WTG2 | 37.9 | 37.9 | 37.9 | 37.9 | 37.9 |
| PR04 | Participating Receptor | 4.5 | 610 | WTG3 | 37.9 | 37.9 | 37.9 | 37.9 | 37.9 |
| PR05 | Participating Receptor | 4.5 | 414 | WTG5 | 40.2 | 40.2 | 40.2 | 40.2 | 40.2 |
| PR06 | Participating Receptor | 4.5 | 503 | WTG4 | 38.5 | 38.5 | 38.5 | 38.5 | 38.5 |
| PR07 | Participating Receptor | 4.5 | 478 | WTG2 | 41.4 | 41.4 | 41.4 | 41.4 | 41.4 |
| PR08 | Participating Receptor | 4.5 | 382 | WTG4 | 40.9 | 40.9 | 40.9 | 40.9 | 40.9 |
| PR09 | Participating Receptor | 4.5 | 481 | WTG2 | 42.9 | 42.9 | 42.9 | 42.9 | 42.9 |
| PV01 | Participating Vacant Lot | 4.5 | 641 | WTG3 | 37.6 | 37.6 | 37.6 | 37.6 | 37.6 |

**APPENDIX B:
Zoning Map**

TOWNSHIP OF WEST LINCOLN

THIS IS MAP 1 AND KEY MAPS 2-16
TO SCHEDULE 'A', BY-LAW No. 79-14
PASSED THIS 5th DAY OF MARCH 1979.

'C.O. HODGKINS' MAYOR
'J.G. KILLINS' CLERK

| ZONES | SYMBOLS | ZONES | SYMBOLS |
|-------------------------|---------|--------------------|---------|
| RESTRICTED AGRICULTURAL | A1 | LOCAL COMMERCIAL | C1 |
| AGRICULTURAL | A2 | GENERAL COMMERCIAL | C2 |
| RESIDENTIAL | R1 | HIGHWAY COMMERCIAL | C3 |
| RESIDENTIAL | R2 | RURAL COMMERCIAL | RC |
| RESIDENTIAL | R3 | INDUSTRIAL | M1 |
| RESIDENTIAL MULTIPLE | RM1 | PUBLIC INDUSTRIAL | M2 |
| RESIDENTIAL MULTIPLE | RM2 | INSTITUTIONAL | I |
| RURAL RESIDENTIAL | RuR | PUBLIC | P |
| DEVELOPMENT | D | OPEN SPACE | O1 |
| TRAILOR CAMP | T2 | HAZARD | H |

TEMPORARY USE

- NIAGARA ROAD 12 LANDFILL SITE - WASTE DISPOSAL FILL AREA
- NIAGARA ROAD 12 LANDFILL SITE - BUFFER ZONE
- NIAGARA ROAD 12 LANDFILL SITE - BUFFER AND HAZARD LANDS
- NIAGARA ROAD 12 LANDFILL SITE - AREA OF POSSIBLE INFLUENCE

SEE BY-LAW 91-52, 91-78

Project Area

OFFICE CONSOLIDATION


This is an Office Consolidation of Zoning By-law No. 79-14 of the Township of West Lincoln as passed by Council on March 5, 1979.

For accurate reference, recourse should be made to the original Zoning By-law No. 79-14 and amending By-laws.

Consolidated Version November 2009

FOR INFORMATION PURPOSES ONLY.
SCALE N.T.S.

ABINGDON



TOWNSHIP OF
WEST LINCOLN

THIS IS MAP 8
TO SCHEDULE "A",
BY-LAW No. 79-14
PASSED THIS 5th DAY
OF MARCH 1979.

'C.O. HODGKINS' MAYOR
'J.G. KILLINS' CLERK

| ZONES | SYMBOLS |
|--|---------|
| RESTRICTED AGRICULTURAL | A1 |
| AGRICULTURAL | A2 |
| RESIDENTIAL | R1 |
| RESIDENTIAL | R2 |
| RESIDENTIAL MULTIPLE | RM1 |
| RESIDENTIAL MULTIPLE | RM2 |
| RURAL RESIDENTIAL | RuR |
| DEVELOPMENT | D |
| TRAILER CAMP | T2 |
| LOCAL COMMERCIAL | C1 |
| GENERAL COMMERCIAL | C2 |
| HIGHWAY COMMERCIAL | C3 |
| RURAL COMMERCIAL | Rc |
| INDUSTRIAL | M1 |
| PUBLIC INDUSTRIAL | M2 |
| INSTITUTIONAL | I |
| PUBLIC | P |
| OPEN SPACE | O1 |
| HAZARD | H |
| SCHEDULE BOUNDARY | |
| RURAL CLUSTER BOUNDARY | |
| (By-Law No. 2008-29 & By-law 2008-115) | |



FOR INFORMATION PURPOSES ONLY.
MAY NOT BE TO SCALE.

OFFICE CONSOLIDATION

This is an Office Consolidation of Zoning By-law No. 79-14 of the Township of West Lincoln as passed by Council on March 5, 1979.

For accurate reference, recourse should be made to the original Zoning By-law No. 79-14 and amending By-laws.

Consolidated Version
November 2009

APPENDIX C:
VESTAS V100-1.8 MW Wind Turbine Generator Information

Exhibit D.1.1

General Specification

Class 1
Document no.: 0004-3053 V06
2010-10-06

General Specification

V100–1.8 MW VCUS




Table of Contents

| | | |
|----------|--|-----------|
| 1 | General Description..... | 5 |
| 2 | Mechanical Design..... | 5 |
| 2.1 | Rotor..... | 5 |
| 2.2 | Blades..... | 5 |
| 2.3 | Blade Bearing | 6 |
| 2.4 | Pitch System..... | 6 |
| 2.5 | Hub..... | 7 |
| 2.6 | Main Shaft | 7 |
| 2.7 | Bearing Housing | 7 |
| 2.8 | Main Bearings..... | 7 |
| 2.9 | Gearbox..... | 8 |
| 2.10 | Generator Bearings..... | 8 |
| 2.11 | High Speed Shaft Coupling..... | 8 |
| 2.12 | Yaw System..... | 9 |
| 2.13 | Crane..... | 9 |
| 2.14 | Tower Structure | 9 |
| 2.15 | Nacelle Bedplate and Cover | 10 |
| 2.16 | Cooling | 11 |
| 2.17 | Water Cooling System | 11 |
| 2.18 | Gearbox Cooling..... | 11 |
| 2.19 | Hydraulic Cooling..... | 12 |
| 2.20 | VCUS Converter Cooling | 13 |
| 2.21 | Generator Cooling..... | 13 |
| 2.22 | HV Transformer Cooling | 13 |
| 2.23 | Nacelle Conditioning | 14 |
| 3 | Electrical Design..... | 15 |
| 3.1 | Generator | 15 |
| 3.2 | HV Cables | 15 |
| 3.3 | Transformer | 16 |
| 3.4 | Converter..... | 17 |
| 3.5 | AUX System | 17 |
| 3.6 | Wind Sensors | 17 |
| 3.7 | Turbine Controller | 18 |
| 3.8 | Uninterruptible Power Supply (UPS) | 19 |
| 4 | Turbine Protection Systems..... | 19 |
| 4.1 | Braking Concept | 19 |
| 4.2 | Short Circuit Protections | 19 |
| 4.3 | Overspeed Protection | 20 |
| 4.4 | EMC System..... | 20 |
| 4.5 | Lightning System | 20 |
| 4.6 | Earthing (also known as grounding)..... | 21 |
| 4.7 | Corrosion Protection | 21 |
| 5 | Safety..... | 21 |
| 5.1 | Access..... | 21 |
| 5.2 | Escape..... | 22 |
| 5.3 | Rooms/Working Areas | 22 |
| 5.4 | Platforms, Standing and Working Places | 22 |
| 5.5 | Climbing Facilities | 22 |
| 5.6 | Moving Parts, Guards and Blocking Devices..... | 22 |
| 5.7 | Lighting..... | 22 |
| 5.8 | Noise | 23 |
| 5.9 | Emergency Stop | 23 |

| | | |
|-----------|--|-----------|
| 5.10 | Power Disconnection | 23 |
| 5.11 | Fire Protection/First Aid | 23 |
| 5.12 | Warning Signs | 23 |
| 5.13 | Manuals and Warnings | 23 |
| 6 | Environment..... | 23 |
| 6.1 | Chemicals..... | 23 |
| 7 | Approvals, Certificates and Design Codes | 24 |
| 7.1 | Type Approvals..... | 24 |
| 7.2 | Design Codes – Structural Design | 24 |
| 7.3 | Design Codes – Mechanical Equipment..... | 25 |
| 7.4 | Design Codes – Electrical Equipment | 25 |
| 7.5 | Design Codes – I/O Network System | 26 |
| 7.6 | Design Codes – EMC System..... | 26 |
| 7.7 | Design Codes – Lightning Protection | 27 |
| 7.8 | Design Codes – Earthing | 27 |
| 8 | Colour and Surface Treatment..... | 27 |
| 8.1 | Nacelle Colour and Surface Treatment | 27 |
| 8.2 | Tower Colour and Surface Treatment | 28 |
| 8.3 | Blades Colour | 28 |
| 9 | Operational Envelope and Performance Guidelines | 28 |
| 9.1 | Climate and Site Conditions..... | 28 |
| 9.1.1 | Complex Terrain | 29 |
| 9.1.2 | Altitude..... | 29 |
| 9.1.3 | Wind Farm Layout..... | 29 |
| 9.2 | Operational Envelope – Temperature and Wind | 29 |
| 9.3 | Operational Envelope – Grid Connection * | 30 |
| 9.4 | Performance – Fault Ride Through | 30 |
| 9.5 | Current Contribution..... | 31 |
| 9.6 | Performance – Multiple Voltage Dips | 32 |
| 9.7 | Performance – Active Power Control | 32 |
| 9.8 | Performance – Frequency Control | 32 |
| 9.9 | Performance – Own Consumption | 33 |
| 9.10 | Operational Envelope Conditions for Power Curve, C_t Values (at Hub Height)..... | 33 |
| 10 | Drawings | 34 |
| 10.1 | Structural Design – Illustration of Outer Dimensions | 34 |
| 10.2 | Structural Design – Side View Drawing..... | 35 |
| 11 | General Reservations, Notes and Disclaimers | 36 |
| 12 | Appendices | 37 |
| 12.1 | Mode 0..... | 37 |
| 12.1.1 | Mode 0, Power Curve | 37 |
| 12.1.2 | Mode 0, C_t values | 39 |
| 12.1.3 | Mode 0, Sound Power Levels | 40 |
| 12.2 | Mode 1..... | 41 |
| 12.2.1 | Mode 1, Power Curves | 41 |
| 12.2.2 | Mode 1, C_t values | 42 |
| 12.2.3 | Mode 1, Sound Power Levels | 44 |
| 12.3 | Mode 2..... | 45 |
| 12.3.1 | Mode 2, Power Curves | 45 |
| 12.3.2 | Mode 2, C_t values | 46 |
| 12.3.3 | Mode 2, Sound Power Levels | 48 |

Buyer acknowledges that these general specifications are for Buyer's informational purposes only and do not create or constitute a warranty, guarantee, promise, commitment, or other representation by supplier, all of which are disclaimed by supplier except to the extent expressly provided by supplier in writing elsewhere.

See section 11 General Reservations, Notes and Disclaimers, p. 36 for general reservations, notes, and disclaimers applicable to these general specifications.

1 General Description

The Vestas V100-1.8 MW wind turbine is a pitch regulated upwind turbine with active yaw and a three-blade rotor. The Vestas V100-1.8 MW turbine has a rotor diameter of 100 m with a generator rated at 1.8 MW. The turbine utilizes a microprocessor pitch control system called OptiTip[®] and the Variable Speed concepts (VCUS: Vestas Converter Unity System). With these features the wind turbine is able to operate the rotor at variable speed (RPM), helping to maintain the output at or near rated power.

2 Mechanical Design

2.1 Rotor

The V100-1.8 MW turbine is equipped with a 100 meter rotor consisting of three blades and the hub. Based on the prevailing wind conditions, the blades are continuously positioned to help optimise the pitch angle.

| Rotor | |
|--------------------------------|------------------------|
| Diameter | 100 m |
| Swept Area | 7850 m ² |
| Rotational Speed Static, Rotor | 14.9 rpm |
| Speed, Dynamic Operation Range | 9.3-16.6 rpm |
| Rotational Direction | Clockwise (front view) |
| Orientation | Upwind |
| Tilt | 6° |
| Hub Coning | 2° |
| Number of Blades | 3 |
| Aerodynamic Brakes | Full feathering |

Table 2-1: Rotor data.

2.2 Blades

The 49 m Prepreg (PP) blades are made of carbon and fibre glass and consist of two airfoil shells bonded to a supporting beam.

| PP Blades | |
|---------------------------|---|
| Type Description | Airfoil shells bonded to supporting beam |
| Blade Length | 49 m |
| Material | Fibreglass reinforced epoxy and carbon fibres |
| Blade Connection | Steel roots inserted |
| Air Foils | RISØ P + FFA –W3 |
| Chord | 3.9 m |
| Blade Root Outer Diameter | 1.88 m |

| PP Blades | |
|------------------------------|-------------|
| PCD of Steel Root Inserts | 1.80 m |
| R49 | 0.54 m |
| Twist (Blade root/blade tip) | 24,5°/-0,5° |
| Approximate Weight | 7500 kg |

Table 2-2: PP blades data.

2.3 Blade Bearing

The blade bearings are double row 4-point contact ball bearings.

| Blade Bearing | |
|---------------|--|
| Type | 2 row 4-point contact ball bearing |
| Lubrication | Grease lubrication, automatic lubrication pump |

Table 2-3: Blade bearing data.

2.4 Pitch System

The energy input from the wind to the turbine is adjusted by pitching the blades according to the control strategy. The pitch system also works as the primary brake system by pitching the blades out of the wind. This causes the rotor to idle.

Double row 4-point contact ball bearings are used to connect the blades to the hub. The pitch system relies on hydraulics and uses a cylinder to pitch each blade. Hydraulic power is supplied to the cylinder from the hydraulic power unit in the nacelle through the main gearbox and the main shaft via a rotating transfer.

Hydraulic accumulators inside the rotor hub ensure sufficient power to blades in case of failure.

| Pitch System | |
|--------------|---------------|
| Type | Hydraulic |
| Cylinder | Ø125/80 – 760 |
| Number | 1 pcs./ blade |
| Range | -5° to 90° |

Table 2-4: Pitch system data.

| Hydraulic System | |
|------------------|-------------|
| Pump Capacity | 50 l/min |
| Working Pressure | 200-230 bar |
| Oil Quantity | 260 l |
| Motor | 20 kW |

Table 2-5: Hydraulic system data.

2.5 Hub

The hub supports the 3 blades and transfers the reaction forces to the main bearing. The hub structure also supports blade bearings and pitch cylinder.

| Hub | |
|----------|--------------------------------------|
| Type | Cast ball shell hub |
| Material | Cast iron EN GJS 400-18U-LT / EN1560 |

Table 2-6: Hub data.

2.6 Main Shaft

| Main Shaft | |
|------------|------------------------|
| Type | Forged, trumpet shaft |
| Material | 42 CrMo4 QT / EN 10083 |

Table 2-7: Main shaft data.

2.7 Bearing Housing

| Bearing Housing | |
|-----------------|---------------------------------------|
| Type | Cast foot housing with lowered centre |
| Material | Cast iron EN GJS 400-18U-LT / EN1560 |

Table 2-8: Bearing housing data.

2.8 Main Bearings

| Main Bearings | |
|---------------|---|
| Type | Spherical roller bearings |
| Lubrication | Grease lubrication, manually re-greased |

Table 2-9: Main bearings data.

2.9 Gearbox

The main gearbox transmits torque and revolutions from the rotor to the generator.

The main gearbox consists of a planetary stage combined with a two-stage parallel gearbox, torque arms and vibration dampers.

Torque is transmitted from the high-speed shaft to the generator via a flexible composite coupling, located behind the disc brake. The disc brake is mounted directly on the high-speed shaft.

| Gearbox | |
|-------------------|--------------------------------------|
| Type | 1 planetary stage + 2 helical stages |
| Ratio | 1:92.8 nominal |
| Cooling | Oil pump with oil cooler |
| Oil heater | 2 kW |
| Max Gear Oil Temp | 80°C |
| Oil Cleanliness | -/15/12 ISO 4406 |

Table 2-10: Gearbox data.

2.10 Generator Bearings

The bearings are greased and grease is supplied continuously from an automatic lubrication unit when the nacelle temperature is above -10°C. The yearly grease flow is approximately 2400 cm³.

2.11 High Speed Shaft Coupling

The flexible coupling transmits the torque from the gearbox high speed output shaft to the generator input shaft. The flexible coupling is designed to compensate misalignments between gearbox and generator. The coupling consists of two composite discs and an intermediate tube with two aluminium flanges and a fibre glass tube. The coupling is fitted to 3-armed hubs on the brake disc and the generator hub.

| High Speed Shaft Coupling | |
|---------------------------|--------|
| Type Description | VK 420 |

Table 2-11: High speed shaft coupling data.

2.12 Yaw System

The yaw system is designed to keep the turbine upwind. The nacelle is mounted on the yaw plate, which is bolted to the turbine tower. The yaw bearing system is a plain bearing system with built-in friction. Asynchronous yaw motors with brakes enable the nacelle to rotate on top of the tower.

The turbine controller receives information of the wind direction from the wind sensor. Automatic yawing is deactivated when the mean wind speed is below 3 m/s.

| Yaw System | |
|--------------|---|
| Type | Plain bearing system with built-in friction |
| Material | Forged yaw ring heat-treated Plain bearings PETP |
| Yawing Speed | < 0.5°/sec. |

Table 2-12: Yaw system data.

| Yaw Gear | |
|----------------------------------|--|
| Type | Non-locking combined worm gear and planetary gearbox Electrical motor brake |
| Motor | 1.5 kW, 6 pole, asynchronous |
| Number of Yaw Gears | 6 |
| Ratio Total (4 Planetary Stages) | 1,120: 1 |
| Rotational Speed at Full Load | Approximately 1 rpm at output shaft |

Table 2-13: Yaw gear data.

2.13 Crane

The nacelle houses the service crane. The crane is a single system chain hoist.

| Crane | |
|------------------|-------------|
| Lifting Capacity | Max. 800 kg |

Table 2-14: Crane data.

2.14 Tower Structure

Tubular towers with flange connections, certified according to relevant type approvals, are available in different standard heights. Magnets provide load support in a horizontal direction for tower internals, such as platforms, ladders, etc. Tower internals are supported vertically (i.e. in the gravitational direction) by a mechanical connection.

The hub heights listed include a distance from the foundation section to the ground level of approximately 0.6 m depending on the thickness of the bottom flange and a distance from the tower top flange to the centre of the hub of 1.70 m.

| Tower Structure | |
|------------------|---|
| Type Description | Conical tubular |
| Hub Heights (HH) | 80 m/95 m |
| Material | S355 according to EN 10024 A709 according to ASTM |
| Weight | 80 m IEC S 160 metric tonnes* 95 m IEC S 205 metric tonnes** |

Table 2-15: Tower structure (Onshore) data.

NOTE */** Typical values. Dependent on wind class, and can vary with site / project conditions.

2.15 Nacelle Bedplate and Cover

The nacelle cover is made of fibre glass. Hatches are positioned in the floor for lowering or hoisting equipment to the nacelle and evacuation of personnel.

The roof is equipped with wind sensors and skylights which can be opened from inside the nacelle to access the roof and from outside to access the nacelle. The nacelle cover is mounted on the girder structure. Access from the tower to the nacelle is through the yaw system.

The nacelle bedplate is in two parts and consists of a cast iron front part and a girder structure rear part. The front of the nacelle bedplate is the foundation for the drive train, which transmits forces from the rotor to the tower, through the yaw system. The bottom surface is machined and connected to the yaw bearing and the yaw-gears are bolted to the front nacelle bedplate.

The nacelle bedplate carries the crane girders through vertical beams positioned along the site of the nacelle. Lower beams of the girder structure are connected at the rear end.

The rear part of the bedplate serves as foundation for controller panels, generator and transformer.

| Type Description | Material |
|------------------|--------------------------------------|
| Nacelle Cover | GRP |
| Base Frame Front | Cast iron EN GJS 400-18U-LT / EN1560 |
| Base Frame Rear | Welded grid structure |

Table 2-16: Nacelle base-frame and cover data.

2.16 Cooling

The cooling of the main components (gearbox, hydraulic power pack and VCUS converter) in the turbine is done by a water cooling system. The generator is air cooled by nacelle air and the high voltage (HV) transformer is cooled by mainly ambient air.

| Component | Cooling Type | Internal Heating at Low temperature |
|-------------|------------------|---------------------------------------|
| Nacelle | Forced air | Yes |
| Hub/spinner | Natural air | No (Yes Low Temperature (LT) turbine) |
| Gearbox | Water/oil | Yes |
| Generator | Forced air/air | No (heat source) |
| Slip rings | Forced air/air | Yes |
| Transformer | Forced air | No (heat source) |
| VCUS | Forced water/air | Yes |
| VMP section | Forced air/air | Yes |
| Hydraulics | Water/oil | Yes |

Table 2-17: Cooling, summary.

All other heat generating systems are also equipped with fans and or coolers but are considered as minor contributors to nacelle thermodynamics.

2.17 Water Cooling System

The water cooling system is designed as semi-closed systems (closed system but not under pressure) with a free wind water cooler on the roof of the nacelle. This means that the heat loss from the systems (components) is transferred to the water system and the water system is cooled by ambient air.

The water cooling system has three parallel cooling circuits that cool the gearbox, the hydraulic power unit and the VCUS converter.

The water cooling system is equipped with a 3-way thermostatic valve, which is closed (total water flow is bypassing the water cooler) if the temperature of the cooling water is below 35°C and fully open (total water flow is led to the water cooler) if the temperature is above 43°C.

2.18 Gearbox Cooling

The gearbox cooling system consists of two oil circuits that remove the gearbox losses through two plate heat exchangers (oil coolers). The first circuit is equipped with a mechanical driven oil pump and a plate heat exchanger and the second circuit is equipped with an electrical driven oil pump and a plate heat exchanger. The water circuit of the two plate heat exchangers are coupled in serial.

| Gearbox Cooling | |
|---|-----------------------------|
| Gear Oil Plate Heat Exchanger 1 (Mechanically driven oil pump) | |
| Nominal oil flow | 50 l/min |
| Oil inlet temperature | 80°C |
| No. of passes | 2 |
| Cooling capacity | 24.5 kW |
| Gear Oil Plate Heat Exchanger 2 (Electrically driven oil pump) | |
| Nominal oil flow | 85 l/min |
| Oil inlet temperature | 80°C |
| No. of passes | 2 |
| Cooling capacity | 41.5 kW |
| Water Circuit | |
| Nominal water flow | App. 150 l/min (50% glycol) |
| Water inlet temperature | Max. 54°C |
| No. of passes | 1 |
| Heat load | 66 kW |

Table 2-18: Cooling, gearbox data.

2.19 Hydraulic Cooling

The hydraulic cooling system consists of a plate heat exchanger which is mounted on the power pack. In the plate heat exchanger the heat from the hydraulics is transferred to the water cooling system.

| Hydraulic Cooling | |
|---|----------------------------|
| Hydraulic Oil Plate Heat Exchanger | |
| Nominal oil flow | 40 l/min |
| Oil inlet temperature | 66°C |
| Cooling capacity | 10.28 kW |
| Water Circuit | |
| Nominal water flow | App. 45 l/min (50% glycol) |
| Water inlet temperature | Max. 54°C |
| Heat load | 10.28 kW |

Table 2-19: Cooling, hydraulic data.

2.20 VCUS Converter Cooling

The converter cooling system consists of a number of switch modules which is mounted on cooling plates where the cooling water is lead through.

| Converter Cooling | |
|-------------------------|-------------------------------------|
| Nominal water flow | Approximately 45 l/min (50% glycol) |
| Water inlet pressure | Maximum 2.0 bar |
| Water inlet temperature | Maximum 54°C |
| Cooling capacity | 10 kW |

Table 2-20: Cooling, converter data.

2.21 Generator Cooling

The generator cooling systems consists of an air to air cooler mounted on the top of the generator and two internal and one external fan. All the fans can run at low or high speed.

| Generator Cooling | |
|----------------------------------|------------------------|
| Air inlet temperature – external | 50°C |
| Nominal air flow – internal | 8000 m ³ /h |
| Nominal air flow – external | 7500 m ³ /h |
| Cooling capacity | 60 kW |

Table 2-21: Cooling, generator data.

2.22 HV Transformer Cooling

The transformer is equipped with forced air cooling. The cooling system consists of a central fan, which is located under the service floor, an air distribution manifold and six hoses leading to locations beneath and between the HV and LV windings.

| Transformer Cooling | |
|-----------------------|------------------------|
| Nominal air flow | 1920 m ³ /h |
| Air inlet temperature | Maximum 40°C |

Table 2-22: Cooling, transformer data.

2.23 Nacelle Conditioning

The nacelle conditioning system consists of one fan and two air heaters. There are two main circuits of the nacelle conditioning system:

1. Cooling of the HV transformer.
2. Heating and ventilation of the nacelle.

For both systems, the airflow enters the nacelle through louver dampers in the weather shield underneath the nacelle.

The cooling of the HV transformer is described in section 2.22 HV Transformer Cooling, p. 13.

The heating and ventilation of the nacelle is done by means of two air heaters and one fan. To avoid condensation in the nacelle, the two air heaters keep the nacelle temperature +5°C above the ambient temperature. At start-up in cold conditions, the heaters will also heat the air around the gearbox.

The ventilation of the nacelle is done by means of one fan, removing hot air from the nacelle, which is generated by mechanical and electrical equipment.

| Nacelle Cooling | |
|-----------------------|-----------------------|
| Nominal air flow | 1.2 m ³ /s |
| Air inlet temperature | Maximum 50°C |

Table 2-23: Cooling, nacelle data.

| Nacelle Heating | |
|-----------------|----------|
| Rated power | 2 x 6 kW |

Table 2-24: Heating, nacelle data.

3 Electrical Design

3.1 Generator

The generator is a 3-phase asynchronous generator with wound rotor, which is connected to the Vestas Converter Unity System (VCUS) via a slip ring system. The generator is an air-to-air cooled generator with an internal and external cooling circuit. The external circuit uses air from the nacelle and exhausts it out through the rear end of the nacelle.

The generator has six poles. The generator is wound with form windings in both rotor and stator. The stator is connected in star at low power and delta at high power. The rotor is connected in star and is insulated from the shaft. A slip ring is mounted to the rotor for the purpose of the VCUS control.

| Generator | |
|---|--|
| Type Description | Asynchronous with wound rotor, slip rings and VCUS |
| Rated Power (PN) | 1.8 MW |
| Rated Apparent Power | 1.8 MVA ($\cos\phi = 1.00$) |
| Frequency | 60 Hz |
| Voltage, Generator | 690 Vac |
| Voltage, Converter | 480 Vac |
| Number of Poles | 6 |
| Winding Type (Stator/Rotor) | Form/Form |
| Winding Connection, Stator | Star/Delta |
| Rated Efficiency (Generator only) | > 96.5% |
| Power Factor (cos) | 1.0 |
| Over Speed Limit acc. to IEC (2 min.) | 2400 rpm |
| Vibration Level | ≤ 1.8 mm/s |
| Weight | Approx. 8,100 kg |
| Generator Bearing - Temperature | 2 PT100 sensors |
| Generator Stator Windings - Temperature | 3 PT100 sensors placed at hot spots and 3 as back-up |

Table 3-1: Generator data.

3.2 HV Cables

The high voltage cable runs from the transformer in the nacelle down the tower to the switchgear located in the bottom of the tower (switchgear is not included). The high voltage cable is a 4-core rubber insulated halogen free high voltage cable.

| HV Cables | |
|---|--|
| High Voltage Cable Insulation Compound | Improved ethylene-propylene (EP) based material – EPR or high modulus or hard grade ethylene-propylene rubber – HEPR |
| Conductor Cross Section | 3x70/70 mm ² |
| Rated Voltage | 12/20 kV (24 kV) or 20/35 kV (42 kV) depending on the transformer voltage |

Table 3-2: HV cables data.

3.3 Transformer

The transformer is located in a separate locked room in the nacelle with surge arresters mounted on the high voltage side of the transformer. The transformer is a two winding, three-phase dry-type transformer. The windings are delta-connected on the high voltage side unless otherwise specified.

The low voltage windings have a voltage of 690 V and a tapping at 480 V and are star-connected. The 690 V and 480 V systems in the nacelle are a TN-system, which means the star point is connected to earth.

| Transformer | |
|-------------------------------|---------------------|
| Type Description | Dry-type cast resin |
| Primary Voltage | 6-34.5 kV |
| Rated Apparent Power | 2100 kVA |
| Secondary Voltage 1 | 690 V |
| Rated Power 1 at 690 V | 1,900 kVA |
| Secondary Voltage 2 | 480 V |
| Rated Power 2 at 480 V | 200 kVA |
| Vector Group | Dyn5 (option YNyn0) |
| Frequency | 60 Hz |
| HV-tappings | ±2 x 2.5% offload |
| Insulation Class | F |
| Climate Class | C2 |
| Environmental Class | E2 |
| Fire Behaviour Class | F1 |

Table 3-3: Transformer data.

3.4 Converter

The converter controls the energy conversion in the generator. The VCUS converter feeds power from the grid into the generator rotor at sub sync speed and feeds power from the generator rotor to the grid at super sync speed.

| Converter | |
|--|----------|
| Rated Slip | 12% |
| Rated RPM | 1344 RPM |
| Rated Rotor Power (@rated slip) | 193 kW |
| Rated Grid Current (@ rated slip, PF = 1 & 480V) | 232 A |
| Rated Rotor Current (@ rated slip & PF = 1) | 573 A |

Table 3-4: Converter data.

3.5 AUX System

The AUX System is supplied from the 690/480 V socket from the HV transformer. All motors, pumps, fans and heaters are supplied from this system.

All 110 V power sockets are supplied from a 690/110 V transformer.

| Power Sockets | |
|---------------|--------------------|
| Single Phase | 110 V (20 A) |
| Three Phase | 690 V Crane (16 A) |

Table 3-5: AUX system data.

3.6 Wind Sensors

The turbine is equipped with two ultrasonic wind sensors with built-in heaters.

| Wind Sensors | |
|---------------|--------------------|
| Type | FT702LT |
| Principle | Acoustic Resonance |
| Built-in Heat | 99 W |

Table 3-6: Wind sensor data.

3.7 Turbine Controller

The turbine is controlled and monitored by the System 3500 controller hardware and Vestas controller software.

The turbine controller is based on four main processors (Ground, Nacelle, Hub and Converter) which are interconnected by an optical-based 2.5 Mbit ArcNet network.

I/O modules are connected either as rack modules in the System 3500 rack or by CAN.

The turbine control system serves the following main functions:

- Monitoring and supervision of overall operation.
- Synchronizing of the generator to the grid during connection sequence in order to limit the inrush current.
- Operating the wind turbine during various fault situations.
- Automatic yawing of the nacelle.
- OptiTip® - blade pitch control.
- Noise emission control.
- Monitoring of ambient conditions.
- Monitoring of the grid.

The turbine controller hardware is built from the following main modules:

| Module | Function | Network |
|----------------|---|-------------------------------|
| CT3603 | Main processor. Control and monitoring (nacelle and hub). | ArcNet, CAN, Ethernet, serial |
| CT396 | Main processor. Control, monitoring, external communication (ground). | ArcNet, CAN, Ethernet, serial |
| CT360 | Main processor. Converter control and monitoring. | ArcNet, CAN, Ethernet |
| CT3218 | Counter/encoder module. RPM, Azimuth and wind measurement. | Rack module |
| CT3133 | 24 VDC digital input module. 16 channels. | Rack module |
| CT3153 | 24 VDC digital output module. 16 channels. | Rack module |
| CT3320 | 4 channel analogue input (0-10V, 4-20mA, PT100). | Rack module |
| CT6061 | CAN I/O controller | CAN node |
| CT6221 | 3 channel PT100 module | CAN I/O module |
| CT6050 | Blade controller. | CAN node |
| Balluff | Position transducer | CAN node |
| Rexroth | Proportional valve | CAN node |

Table 3-7: Turbine controller hardware.

3.8 Uninterruptible Power Supply (UPS)

The UPS supplies power to critical wind turbine components.

The actual back up time for the UPS system is proportional to the power consumption. Actual back-up time may vary.

| UPS | | |
|-----------------------|----------------------------------|-------------------|
| Battery Type | Valve-Regulated Lead Acid (VRLA) | |
| Rated Battery Voltage | 2 x 8 x 12 V (192 V) | |
| Converter Type | Double conversion online | |
| Rated Output Voltage | 230 V AC | |
| Rated Output Voltage | 230 V AC | |
| Converter Input | 230 V \pm 20% | |
| Back-up Time* | Controller system | 30 seconds |
| | Safety systems | 35 minutes |
| Re-charging Time | Typical | Approx. 2.5 hours |

Table 3-8: UPS data.

NOTE * For alternative back-up times, consult Vestas!

4 Turbine Protection Systems

4.1 Braking Concept

The main brake on the turbine is aerodynamic. Braking the turbine is done by feathering the three blades. During emergency stop all three blades will feather simultaneously to full end stop and thereby slowing the rotor speed.

In addition there is a mechanical disc brake on the high speed shaft of the gearbox. The mechanical brake is only used as a parking brake, and when activating the emergency stop push buttons.

4.2 Short Circuit Protections

| Breakers | Generator / Q8 ABB E2B 2000 690 V | Controller / Q15 ABB S3X 690 V | VCS-VCUS / Q7 ABB S5H 400 480 V |
|--|---|--------------------------------------|---------------------------------------|
| Breaking Capacity I_{cu} , I_{cs} | 42, 42 kA | 75, 75 kA | 40, 40 kA |
| Making Capacity I_{cm} (415V Data) | 88 kA | 440 kA | 143 kA |
| Thermo Release I_{th} | 2000 A | 100 A | 400 A |

Table 4-1: Short circuit protection data.

4.3 Overspeed Protection

The generator RPM and the main shaft RPM are registered by inductive sensors and calculated by the wind turbine controller in order to protect against over-speed and rotating errors.

The turbine is also equipped with a VOG (Vestas Overspeed Guard), which is an independent computer module measuring the rotor RPM, and in case of an overspeed situation the VOG activates the emergency feathered position (full feathering) of the three blades.

| Overspeed Protection | |
|----------------------|---|
| VOG Sensors Type | Inductive |
| Trip Levels | 17.3 (Rotor RPM) / 1597 (Generator RPM) |

Table 4-2: Overspeed protection data.

4.4 EMC System

The turbine and related equipment must fulfil the EU EMC-Directive with later amendments:

- Council Directive 2004/108/EC of 15 December 2004 on the approximation of the laws of the Member States relating to Electromagnetic Compatibility.
- The (Electromagnetic Compatibility) EMC-Directive with later amendments.

4.5 Lightning System

The Lightning Protection System (LPS) consists of three main parts.

- Lightning receptors.
- Down conducting system.
- Earthing System.

| Lightning Protection Design Parameters | | | Protection Level I |
|--|--------------------|---------|--------------------|
| Current Peak Value | i_{\max} | [kA] | 200 |
| Total Charge | Q_{total} | [C] | 300 |
| Specific Energy | W/R | [MJ/Ω] | 10 |
| Average Steepness | di/dt | [kA/μs] | 200 |

Table 4-3: Lightning design parameters.

NOTE The Lightning Protection System is designed according to IEC standards (see section 7.7 Design Codes – Lightning Protection, p. 27). Lightning strikes are considered force majeure, i.e. damage caused by lightning strikes is not warranted by Vestas.

4.6 Earthing (also known as grounding)

The Vestas Earthing System is based on foundation earthing.

Vestas document no. 0000-3388 contains the list of documents regarding Vestas Earthing System.

Requirements in the Vestas Earthing System specifications and work descriptions are minimum requirements from Vestas and IEC. Local and national requirements may require additional measures.

4.7 Corrosion Protection

Classification of corrosion categories for atmospheric corrosion is according to ISO 9223:1992.

| Corrosion Protection | External Areas | Internal Areas |
|----------------------|----------------|---|
| Nacelle | C5 | C3 and C4 Climate strategy: Heating the air inside the nacelle compared to the outside air temperature lowers the relative humidity and helps ensure a controlled corrosion level. |
| Hub | C5 | C3 |
| Tower | C5-I | C3 |

Table 4-4: Corrosion protection data for nacelle, hub and tower.

5 Safety

The safety specifications in this safety section provide limited general information about the safety features of the turbine and are not a substitute for Buyer and its agents taking all appropriate safety precautions, including but not limited to (a) complying with all applicable safety, operation, maintenance, and service agreements, instructions, and requirements, (b) complying with all safety-related laws, regulations, and ordinances, (c) conducting all appropriate safety training and education and (d) reading and understanding all safety-related manuals and instructions. See section 5.13 Manuals and Warnings, p. 23 for additional guidance.

5.1 Access

Access to the turbine from the outside is through the bottom of the tower. The door is equipped with a lock. Access to the top platform in the tower is by a ladder or service lift. Access to the nacelle from the top platform is by ladder. Access to the transformer room in the nacelle is equipped with a lock. Unauthorised access to electrical switch boards and power panels in the turbine is prohibited according to IEC 60204-1 2006.

5.2 Escape

In addition to the normal access routes, alternative escape routes from the nacelle are through the crane hatch.

The hatch in the roof can be opened from both the inside and outside.

Escape from the service lift is by ladder.

5.3 Rooms/Working Areas

The tower and nacelle are equipped with connection points for electrical tools for service and maintenance of the turbine.

5.4 Platforms, Standing and Working Places

The bottom tower section has three platforms. There is one platform at the entrance level (door level), one safety platform approximately three metres above the entrance platform and finally a platform in the top of the tower section.

Each middle tower section has one platform in the top of the tower section.

The top tower section has two platforms. A top platform and a service lift platform - where the service lift stops - below the top platform.

There are places to stand at various locations along the ladder.

The platforms have anti-slip surfaces.

Foot supports are placed in the turbine for maintenance and service purposes.

5.5 Climbing Facilities

A ladder with a fall arrest system (rigid rail or wire system) is mounted through the tower.

Rest platforms are provided at maximum intervals of 9 metres along the tower ladder between platforms.

There are anchorage points in the tower, nacelle, hub and on the roof for attaching a fall arrest equipment (full body harness).

Over the crane hatch there is an anchorage point for the emergency descent equipment. The anchorage point is tested to 22.2 kN.

Anchorage points are coloured yellow and are calculated and tested to 22.2 kN.

5.6 Moving Parts, Guards and Blocking Devices

Moving parts in the nacelle are shielded.

The turbine is equipped with a rotor lock to block the rotor and drive train.

It is possible to block the pitch of the cylinder with mechanical tools in the hub.

5.7 Lighting

The turbine is equipped with light in the tower, nacelle and in the hub.

There is emergency light in case of loss of electrical power.

5.8 Noise

When the turbine is out of operation for maintenance, the sound level in the nacelle is below 80 dB(A). In operation mode ear protection is required.

5.9 Emergency Stop

There are emergency stops in the nacelle and in the bottom of the tower.

5.10 Power Disconnection

The turbine is designed to allow for disconnection from all its power sources during inspection or maintenance. The switches are marked with signs and are located in the nacelle and in the bottom of the tower.

5.11 Fire Protection/First Aid

A 5 kg CO₂ fire extinguisher must be located in the nacelle at the left yaw gear. The location of the fire extinguisher, and how to use it, must be confirmed before operating the turbine.

A first aid kit must be placed by the wall at the back end of the nacelle. The location of the first aid kit, and how to use it, must be confirmed before operating the turbine.

Above the generator there must be a fire blanket which can be used to put out small fires.

5.12 Warning Signs

Additional warning signs inside or on the turbine must be reviewed before operating or servicing of the turbine.

5.13 Manuals and Warnings

Vestas OH&S manual and manuals for operation, maintenance and service of the turbine provide additional safety rules and information for operating, servicing or maintaining the turbine.

6 Environment

6.1 Chemicals

Chemicals used in the turbine are evaluated according to Vestas Wind Systems A/S Environmental system certified according to ISO 14001:2004.

- Anti-freeze liquid to help prevent the cooling system from freezing.
- Gear oil for lubricating the gearbox.
- Hydraulic oil to pitch the blades and operate the brake.
- Grease to lubricate bearings.
- Various cleaning agents and chemicals for maintenance of the turbine.

7 Approvals, Certificates and Design Codes

7.1 Type Approvals

The turbine is type certified according to the certification standards listed below:

| Certification | Wind Class | Hub Height |
|--|------------|------------|
| Type Certificate after IEC WT01 and IEC 61400-1:2005 | IEC S* | 80 m |
| | IEC S* | 95 m |

**Refer to section 9.1 Climate and Site Conditions, p. 28 for details.*

Table 7-1: Type approvals.

7.2 Design Codes – Structural Design

The structural design has been developed and tested with regard to, but not limited to, the following main standards.

| Design Codes – Structural Design | |
|----------------------------------|---|
| Nacelle and Hub | IEC 61400-1:2005 EN 50308 ANSI/ASSE Z359.1-2007 |
| Bedframe | IEC 61400-1:2005 |
| Tower | IEC 61400-1:2005 Eurocode 3 DIBt: Richtlinie für Windenergieanlagen, Einwirkungen und Standsicherheitsnachweise für Turm und Gründung, 4th edition. |

Table 7-2: Structural design codes.

7.3 Design Codes – Mechanical Equipment

The mechanical equipment has been developed and tested with regard to, but not limited to, the following main standards:

| Design Codes – Mechanical Equipment | |
|-------------------------------------|---|
| Gear | Designed in accordance to rules in ISO 81400-4 |
| Blades | DNV-OS-J102 IEC 1024-1 IEC 60721-2-4 IEC 61400 (Part 1, 12 and 23) IEC WT 01 IEC DEFU R25 ISO 2813 DS/EN ISO 12944-2 |

Table 7-3: Mechanical equipment design codes.

7.4 Design Codes – Electrical Equipment

The electrical equipment has been developed and tested with regard to, but not limited to, the following main standards:

| Design Codes – Electrical Equipment | |
|--|--------------|
| High Voltage AC Circuit Breakers | IEC 60056 |
| High Voltage Testing Techniques | IEC 60060 |
| Power Capacitors | IEC 60831 |
| Insulating Bushings for AC Voltage above 1kV | IEC 60137 |
| Insulation Co-ordination | BS EN 60071 |
| AC Disconnectors and Earth Switches | BS EN 60129 |
| Current Transformers | IEC 60185 |
| Voltage Transformers | IEC 60186 |
| High Voltage Switches | IEC 60265 |
| Disconnectors and Fuses | IEC 60269 |
| Flame Retardant Standard for MV Cables | IEC 60332 |
| Transformer | IEC 60076-11 |
| Generator | IEC 60034 |
| Specification for Sulphur Hexafluoride for Electrical Equipment | IEC 60376 |
| Rotating Electrical Machines | IEC 34 |

| Design Codes – Electrical Equipment | |
|--|------------------|
| Dimensions and Output Ratings for Rotating Electrical Machines | IEC 72 & IEC 72A |
| Classification of Insulation, Materials for Electrical Machinery | IEC 85 |
| Safety of Machinery – Electrical Equipment of Machines | IEC 60204-1 |

Table 7-4: Electrical equipment design codes.

7.5 Design Codes – I/O Network System

The distributed I/O network system has been developed and tested with regard to, but not limited to, the following main standards:

| Design Codes – I/O Network System | |
|-----------------------------------|----------------|
| Salt Mist Test | IEC 60068-2-52 |
| Damp Head, Cyclic | IEC 60068-2-30 |
| Vibration Sinus | IEC 60068-2-6 |
| Cold | IEC 60068-2-1 |
| Enclosure | IEC 60529 |
| Damp Head, Steady State | IEC 60068-2-56 |
| Vibration Random | IEC 60068-2-64 |
| Dry Heat | IEC 60068-2-2 |
| Temperature Shock | IEC 60068-2-14 |
| Free Fall | IEC 60068-2-32 |

Table 7-5: I/O Network system design codes.

7.6 Design Codes – EMC System

To fulfil EMC requirements the design must be as recommended for lightning protection, see section 7.7 Design Codes – Lightning Protection, p. 27.

| Design Codes – EMC System | |
|--|-------------------|
| Designed according to | IEC 61400-1: 2005 |
| Further robustness requirements according to | TPS 901785 |

Table 7-6: EMC system design codes.

7.7 Design Codes – Lightning Protection

The LPS is designed according to Lightning Protection Level (LPL) I:

| Design Codes – Lightning Protection | |
|---|----------------------|
| Designed according to | IEC 62305-1: 2006 |
| | IEC 62305-3: 2006 |
| | IEC 62305-4: 2006 |
| Non Harmonized Standard and Technically Normative Documents | IEC/TR 61400-24:2002 |

Table 7-7: Lightning protection design codes.

7.8 Design Codes – Earthing

The Vestas Earthing System design is based on and complies with the following international standards and guidelines:

- IEC 62305-1 Ed. 1.0: Protection against lightning – Part 1: General principles.
- IEC 62305-3 Ed. 1.0: Protection against lightning – Part 3: Physical damage to structures and life hazard.
- IEC 62305-4 Ed. 1.0: Protection against lightning – Part 4: Electrical and electronic systems within structures.
- IEC/TR 61400-24. First edition. 2002-07. Wind turbine generator systems - Part 24: Lightning protection.
- IEC 60364-5-54. Second edition 2002-06. Electrical installations of buildings - Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors.
- IEC 61936-1. First edition. 2002-10. Power installations exceeding 1kV a.c.- Part 1: Common rules.

8 Colour and Surface Treatment

8.1 Nacelle Colour and Surface Treatment

| Surface Treatment of Vestas Nacelles | |
|--------------------------------------|-----------------------|
| Standard Nacelle Colours | RAL 7035 (light grey) |
| Gloss | According to ISO 2813 |

Table 8-1: Surface treatment, nacelle.

8.2 Tower Colour and Surface Treatment

| Surface Treatment of Vestas Tower Section | | |
|---|-----------------------|------------------------|
| | External: | Internal: |
| Tower Colour Variants | RAL 7035 (light grey) | RAL 9001 (cream white) |
| Gloss | 50-75% UV resistant | Maximum 50% |

Table 8-2: Surface treatment, tower.

8.3 Blades Colour

| Blades Colour | |
|--------------------------------|---|
| Blade Colour | RAL 7035 (Light Grey) |
| Tip-End Colour Variants | RAL 2009 (Traffic Orange), RAL 3000 (Flame Red), RAL 3020 (Traffic Red) |
| Gloss | < 20% |

Table 8-3: Colours, blades.

9 Operational Envelope and Performance Guidelines

Actual climatic and site conditions have many variables and must be considered in evaluating actual turbine performance. The design and operating parameters set forth in this section do not constitute warranties, guarantees, or representations as to turbine performance at actual sites.

NOTE As evaluation of climate and site conditions is complex, it is needed to consult Vestas for every project.

9.1 Climate and Site Conditions

Values refer to hub height:

| Extreme Design Parameters | |
|---|---------------|
| Wind Climate | IEC S |
| Ambient Temperature Interval (Normal Temperature Turbine) | -30° to +50°C |
| Extreme Wind Speed (10 min. average) | 42.5 m/s |
| Survival Wind Speed (3 sec. gust) | 59.5 m/s |

Table 9-1: Extreme design parameters.

| Average Design Parameters | |
|--|----------|
| Wind Climate | IEC S |
| Wind Speed | 7.5 m/s |
| A-factor | 8.45 m/s |
| Form Factor, c | 2.0 |
| Turbulence Intensity acc. to IEC 61400-1, including Wind Farm Turbulence (@ 15 m/s – 90% quantile) | 18% |
| Wind Shear | 0.20 |
| Inflow Angle (vertical) | 8° |

Table 9-2: Average design parameters.

9.1.1 Complex Terrain

Classification of complex terrain acc. to IEC 61400-1:2005 Chapter 11.2.

For sites classified as complex appropriate measures are to be included in site assessment.

9.1.2 Altitude

The turbine is designed for use at altitudes up to 1500 m above sea level as standard.

Above 1500 m special considerations must be taken regarding e.g. HV installations and cooling performance. Consult Vestas for further information.

9.1.3 Wind Farm Layout

Turbine spacing is to be evaluated site-specifically. Spacing in any case not below three rotor diameters (3D).

DISCLAIMER

As evaluation of climate and site conditions is complex, consult Vestas for every project. If conditions exceed the above parameters Vestas must be consulted!

9.2 Operational Envelope – Temperature and Wind

Values refer to hub height and as determined by the sensors and control system of the turbine.

| Operational Envelope – Temperature and Wind | |
|---|----------------|
| Ambient Temperature Interval (Normal Temperature Turbine) | -20° to +40° C |
| Cut-in (10 min. average) | 3 m/s |
| Cut-out (100 sec. exponential average) | 20 m/s |
| Re-cut in (100 sec. exponential average) | 18 m/s |

Table 9-3: Operational envelope - temperature and wind.

9.3 Operational Envelope – Grid Connection *

Values refer to hub height and as determined by the sensors and control system of the turbine.

| Operational Envelope - Grid Connection | | |
|--|------------------------|-------|
| Nominal Phase Voltage | $U_{P, \text{nom}}$ | 400 V |
| Nominal Frequency | f_{nom} | 60 Hz |
| Max. Steady State Voltage Jump | $\pm 2\%$ | |
| Max. Frequency Gradient | $\pm 4 \text{ Hz/sec}$ | |
| Max. Negative Sequence Voltage | 3% | |

Table 9-4: Operational envelope - grid connection.

The generator and the converter will be disconnected if:

| | U_P | U_N |
|---|---------|-------|
| Voltage above 110% of nominal for 60 sec. | 440 V | 759 V |
| Voltage above 115% of nominal for 2 sec. | 460 V | 794 V |
| Voltage above 120% of nominal for 0.08 sec. | 480 V | 828 V |
| Voltage above 125% of nominal for 0.005 sec | 500 V | 863 V |
| Voltage below 90% of nominal for 60 sec. | 360 V | 621 V |
| Voltage below 85% of nominal for 11 sec. | 340 V | 586 V |
| Frequency is above [Hz] for 0.2 sec. | 63.6 Hz | |
| Frequency is below [Hz] for 0.2 sec. | 56.4 Hz | |

Table 9-5: Generator and converter disconnecting values.

NOTE * Over the turbine lifetime, grid drop-outs are to occur at an average of no more than 50 times a year.

9.4 Performance – Fault Ride Through

The turbine is equipped with a reinforced Vestas Converter System in order to gain better control of the generator during grid faults. The controllers and contactors have a UPS backup system in order to keep the turbine control system running during grid faults.

The pitch system is optimised to keep the turbine within normal speed conditions and the generator speed is accelerated in order to store rotational energy and be able to resume normal power production faster after a fault and keep mechanical stress on the turbine at a minimum.

The turbine is designed to stay connected during grid disturbances within the voltage tolerance curve in Figure 9-1, p. 31.




Figure 9-1: Low voltage tolerance curve for symmetrical and asymmetrical faults.

For grid disturbances outside the protection curve in Figure 9-2, p. 31, the turbine will be disconnected from the grid.




Figure 9-2: Default low voltage protection settings for symmetrical and asymmetrical faults.

| Power Recovery Time | |
|--|-------------|
| Power recovery to 90% of pre-fault level | Max 1.0 sec |

9.5 Current Contribution

During the grid dip the generator is typical magnetized from the converter. The controller setpoints are set to keep the reactive current exchange with the grid close to zero and keep as much torque on the generator as possible.

9.6 Performance – Multiple Voltage Dips

The turbine is designed to handle re-closure events and multiple voltage dips within a short period of time, due to the fact that voltage dips are not evenly distributed during the year. As an example 6 voltage dips of duration of 200 ms down to 20% voltage within 30 minutes will normally not lead to a problem for the turbine.

9.7 Performance – Active Power Control

The turbine is designed for control of active power via the VestasOnline™ SCADA system.

Max. Ramp Rates for External Control

| | |
|--------------|------------|
| Active Power | 0.1 pu/sec |
|--------------|------------|

To protect the turbine active power cannot be controlled to values below the curve in Figure 9-3, p. 32.




Figure 9-3: Minimum active power output dependant of wind speed.

9.8 Performance – Frequency Control

The turbine can be configured to perform frequency control by decreasing the output power as a linear function of the grid frequency (over frequency).

Dead band and slope for the frequency control function are configurable.

9.9 Performance – Own Consumption

The consumption of electrical power by the wind turbine is defined as consumption when the wind turbine is not producing energy (generator is not connected to the grid). This is defined in the control system as Production Generator (zero).

The following components have the largest influence on the power consumption of the wind turbine:

| Own Consumption | |
|---|---|
| Hydraulic Motor | 20 kW |
| Yaw Motors 6 x 1.75 kW | 10.5 kW |
| Oil Heating 3 x 0.76 kW | 2.3 kW |
| Air Heaters 2 x 6 kW (std) 3 x 6 kW (LT) | 12 kW (Standard) 18 kW (Low Temperature) |
| Oil Pump for Gearbox Lubrication | 3.5 kW |
| HV Transformer located in the nacelle has a no-load loss of | Max. 3.9 kW |

Table 9-6: Own consumption data.

9.10 Operational Envelope Conditions for Power Curve, C_t Values (at Hub Height)

See appendix section 12.1 Mode 0, p. 37, 12.2 Mode 1, p. 41 and 12.3 Mode 2, p. 45 for power curve, C_t values and noise level.

| Conditions for Power Curve, C_t Values (at Hub Height) | |
|--|-------------------------------|
| Wind Shear | 0.10 - 0.16 (10 min. average) |
| Turbulence Intensity | 8 - 12% (10 min. average) |
| Blades | Clean |
| Rain | No |
| Ice/Snow on Blades | No |
| Leading Edge | No damage |
| Terrain | IEC 61400-12-1 |
| Inflow Angle (Vertical) | $0 \pm 2^\circ$ |
| Grid Frequency | 60 ± 0.5 Hz |

Table 9-7: Conditions for power curve, C_t values.

10 Drawings

10.1 Structural Design – Illustration of Outer Dimensions




Figure 10-1: Illustration of outer dimensions – structure.

10.2 Structural Design – Side View Drawing




Figure 10-2: Side view drawing.

11 General Reservations, Notes and Disclaimers

- These general specifications apply to the current version of the V100 wind turbine. Updated versions of the V100 wind turbine, which may be manufactured in the future, may have general specifications that differ from these general specifications. In the event that Vestas supplies an updated version of the V100 wind turbine, Vestas will provide updated general specifications applicable to the updated version.
- Periodic operational disturbances and generator power de-rating may be caused by combination of high winds, low voltage or high temperature.
- Vestas recommends that the grid be as close to nominal as possible with little variation in frequency.
- A certain time allowance for turbine warm-up must be expected following grid dropout and/or periods of very low ambient temperature.
- The estimated power curve for the different estimated noise levels (sound power levels) is for wind speeds at 10 minute average value at hub height and perpendicular to the rotor plane.
- All listed start/stop parameters (e. g. wind speeds and temperatures) are equipped with hysteresis control. This can, in certain borderline situations, result in turbine stops even though the ambient conditions are within the listed operation parameters.
- The earthing system must comply with the minimum requirements from Vestas, and be in accordance with local and national requirements, and codes of standards.
- Lightning strikes are considered force majeure, i.e. damage caused by lightning strikes is not warranted by Vestas.
- For the avoidance of doubt, this document 'General Specifications' is not, and does not contain, any guarantee, warranty and/or verification of the power curve and noise (including, without limitation, the power curve and noise verification method). Any guarantee, warranty and/or verification of the power curve and noise (including, without limitation, the power curve and noise verification method) must be agreed to separately in writing.

12 Appendices

Power Curve, C_t values and Sound Power Levels for Mode 0 to 2 are defined below.

12.1 Mode 0

12.1.1 Mode 0, Power Curve

| Mode 0, Power curve | | | | | | | | | | | | | | |
|---------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| Wind speed [m/s] | Air density kg/m ³ | | | | | | | | | | | | | |
| | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 13 | 9 | 9 | 9 | 10 | 10 | 11 | 11 | 11 | 12 | 12 | 13 | 14 | 15 |
| 3.5 | 53 | 34 | 36 | 38 | 39 | 41 | 43 | 45 | 46 | 48 | 50 | 52 | 55 | 57 |
| 4 | 112 | 80 | 83 | 86 | 89 | 92 | 95 | 98 | 101 | 104 | 106 | 109 | 115 | 118 |
| 4.5 | 181 | 136 | 140 | 144 | 148 | 152 | 156 | 160 | 165 | 169 | 173 | 177 | 185 | 189 |
| 5 | 260 | 198 | 203 | 209 | 215 | 220 | 226 | 232 | 237 | 243 | 248 | 254 | 265 | 271 |
| 5.5 | 353 | 270 | 278 | 285 | 293 | 300 | 308 | 315 | 323 | 330 | 338 | 345 | 360 | 368 |
| 6 | 462 | 356 | 365 | 375 | 385 | 395 | 404 | 414 | 424 | 433 | 443 | 453 | 472 | 481 |
| 6.5 | 581 | 443 | 455 | 468 | 481 | 493 | 506 | 518 | 531 | 544 | 556 | 569 | 594 | 606 |
| 7 | 736 | 563 | 579 | 595 | 611 | 626 | 642 | 658 | 673 | 689 | 705 | 720 | 751 | 767 |
| 7.5 | 911 | 700 | 720 | 739 | 758 | 777 | 796 | 816 | 835 | 854 | 873 | 892 | 930 | 949 |
| 8 | 1108 | 856 | 879 | 902 | 925 | 948 | 971 | 994 | 1017 | 1040 | 1063 | 1086 | 1131 | 1153 |
| 8.5 | 1321 | 1028 | 1055 | 1082 | 1110 | 1137 | 1163 | 1190 | 1216 | 1243 | 1269 | 1295 | 1347 | 1372 |
| 9 | 1524 | 1212 | 1243 | 1273 | 1304 | 1335 | 1363 | 1392 | 1421 | 1449 | 1474 | 1499 | 1547 | 1570 |
| 9.5 | 1679 | 1397 | 1429 | 1460 | 1491 | 1522 | 1547 | 1572 | 1597 | 1622 | 1641 | 1660 | 1695 | 1710 |
| 10 | 1766 | 1566 | 1591 | 1616 | 1641 | 1666 | 1682 | 1699 | 1716 | 1733 | 1744 | 1755 | 1773 | 1780 |
| 10.5 | 1800 | 1689 | 1705 | 1721 | 1737 | 1753 | 1762 | 1770 | 1779 | 1788 | 1792 | 1796 | 1802 | 1804 |
| 11 | 1811 | 1764 | 1772 | 1779 | 1786 | 1794 | 1797 | 1800 | 1803 | 1807 | 1808 | 1809 | 1812 | 1813 |
| 11.5 | 1815 | 1796 | 1799 | 1802 | 1805 | 1808 | 1809 | 1811 | 1812 | 1813 | 1814 | 1814 | 1815 | 1815 |
| 12 | 1815 | 1808 | 1810 | 1811 | 1812 | 1814 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 12.5 | 1815 | 1813 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 13 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 13.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 14 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 14.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 16 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

| Mode 0, Power curve | | | | | | | | | | | | | | |
|---------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| | Air density kg/m ³ | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 16.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 18 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 18.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 20 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

Table 12-1: Mode 0, power curve.

12.1.2 Mode 0, C_t values

| Mode 0, C_t values | | | | | | | | | | | | | | |
|----------------------|-------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Wind speed [m/s] | Air density kg/m ³ | | | | | | | | | | | | | |
| | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 |
| 3.5 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 |
| 4 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 |
| 4.5 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 |
| 5 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 | 0.820 |
| 5.5 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 | 0.806 |
| 6 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 | 0.802 |
| 6.5 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 | 0.814 |
| 7 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 | 0.807 |
| 7.5 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 | 0.804 |
| 8 | 0.795 | 0.800 | 0.800 | 0.799 | 0.799 | 0.799 | 0.799 | 0.798 | 0.798 | 0.797 | 0.796 | 0.796 | 0.794 | 0.793 |
| 8.5 | 0.768 | 0.786 | 0.784 | 0.783 | 0.782 | 0.780 | 0.779 | 0.777 | 0.776 | 0.774 | 0.772 | 0.770 | 0.766 | 0.764 |
| 9 | 0.716 | 0.756 | 0.754 | 0.751 | 0.749 | 0.746 | 0.743 | 0.739 | 0.736 | 0.732 | 0.727 | 0.721 | 0.710 | 0.704 |
| 9.5 | 0.636 | 0.713 | 0.708 | 0.703 | 0.698 | 0.693 | 0.685 | 0.678 | 0.670 | 0.663 | 0.654 | 0.645 | 0.627 | 0.617 |
| 10 | 0.545 | 0.657 | 0.648 | 0.639 | 0.630 | 0.621 | 0.610 | 0.599 | 0.589 | 0.578 | 0.567 | 0.556 | 0.535 | 0.524 |
| 10.5 | 0.459 | 0.587 | 0.576 | 0.564 | 0.552 | 0.540 | 0.528 | 0.517 | 0.505 | 0.493 | 0.482 | 0.471 | 0.449 | 0.439 |
| 11 | 0.389 | 0.514 | 0.501 | 0.488 | 0.475 | 0.462 | 0.451 | 0.440 | 0.428 | 0.417 | 0.408 | 0.398 | 0.380 | 0.372 |
| 11.5 | 0.333 | 0.442 | 0.430 | 0.418 | 0.406 | 0.395 | 0.385 | 0.376 | 0.366 | 0.357 | 0.349 | 0.341 | 0.325 | 0.318 |
| 12 | 0.288 | 0.381 | 0.370 | 0.360 | 0.350 | 0.340 | 0.332 | 0.324 | 0.316 | 0.308 | 0.301 | 0.294 | 0.282 | 0.276 |
| 12.5 | 0.251 | 0.330 | 0.322 | 0.313 | 0.305 | 0.296 | 0.289 | 0.282 | 0.275 | 0.269 | 0.263 | 0.257 | 0.246 | 0.241 |
| 13 | 0.222 | 0.289 | 0.282 | 0.275 | 0.267 | 0.260 | 0.254 | 0.248 | 0.242 | 0.236 | 0.231 | 0.227 | 0.217 | 0.213 |
| 13.5 | 0.197 | 0.256 | 0.249 | 0.243 | 0.237 | 0.230 | 0.225 | 0.220 | 0.215 | 0.210 | 0.206 | 0.201 | 0.193 | 0.189 |
| 14 | 0.176 | 0.227 | 0.222 | 0.216 | 0.211 | 0.205 | 0.201 | 0.196 | 0.192 | 0.187 | 0.184 | 0.180 | 0.173 | 0.169 |
| 14.5 | 0.158 | 0.203 | 0.199 | 0.194 | 0.189 | 0.184 | 0.180 | 0.176 | 0.172 | 0.168 | 0.165 | 0.161 | 0.155 | 0.152 |
| 15 | 0.142 | 0.183 | 0.178 | 0.174 | 0.170 | 0.165 | 0.162 | 0.158 | 0.155 | 0.151 | 0.148 | 0.145 | 0.140 | 0.137 |
| 15.5 | 0.129 | 0.165 | 0.161 | 0.157 | 0.153 | 0.150 | 0.146 | 0.143 | 0.140 | 0.137 | 0.134 | 0.132 | 0.127 | 0.124 |
| 16 | 0.117 | 0.150 | 0.146 | 0.143 | 0.139 | 0.136 | 0.133 | 0.130 | 0.127 | 0.125 | 0.122 | 0.120 | 0.115 | 0.113 |
| 16.5 | 0.107 | 0.137 | 0.133 | 0.130 | 0.127 | 0.124 | 0.121 | 0.119 | 0.116 | 0.114 | 0.112 | 0.109 | 0.105 | 0.103 |
| 17 | 0.098 | 0.125 | 0.122 | 0.119 | 0.116 | 0.114 | 0.111 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.097 | 0.095 |
| 17.5 | 0.091 | 0.115 | 0.112 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.098 | 0.096 | 0.094 | 0.092 | 0.089 | 0.087 |
| 18 | 0.084 | 0.105 | 0.103 | 0.101 | 0.098 | 0.096 | 0.094 | 0.092 | 0.090 | 0.088 | 0.087 | 0.085 | 0.082 | 0.081 |
| 18.5 | 0.077 | 0.097 | 0.095 | 0.093 | 0.091 | 0.089 | 0.087 | 0.085 | 0.083 | 0.082 | 0.080 | 0.079 | 0.076 | 0.075 |
| 19 | 0.072 | 0.090 | 0.088 | 0.086 | 0.084 | 0.082 | 0.081 | 0.079 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.069 |

| Mode 0, C_t values | | | | | | | | | | | | | | |
|----------------------|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Air density kg/m^3 | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 19.5 | 0.067 | 0.084 | 0.082 | 0.080 | 0.078 | 0.077 | 0.075 | 0.074 | 0.072 | 0.071 | 0.069 | 0.068 | 0.066 | 0.065 |
| 20 | 0.062 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.070 | 0.069 | 0.067 | 0.066 | 0.065 | 0.063 | 0.061 | 0.060 |

Table 12-2: Mode 0, C_t values.

12.1.3 Mode 0, Sound Power Levels

| Sound Power Level at Hub Height, Mode 0 | | |
|--|--|---------------|
| Conditions for Sound Power Level | Verification standard: IEC 61400-11 Ed. 2. Wind shear 0.15 Max turbulence at 10 meter height: 16% Inflow angle (vertical): $0 \pm 2^\circ$ Air density: 1.225 kg/m^3 | |
| Hub Height | 80 m | 95 m |
| LwA @ 3 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 93.8 4.2 | 93.8 4.3 |
| LwA @ 4 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 96.0 5.6 | 96.4 5.7 |
| LwA @ 5 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 100.1 7.0 | 100.7 7.2 |
| LwA @ 6 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.9 8.4 | 104.4 8.6 |
| LwA @ 7 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 9.8 | 105.0 10.0 |
| LwA @ 8 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 11.2 | 105.0 11.5 |
| LwA @ 9 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 12.6 | 105.0 12.9 |
| LwA @ 10 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 13.9 | 105.0 14.3 |
| LwA @ 11 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 15.3 | 105.0 15.8 |
| LwA @ 12 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 16.7 | 105.0 17.2 |
| LwA @ 13 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 18.1 | 105.0 18.6 |

Table 12-3: Sound power level at hub height: Mode 0.

12.2 Mode 1

12.2.1 Mode 1, Power Curves

| Mode 1, Power curves | | | | | | | | | | | | | | |
|----------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| Wind speed [m/s] | Air density kg/m ³ | | | | | | | | | | | | | |
| | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 13 | 9 | 9 | 9 | 10 | 10 | 11 | 11 | 11 | 12 | 12 | 13 | 14 | 15 |
| 3.5 | 53 | 34 | 36 | 38 | 39 | 41 | 43 | 45 | 46 | 48 | 50 | 52 | 55 | 57 |
| 4 | 112 | 80 | 83 | 86 | 89 | 92 | 95 | 98 | 101 | 104 | 106 | 109 | 115 | 118 |
| 4.5 | 180 | 134 | 139 | 143 | 147 | 151 | 155 | 159 | 163 | 167 | 171 | 175 | 184 | 188 |
| 5 | 256 | 195 | 200 | 206 | 211 | 217 | 223 | 228 | 234 | 239 | 245 | 250 | 261 | 267 |
| 5.5 | 346 | 265 | 273 | 280 | 287 | 295 | 302 | 310 | 317 | 324 | 332 | 339 | 354 | 361 |
| 6 | 453 | 349 | 358 | 368 | 377 | 387 | 396 | 406 | 415 | 425 | 434 | 444 | 463 | 472 |
| 6.5 | 576 | 439 | 451 | 464 | 476 | 489 | 501 | 514 | 526 | 539 | 551 | 564 | 588 | 601 |
| 7 | 728 | 558 | 573 | 589 | 604 | 620 | 635 | 651 | 666 | 682 | 697 | 713 | 744 | 759 |
| 7.5 | 902 | 693 | 712 | 731 | 750 | 769 | 788 | 807 | 826 | 845 | 864 | 883 | 920 | 939 |
| 8 | 1098 | 847 | 870 | 893 | 916 | 939 | 961 | 984 | 1007 | 1030 | 1053 | 1075 | 1120 | 1143 |
| 8.5 | 1312 | 1019 | 1046 | 1073 | 1100 | 1127 | 1154 | 1180 | 1207 | 1234 | 1260 | 1286 | 1338 | 1364 |
| 9 | 1519 | 1204 | 1234 | 1265 | 1296 | 1326 | 1355 | 1384 | 1413 | 1443 | 1468 | 1494 | 1542 | 1565 |
| 9.5 | 1678 | 1392 | 1423 | 1455 | 1486 | 1518 | 1543 | 1569 | 1594 | 1619 | 1639 | 1658 | 1693 | 1709 |
| 10 | 1766 | 1562 | 1588 | 1613 | 1638 | 1664 | 1681 | 1698 | 1715 | 1732 | 1743 | 1754 | 1773 | 1780 |
| 10.5 | 1799 | 1687 | 1703 | 1720 | 1736 | 1753 | 1761 | 1770 | 1779 | 1788 | 1791 | 1795 | 1801 | 1803 |
| 11 | 1811 | 1764 | 1772 | 1779 | 1787 | 1794 | 1798 | 1801 | 1804 | 1807 | 1808 | 1810 | 1812 | 1813 |
| 11.5 | 1814 | 1796 | 1799 | 1802 | 1805 | 1809 | 1810 | 1811 | 1812 | 1813 | 1813 | 1814 | 1815 | 1815 |
| 12 | 1815 | 1809 | 1810 | 1811 | 1812 | 1813 | 1814 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 12.5 | 1815 | 1813 | 1814 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 13 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 13.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 14 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 14.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 16 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 16.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 18 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

| Mode 1, Power curves | | | | | | | | | | | | | | |
|----------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| | Air density kg/m ³ | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 18.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 20 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

Table 12-4: Mode 1, power curve.

12.2.2 Mode 1, C_t values

| Mode 1, C _t values | | | | | | | | | | | | | | |
|-------------------------------|-------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Air density kg/m ³ | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 |
| 3.5 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 | 0.890 |
| 4 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 | 0.863 |
| 4.5 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 | 0.809 |
| 5 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 | 0.764 |
| 5.5 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 | 0.741 |
| 6 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 | 0.733 |
| 6.5 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 | 0.766 |
| 7 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 | 0.755 |
| 7.5 | 0.750 | 0.749 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 | 0.750 |
| 8 | 0.748 | 0.749 | 0.749 | 0.749 | 0.749 | 0.749 | 0.749 | 0.749 | 0.749 | 0.749 | 0.748 | 0.748 | 0.748 | 0.747 |
| 8.5 | 0.735 | 0.745 | 0.744 | 0.744 | 0.743 | 0.742 | 0.741 | 0.741 | 0.740 | 0.739 | 0.738 | 0.737 | 0.734 | 0.733 |
| 9 | 0.699 | 0.729 | 0.727 | 0.726 | 0.724 | 0.722 | 0.720 | 0.717 | 0.715 | 0.712 | 0.708 | 0.703 | 0.694 | 0.689 |
| 9.5 | 0.631 | 0.699 | 0.695 | 0.691 | 0.687 | 0.683 | 0.676 | 0.669 | 0.663 | 0.656 | 0.648 | 0.639 | 0.622 | 0.613 |
| 10 | 0.544 | 0.652 | 0.643 | 0.634 | 0.626 | 0.617 | 0.607 | 0.597 | 0.586 | 0.576 | 0.565 | 0.555 | 0.533 | 0.522 |
| 10.5 | 0.458 | 0.585 | 0.574 | 0.562 | 0.551 | 0.539 | 0.527 | 0.516 | 0.504 | 0.492 | 0.481 | 0.470 | 0.448 | 0.438 |
| 11 | 0.388 | 0.514 | 0.501 | 0.488 | 0.475 | 0.462 | 0.451 | 0.440 | 0.428 | 0.417 | 0.408 | 0.398 | 0.380 | 0.371 |
| 11.5 | 0.333 | 0.442 | 0.430 | 0.418 | 0.406 | 0.395 | 0.385 | 0.376 | 0.366 | 0.356 | 0.349 | 0.341 | 0.325 | 0.318 |
| 12 | 0.288 | 0.381 | 0.370 | 0.360 | 0.350 | 0.340 | 0.332 | 0.324 | 0.316 | 0.308 | 0.301 | 0.294 | 0.282 | 0.276 |
| 12.5 | 0.251 | 0.331 | 0.322 | 0.313 | 0.305 | 0.296 | 0.289 | 0.282 | 0.275 | 0.269 | 0.263 | 0.257 | 0.246 | 0.241 |
| 13 | 0.222 | 0.289 | 0.282 | 0.275 | 0.267 | 0.260 | 0.254 | 0.248 | 0.242 | 0.236 | 0.231 | 0.227 | 0.217 | 0.213 |
| 13.5 | 0.197 | 0.256 | 0.249 | 0.243 | 0.237 | 0.230 | 0.225 | 0.220 | 0.215 | 0.210 | 0.206 | 0.201 | 0.193 | 0.189 |
| 14 | 0.176 | 0.227 | 0.222 | 0.216 | 0.211 | 0.205 | 0.201 | 0.196 | 0.192 | 0.187 | 0.184 | 0.180 | 0.173 | 0.169 |

| Mode 1, C_t values | | | | | | | | | | | | | | |
|----------------------|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Air density kg/m^3 | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 14.5 | 0.158 | 0.203 | 0.199 | 0.194 | 0.189 | 0.184 | 0.180 | 0.176 | 0.172 | 0.168 | 0.165 | 0.161 | 0.155 | 0.152 |
| 15 | 0.142 | 0.183 | 0.178 | 0.174 | 0.170 | 0.165 | 0.162 | 0.158 | 0.155 | 0.151 | 0.148 | 0.145 | 0.140 | 0.137 |
| 15.5 | 0.129 | 0.165 | 0.161 | 0.157 | 0.153 | 0.150 | 0.146 | 0.143 | 0.140 | 0.137 | 0.134 | 0.132 | 0.127 | 0.124 |
| 16 | 0.117 | 0.150 | 0.146 | 0.143 | 0.139 | 0.136 | 0.133 | 0.130 | 0.127 | 0.125 | 0.122 | 0.120 | 0.115 | 0.113 |
| 16.5 | 0.107 | 0.137 | 0.133 | 0.130 | 0.127 | 0.124 | 0.121 | 0.119 | 0.116 | 0.114 | 0.112 | 0.109 | 0.105 | 0.103 |
| 17 | 0.098 | 0.125 | 0.122 | 0.119 | 0.116 | 0.114 | 0.111 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.097 | 0.095 |
| 17.5 | 0.091 | 0.115 | 0.112 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.098 | 0.096 | 0.094 | 0.092 | 0.089 | 0.087 |
| 18 | 0.084 | 0.105 | 0.103 | 0.101 | 0.098 | 0.096 | 0.094 | 0.092 | 0.090 | 0.088 | 0.087 | 0.085 | 0.082 | 0.081 |
| 18.5 | 0.077 | 0.097 | 0.095 | 0.093 | 0.091 | 0.089 | 0.087 | 0.085 | 0.083 | 0.082 | 0.080 | 0.079 | 0.076 | 0.075 |
| 19 | 0.072 | 0.090 | 0.088 | 0.086 | 0.084 | 0.082 | 0.081 | 0.079 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.069 |
| 19.5 | 0.067 | 0.084 | 0.082 | 0.080 | 0.078 | 0.077 | 0.075 | 0.074 | 0.072 | 0.071 | 0.069 | 0.068 | 0.066 | 0.065 |
| 20 | 0.062 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.070 | 0.069 | 0.067 | 0.066 | 0.065 | 0.063 | 0.061 | 0.060 |

Table 12-5: Mode 1, C_t values.

12.2.3 Mode 1, Sound Power Levels

| Sound Power Level at Hub Height, Mode 1 | | |
|--|--|---------------|
| Conditions for Sound Power Level | Verification standard: IEC 61400-11 Ed. 2. Wind shear 0.15 Max turbulence at 10 meter height: 16% Inflow angle (vertical): $0 \pm 2^\circ$ Air density: 1.225 kg/m^3 | |
| Hub Height | 80 m | 95 m |
| LwA @ 3 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 93.7 4.2 | 93.7 4.3 |
| LwA @ 4 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 95.3 5.6 | 95.7 5.7 |
| LwA @ 5 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 99.1 7.0 | 99.7 7.2 |
| LwA @ 6 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 102.9 8.4 | 103.4 8.6 |
| LwA @ 7 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 9.8 | 105.0 10.0 |
| LwA @ 8 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 11.2 | 105.0 11.5 |
| LwA @ 9 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 12.6 | 105.0 12.9 |
| LwA @ 10 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 13.9 | 105.0 14.3 |
| LwA @ 11 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 15.3 | 105.0 15.8 |
| LwA @ 12 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 16.7 | 105.0 17.2 |
| LwA @ 13 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 105.0 18.1 | 105.0 18.6 |

Table 12-6: Sound power level at hub height: Mode 1.

12.3 Mode 2

12.3.1 Mode 2, Power Curves

| Mode 2, Power curves | | | | | | | | | | | | | | |
|----------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| Wind speed [m/s] | Air density kg/m ³ | | | | | | | | | | | | | |
| | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 13 | 9 | 9 | 9 | 10 | 10 | 11 | 11 | 11 | 12 | 12 | 13 | 14 | 15 |
| 3.5 | 53 | 34 | 36 | 38 | 39 | 41 | 43 | 45 | 46 | 48 | 50 | 52 | 55 | 57 |
| 4 | 112 | 80 | 83 | 86 | 89 | 92 | 95 | 98 | 101 | 104 | 106 | 109 | 115 | 118 |
| 4.5 | 181 | 136 | 140 | 144 | 148 | 152 | 156 | 160 | 165 | 169 | 173 | 177 | 185 | 189 |
| 5 | 260 | 198 | 203 | 209 | 215 | 220 | 226 | 231 | 237 | 243 | 248 | 254 | 265 | 271 |
| 5.5 | 353 | 270 | 278 | 285 | 293 | 300 | 308 | 315 | 323 | 330 | 338 | 345 | 360 | 367 |
| 6 | 462 | 355 | 365 | 375 | 384 | 394 | 404 | 413 | 423 | 433 | 442 | 452 | 471 | 481 |
| 6.5 | 581 | 443 | 455 | 468 | 480 | 493 | 506 | 518 | 531 | 543 | 556 | 568 | 594 | 606 |
| 7 | 735 | 563 | 579 | 594 | 610 | 626 | 642 | 657 | 673 | 688 | 704 | 720 | 751 | 766 |
| 7.5 | 908 | 697 | 717 | 736 | 755 | 774 | 793 | 812 | 831 | 851 | 870 | 889 | 926 | 945 |
| 8 | 1090 | 840 | 863 | 886 | 909 | 932 | 954 | 977 | 999 | 1022 | 1045 | 1067 | 1113 | 1135 |
| 8.5 | 1271 | 981 | 1008 | 1034 | 1061 | 1087 | 1113 | 1140 | 1166 | 1192 | 1218 | 1244 | 1297 | 1323 |
| 9 | 1437 | 1112 | 1142 | 1172 | 1201 | 1231 | 1261 | 1290 | 1320 | 1349 | 1379 | 1408 | 1465 | 1494 |
| 9.5 | 1580 | 1227 | 1260 | 1293 | 1325 | 1358 | 1390 | 1423 | 1455 | 1487 | 1518 | 1549 | 1607 | 1634 |
| 10 | 1689 | 1331 | 1367 | 1402 | 1437 | 1473 | 1506 | 1540 | 1573 | 1607 | 1634 | 1661 | 1709 | 1729 |
| 10.5 | 1757 | 1425 | 1462 | 1499 | 1536 | 1573 | 1604 | 1635 | 1666 | 1697 | 1717 | 1737 | 1768 | 1780 |
| 11 | 1792 | 1512 | 1549 | 1585 | 1622 | 1659 | 1683 | 1708 | 1732 | 1757 | 1768 | 1780 | 1797 | 1802 |
| 11.5 | 1805 | 1592 | 1624 | 1657 | 1690 | 1722 | 1738 | 1755 | 1771 | 1787 | 1793 | 1799 | 1808 | 1811 |
| 12 | 1811 | 1666 | 1691 | 1715 | 1740 | 1764 | 1774 | 1783 | 1792 | 1802 | 1805 | 1808 | 1812 | 1813 |
| 12.5 | 1813 | 1726 | 1742 | 1757 | 1773 | 1789 | 1794 | 1799 | 1804 | 1809 | 1810 | 1812 | 1814 | 1814 |
| 13 | 1814 | 1765 | 1774 | 1784 | 1793 | 1802 | 1805 | 1807 | 1810 | 1812 | 1813 | 1814 | 1815 | 1815 |
| 13.5 | 1815 | 1786 | 1791 | 1797 | 1803 | 1808 | 1810 | 1811 | 1813 | 1814 | 1815 | 1815 | 1815 | 1815 |
| 14 | 1815 | 1802 | 1805 | 1808 | 1811 | 1813 | 1814 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 14.5 | 1815 | 1812 | 1812 | 1813 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15 | 1815 | 1813 | 1813 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 15.5 | 1815 | 1814 | 1814 | 1814 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 16 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 16.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 17.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 18 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

| Mode 2, Power curves | | | | | | | | | | | | | | |
|----------------------|-------------------------------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|-------|
| | Air density kg/m ³ | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 18.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 19.5 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |
| 20 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 | 1815 |

Table 12-7: Mode 2, power curve.

12.3.2 Mode 2, C_t values

| Mode 2, C _t values | | | | | | | | | | | | | | |
|-------------------------------|-------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Air density kg/m ³ | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 3 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 | 0.874 |
| 3.5 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 | 0.891 |
| 4 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 | 0.877 |
| 4.5 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.846 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 | 0.847 |
| 5 | 0.818 | 0.818 | 0.818 | 0.818 | 0.818 | 0.817 | 0.818 | 0.818 | 0.818 | 0.818 | 0.818 | 0.818 | 0.818 | 0.818 |
| 5.5 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 | 0.801 |
| 6 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 | 0.796 |
| 6.5 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 | 0.811 |
| 7 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 | 0.800 |
| 7.5 | 0.783 | 0.783 | 0.783 | 0.783 | 0.783 | 0.782 | 0.783 | 0.783 | 0.783 | 0.783 | 0.783 | 0.783 | 0.783 | 0.783 |
| 8 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 | 0.747 |
| 8.5 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 | 0.695 |
| 9 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 | 0.634 |
| 9.5 | 0.569 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.570 | 0.569 | 0.567 | 0.565 |
| 10 | 0.505 | 0.513 | 0.513 | 0.513 | 0.513 | 0.513 | 0.513 | 0.513 | 0.512 | 0.512 | 0.509 | 0.507 | 0.500 | 0.496 |
| 10.5 | 0.441 | 0.462 | 0.462 | 0.462 | 0.462 | 0.462 | 0.460 | 0.458 | 0.456 | 0.454 | 0.450 | 0.445 | 0.435 | 0.428 |
| 11 | 0.381 | 0.417 | 0.416 | 0.415 | 0.415 | 0.414 | 0.410 | 0.407 | 0.403 | 0.400 | 0.394 | 0.388 | 0.375 | 0.368 |
| 11.5 | 0.330 | 0.377 | 0.375 | 0.373 | 0.371 | 0.369 | 0.364 | 0.359 | 0.354 | 0.349 | 0.342 | 0.336 | 0.323 | 0.317 |
| 12 | 0.287 | 0.342 | 0.339 | 0.335 | 0.331 | 0.328 | 0.322 | 0.316 | 0.311 | 0.305 | 0.299 | 0.293 | 0.281 | 0.275 |
| 12.5 | 0.251 | 0.310 | 0.305 | 0.300 | 0.295 | 0.290 | 0.285 | 0.279 | 0.273 | 0.267 | 0.262 | 0.257 | 0.246 | 0.241 |
| 13 | 0.222 | 0.279 | 0.274 | 0.268 | 0.263 | 0.258 | 0.252 | 0.247 | 0.241 | 0.236 | 0.231 | 0.226 | 0.217 | 0.213 |
| 13.5 | 0.197 | 0.250 | 0.245 | 0.240 | 0.235 | 0.229 | 0.224 | 0.220 | 0.215 | 0.210 | 0.206 | 0.201 | 0.193 | 0.189 |
| 14 | 0.176 | 0.225 | 0.220 | 0.215 | 0.210 | 0.205 | 0.201 | 0.196 | 0.192 | 0.187 | 0.184 | 0.180 | 0.173 | 0.169 |

| Mode 2, C_t values | | | | | | | | | | | | | | |
|----------------------|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | Air density kg/m^3 | | | | | | | | | | | | | |
| Wind speed [m/s] | 1.225 | 0.95 | 0.975 | 1 | 1.025 | 1.05 | 1.075 | 1.1 | 1.125 | 1.15 | 1.175 | 1.2 | 1.25 | 1.275 |
| 14.5 | 0.158 | 0.203 | 0.198 | 0.193 | 0.189 | 0.184 | 0.180 | 0.176 | 0.172 | 0.168 | 0.165 | 0.161 | 0.155 | 0.152 |
| 15 | 0.142 | 0.182 | 0.178 | 0.174 | 0.169 | 0.165 | 0.162 | 0.158 | 0.155 | 0.151 | 0.148 | 0.145 | 0.140 | 0.137 |
| 15.5 | 0.129 | 0.165 | 0.161 | 0.157 | 0.153 | 0.150 | 0.146 | 0.143 | 0.140 | 0.137 | 0.134 | 0.132 | 0.127 | 0.124 |
| 16 | 0.117 | 0.150 | 0.146 | 0.143 | 0.139 | 0.136 | 0.133 | 0.130 | 0.127 | 0.125 | 0.122 | 0.120 | 0.115 | 0.113 |
| 16.5 | 0.107 | 0.137 | 0.133 | 0.130 | 0.127 | 0.124 | 0.121 | 0.119 | 0.116 | 0.114 | 0.112 | 0.109 | 0.105 | 0.103 |
| 17 | 0.098 | 0.125 | 0.122 | 0.119 | 0.116 | 0.114 | 0.111 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.097 | 0.095 |
| 17.5 | 0.091 | 0.115 | 0.112 | 0.109 | 0.107 | 0.104 | 0.102 | 0.100 | 0.098 | 0.096 | 0.094 | 0.092 | 0.089 | 0.087 |
| 18 | 0.084 | 0.105 | 0.103 | 0.101 | 0.098 | 0.096 | 0.094 | 0.092 | 0.090 | 0.088 | 0.087 | 0.085 | 0.082 | 0.081 |
| 18.5 | 0.077 | 0.097 | 0.095 | 0.093 | 0.091 | 0.089 | 0.087 | 0.085 | 0.083 | 0.082 | 0.080 | 0.079 | 0.076 | 0.075 |
| 19 | 0.072 | 0.090 | 0.088 | 0.086 | 0.084 | 0.082 | 0.081 | 0.079 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.069 |
| 19.5 | 0.067 | 0.084 | 0.082 | 0.080 | 0.078 | 0.077 | 0.075 | 0.074 | 0.072 | 0.071 | 0.069 | 0.068 | 0.066 | 0.065 |
| 20 | 0.062 | 0.078 | 0.076 | 0.075 | 0.073 | 0.071 | 0.070 | 0.069 | 0.067 | 0.066 | 0.065 | 0.063 | 0.061 | 0.060 |

Table 12-8: Mode 2, C_t values.

12.3.3 Mode 2, Sound Power Levels

| Sound Power Level at Hub Height, Mode 2 | | |
|--|--|---------------|
| Conditions for Sound Power Level | Verification standard: IEC 61400-11 Ed. 2. Wind shear 0.15 Max turbulence at 10 meter height: 16% Inflow angle (vertical): $0 \pm 2^\circ$ Air density: 1.225 kg/m^3 | |
| Hub Height | 80 m | 95 m |
| LwA @ 3 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 93.8 4.2 | 93.8 4.3 |
| LwA @ 4 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 96.0 5.6 | 96.4 5.7 |
| LwA @ 5 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 100.1 7.0 | 100.7 7.2 |
| LwA @ 6 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 8.4 | 103.0 8.6 |
| LwA @ 7 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 9.8 | 103.0 10.0 |
| LwA @ 8 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 11.2 | 103.0 11.5 |
| LwA @ 9 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 12.6 | 103.0 12.9 |
| LwA @ 10 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 13.9 | 103.0 14.3 |
| LwA @ 11 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 15.3 | 103.0 15.8 |
| LwA @ 12 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 16.7 | 103.0 17.2 |
| LwA @ 13 m/s (10 m above ground) [dBA] Wind speed at hh [m/sec] | 103.0 18.1 | 103.0 18.6 |

Table 12-9: Sound power level at hub height: Mode 2.

**APPENDIX D:
VESTAS V100-1.8 MW SOUND POWER DATA**

CONFIDENTIAL – These materials have been supplied to the Ontario
Ministry of the Environment.

Sound Power Level Data for the V100-1.8MW

These values are valid for the following conditions

| | |
|------------------------------|--|
| WTG Type | V100-1.8 MW |
| Max Rated Power | 1.8 MW |
| Hub Height [m] | 95 m |
| Shear factor | 0.16 |
| Max turbulence at 10m height | 0.16 |
| Inflow angle | 0 +/-2 deg |
| Air Density | 1.225 kg/m3 |
| Measurement Standard: | ICE 61400-11:2002, using amendments procedure above 95% RP |

| Wind Speed@10m [m/s] | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 |
|----------------------|-----|-----|-----|------|------|------|------|------|-----|-----|-----|-----|
| 16Hz [dB(A)] | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN |
| 31.5Hz [dB(A)] | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN | NaN |
| 63Hz [dB(A)] | NaN | NaN | NaN | 85.2 | 87.4 | 87.1 | 86.7 | 86.6 | NaN | NaN | NaN | NaN |
| 125Hz [dB(A)] | NaN | NaN | NaN | 89.6 | 92 | 91.7 | 91.3 | 91.4 | NaN | NaN | NaN | NaN |
| 250Hz [dB(A)] | NaN | NaN | NaN | 93 | 94.7 | 94.2 | 93.6 | 93.5 | NaN | NaN | NaN | NaN |
| 500Hz [dB(A)] | NaN | NaN | NaN | 95.4 | 97.1 | 96.7 | 96.1 | 96.1 | NaN | NaN | NaN | NaN |
| 1000Hz [dB(A)] | NaN | NaN | NaN | 98.2 | 99.7 | 99.5 | 99 | 99.1 | NaN | NaN | NaN | NaN |
| 2000Hz [dB(A)] | NaN | NaN | NaN | 96.6 | 98.2 | 98.4 | 98.2 | 98.2 | NaN | NaN | NaN | NaN |
| 4000Hz [dB(A)] | NaN | NaN | NaN | 94.6 | 96.6 | 97.2 | 98.7 | 98.6 | NaN | NaN | NaN | NaN |
| 8000Hz [dB(A)] | NaN | NaN | NaN | 85.4 | 89.8 | 90.3 | 91.4 | 92.3 | NaN | NaN | NaN | NaN |

| | | | | | | | | | | | | |
|-----------------------|-----|-----|-----|-------|-----|-----|-----|-----|-----|-----|-----|---|
| Spectra Value [dB(A)] | NaN | NaN | NaN | 103.3 | 105 | 105 | 105 | 105 | NaN | NaN | NaN | 0 |
|-----------------------|-----|-----|-----|-------|-----|-----|-----|-----|-----|-----|-----|---|

Notes:

1. NAN indicates data not available due to insufficient data collection at this wind speed.
2. Disclaimer:
The values are valid for the A-weighted sound power levels
Octave band values must be regarded as informative
Site specific values are not warranted
3. Measurement standard - ICE 61400-11:2002, using amendments procedure above 95% RP

Vestas

WIND. IT MEANS THE WORLD TO US. | vestas.com

Confidential



IPC Energy
December 01, 2010

Attention: Sunny Galia / John Andrews / Terry Hawrysh

IPC Energy
2550 Argentia Rd. Suite 105
Mississauga, ON, Canada
L5N 5R1

Reference: Warranted Sound Power Level and Tonality for the Vestas V100-1.8MW for the Vineland Power Inc. and Wainfleet Wind Energy Inc. Projects.

Dear Sunny/John/Terry,

Vestas is pleased to provide the following clarification regarding the sound characteristics of the V100-1.8MW wind turbine. The V100-1.8 wind turbine will be used by Vineland Power Inc and Wainfleet Wind Energy Inc. located respectively in Vineland ON, and Wainfleet ON, Canada to power their projects and supply power to the OPA. This letter provides clarification of the V100-1.8 sound characteristics and is not intended as a warranty, the above projects will be covered by warranties provided to the above contracts as part of the Ontario FIT award and as such constitute a special offer to only these FIT contracts.

Warranted Sound Power Level and Tonality V100 – 1.8MW WTG IEC Class IIIA

Sound Power Level:

When measured in accordance with the Sound Level Testing Procedures attached as Exhibit N.2 to the Wind Turbine Supply Agreement to which this Exhibit N.1 is attached, the V100 1.8MW WTG IEC Class IIIA warranted sound power level at 8m/s (10m height) is

$$L_{wa} = 105.0 \text{ dB(A)}.$$

This warranted sound level is subject to a tolerance for measurement uncertainties of the greater of (i) the actual measurement uncertainty determined in accordance with the Sound Level Test Standard and (ii) $\pm 2\text{dB(A)}$. If the measured sound power level is at or below the warranted sound power level plus the uncertainty, the standard has been met.

Confidential



IPC Energy
December 01, 2010

Tonality:

The supplier will warrant the tonality of the sound generated by the Wind Turbines as measured by the Sound Level Testing Procedures attached as Exhibit N.2 (IEC 61400-11-ed2:2002 standard), such that the tonal audibilities, $\Delta L_{a,k}$ are not greater than two (2) DBa.

The above commitments will be captured in the contracts for IPC Energy Wainfleet and Vineland that are in the process of being finalized.

Thank you for the opportunity to clarify our position with respect to the V100 sound characteristics. Vestas prides itself on its excellent working relationships with owners of wind turbines worldwide. Our goal is to provide you with the highest levels of customer service in order to support you in creating a successful project. If you have any questions, please do not hesitate to contact me at your convenience.

Sincerely,

Timothy Koivu

Timothy Koivu (MEng)
Senior Contract and Business Development Manager
Vestas-American Wind Technology, Inc.
65 Queen Street, Suite 2000, Box 56
Toronto, Ontario, Canada
Direct: 416-254-6238

Exhibit N

Sound Level Performance Standard

Warranted Sound Power Level V100 – 1.8MW WTG IEC Class III

When measured in accordance with the Sound Level Testing Procedures attached as Exhibit O to the Wind Turbine Supply Agreement to which this Exhibit N is attached, the V100 – 1.8MW WTG IEC Class S warranted sound power level at 8m/s (10m height) is

$$L_{wa} = 105.0 \text{ dB(A)}.$$

This warranted sound level is subject to a tolerance for measurement uncertainties of the greater of (i) the actual measurement uncertainty determined in accordance with the Sound Level Test Standard and (ii) $\pm 2\text{dB(A)}$. If the measured sound power level is at or below the warranted sound power level plus the uncertainty, the standard has been met.

Supplier also warrants that the sound generated by any Wind Turbine shall not contain any tone greater than +2dB when measured in accordance with the Sound Level Test Standard.



Acoustic Noise Test Report for a Vestas V100 1.8 MW Turbine at Pueblo, Colorado

CONFIDENTIAL

Vestas American Wind Technology, Inc.

1881 SW Naito Parkway #100
Portland, OR 97201



TESTING CERT #2564.01

DNV Report No.: ANRP0105
May 12, 2011



| | | | |
|---|--|---|----------|
| Acoustic Noise Test Report for a Vestas V100 1.8 MW Turbine at Pueblo, Colorado | | DNV Renewables (USA) Inc. 1809 7th Avenue, Suite 900 Seattle, WA 98101 USA Tel: 1-206-387-4200 Fax: 1-206-387-4201 http://www.dnv.com/windenergy | |
| For: Vestas – American Wind Technology, Inc. 1881 SW Naito Parkway #100 Portland, OR 97201 | | | |
| Customer Name: Galvin Clancy | | | |
| Date of First Issue: | May 11, 2011 | Project No.: | PP003349 |
| Report No.: | ANRP0105 | Organization Unit: | ACGUS364 |
| Version: | B | | |
| Summary: | | | |
| This report presents the methods, assumptions, and results of acoustic noise testing conducted by DNV on one V100 1.8 MW wind turbine at the Pueblo, Colorado Vestas manufacturing plant grounds. | | | |
| Prepared by: | Sarah Taubitz, Test Engineer | Signature | |
| Verified by: | Collin Sad, Test Engineer | Signature | |
| Approved by: | Luke Simmons, Group Leader, Performance and Acoustic Testing | Signature | |

| | | | |
|-------------------------------------|--|----------------|----------------|
| <input type="checkbox"/> | No distribution without permission from the Customer or responsible organizational unit (however, free distribution for internal use within DNV after 3 years) | Indexing Terms | |
| <input checked="" type="checkbox"/> | No distribution without permission from the Customer or responsible organizational unit | Key Words | |
| <input type="checkbox"/> | Strictly confidential | Service Area | Cleaner Energy |
| <input type="checkbox"/> | Unrestricted distribution | Market Segment | Wind Energy |

© 2010 DNV Renewables (USA) Inc. All rights reserved. This publication or parts thereof may not be reproduced or transmitted in any form or by any means, including photocopying or recording, without the prior written consent of DNV Renewables (USA) Inc.



Table of Contents

| | |
|--|-----------|
| 1 Introduction..... | 1 |
| 1.1 Scope | 1 |
| 1.2 Background | 1 |
| 1.3 Turbine Description..... | 1 |
| 1.4 Site Description | 2 |
| 1.5 Site Conditions | 5 |
| 2 Technical Approach..... | 6 |
| 2.1 Test Instrumentation..... | 6 |
| 2.2 Data Reduction Methodology | 8 |
| 2.2.1 Data Selection | 9 |
| 2.2.2 Wind Speed Correction..... | 9 |
| 2.2.3 A-Weighted Sound Power Level | 10 |
| 2.2.4 A-Weighted One-Third Octave Band Levels | 11 |
| 2.2.5 Tonality Analysis | 11 |
| 2.2.6 A-Weighted Apparent Sound Power Level | 12 |
| 2.2.7 One-Third Octave Spectra | 13 |
| 2.2.8 Tonality | 13 |
| 3 Exceptions to the IEC Standard | 14 |
| 4 Results | 15 |
| 4.1 Collected Data | 15 |
| 4.2 Results | 16 |
| 4.2.1 Overall Sound Pressure and Power Levels | 16 |
| 4.2.2 A-Weighted One-Third Octave Analysis..... | 19 |
| 4.2.3 Tonality | 21 |
| 5 References..... | 28 |
| APPENDIX A – POWER CURVE USED FOR WIND SPEED CALCULATION | |
| APPENDIX B – SITE PHOTOS | |
| APPENDIX C – INSTRUMENTATION CALIBRATIONS | |
| APPENDIX D – OTHER TURBINE INFORMATION PROVIDED BY VESTAS | |
| APPENDIX E – RESULTS GRAPHS | |



List of Figures

| | |
|--|----|
| Figure 1-1. Test Site Topography and Measurement Locations (zoomed image below) | 4 |
| Figure 2-1. Met Tower Top Instrumentation drawing | 7 |
| Figure 4-1. Valid Collected Data | 15 |
| Figure 4-2. A-Weighted, Valid Measured Sound Pressure Levels versus Standardized Wind Speed, Operating and Background | 17 |
| Figure 4-3. A-Weighted Sound Pressure Levels, Turbine Operating and Background Measurements versus Density-Corrected Measured Wind Speed at 80-m Height | 18 |
| Figure 4-4. A-Weighted Sound Pressure Levels, Turbine Operating Versus Measured Electrical Power | 18 |

List of Tables

| | |
|---|----|
| Table 1-1. Turbine Description | 2 |
| Table 1-2. Turbine and Turbine Component Identification (per Vestas) | 2 |
| Table 1-3. Meteorological Conditions during the Test Period of 01:52 to 06:12 | 5 |
| Table 2-1. Test Instrumentation and Calibration | 8 |
| Table 2-2. Recorded Data | 9 |
| Table 2-3. Variables for Standardizing Wind Speed | 10 |
| Table 2-4. Category B Uncertainty Components | 13 |
| Table 4-1. Summary of Collected Data | 15 |
| Table 4-2. A-Weighted Sound Pressure and Power Level (L_{WA}) Summary, 4 – 10 m/s | 17 |
| Table 4-3. A-Weighted One-Third Octave Sound Pressure Levels for $V_S = 4 - 10$ m/s | 20 |
| Table 4-4. Uncertainties (\pm dB) for One-Third Octave Results for $V_S = 4 - 7$ m/s | 21 |
| Table 4-5. Tonality Analysis Summary | 22 |
| Table 4-6. Tonality and Tonal Audibility Results, $V_S = 4$ m/s | 23 |
| Table 4-7. Tonality and Tonal Audibility Results, $V_S = 5$ m/s | 24 |
| Table 4-8. Tonality and Tonal Audibility Results, $V_S = 6$ m/s | 25 |
| Table 4-9. Tonality and Tonal Audibility Results, $V_S = 7$ m/s | 25 |
| Table 4-10. Tonality and Tonal Audibility Results, $V_S = 8$ m/s | 26 |
| Table 4-11. Tonality and Tonal Audibility Results, $V_S = 9$ m/s | 26 |
| Table 4-12. Tonality and Tonal Audibility Results, $V_S = 10$ m/s | 27 |



1 INTRODUCTION

1.1 Scope

This report presents the results of an acoustic noise test conducted on one Vestas V100 1.8 MW wind turbine located at Vestas' tower manufacturing facility in Pueblo, Colorado (the Project). The test turbine is a prototype turbine, designated number WTG1, and is the only turbine currently built on the plant property. The test was conducted in accordance with the Test Plan [1] to document acoustic noise emissions from the test turbine in accordance with the IEC acoustic noise measurement standard (the IEC Standard) [2]. The test was conducted during the early hours of February 20, 2011. This report describes the methodology, equipment, assumptions, and the results of the acoustic noise test. This test does not meet all the requirements of the IEC Standard; exceptions are given in Section 3.

A Power Performance Test will be conducted by DNV on the same test turbine. Newly installed met tower instrumentation, planned for use on the Power Performance Test, was therefore utilized for this Acoustic Noise Test.

This test was conducted and the report was prepared by DNV's Seattle-based Technology Group, an organization that is accredited by the American Association for Laboratory Accreditation (A2LA) to perform acoustic noise testing of wind turbines (Certificate number 2564.01).

The results given in this report relate only to this particular wind turbine; the same turbine type installed at a different site or operating with a different control scheme may provide different results.

1.2 Background

The power curve used in this report is the theoretical curve provided in the turbine's General Specification, supplied by Vestas [3]. Using a measured power curve is preferable to a theoretical one; however since the turbine is a prototype no measured power curve yet exists. Additional uncertainty was assigned to the sound power levels and third octave sound pressure levels reported herein.

1.3 Turbine Description

The V100 wind turbine is an upwind, 3-bladed, active yaw turbine incorporating full-span pitch control and constant-speed operation. Table 1-1 lists general details of the test turbine as noted in the General Specification [3]. Table 1-2 lists the serial numbers of the turbine and significant components.

**Table 1-1. Turbine Description**

| Item | Value |
|---|----------------------------------|
| IEC Class | S |
| Grid Frequency | 60 Hz |
| Special Features | - |
| Rated Power | 1815 kW |
| Rotor Diameter | 100 m |
| Rotor Speed | 9.3 – 16.6 RPM, 14.5 RPM nominal |
| Generator Speed | 1345 RPM |
| Gearbox Ratio | 1:92.8 nominal |
| Power Regulation | Pitch Regulated, Variable Speed |
| Shaft Tilt | 6° |
| Hub Height | 80 m |
| Distance from Rotor Center to Tower Center Line | 4480 mm (per Appendix D) |
| Tower Type | Tubular steel |
| Cut-in Wind Speed | 3 m/s |
| Rated Wind Speed | 12 m/s |
| Cut-out Wind Speed | 20 m/s |
| Generator Voltage | 6 pole, 690 Vac |
| Power Factor (cos) | 1.0 |

Table 1-2. Turbine and Turbine Component Identification (per Vestas)

| Item | Manufacturer/Model | Serial Number |
|-----------------------------|----------------------------|--|
| Turbine | Vestas V100-1.8MW VCUS Mk7 | 38733 |
| Blades | Vestas 49M | 781302WHD90177 781302WHD90179 781302WHD90187 |
| Gearbox | Bosch Rexroth GPV 442 | 72802018635 |
| Generator | Vestas/Weier DVSG 560/6M | 620451 |
| Controller Software Version | VMPPGlobal v. 10.05.03 | N/A |

1.4 Site Description

The test turbine is located on arid, bare land approximately 12 km south of Pueblo, Colorado, at an elevation of approximately 1490 m. The latitude and longitude coordinates for the turbine under measurement are 38.16341° N by 104.62135° W. Figure 1-1 shows the site layout and topography of the Project and surrounding areas. The BNSF and UPNW railway is located approximately 0.5 km east of the turbine; Interstate-25 is located approximately 1.5 km northwest of the turbine. The access road to the plant is approximately 130 m from the turbine at its nearest point. Traffic on this access road, Vestas plant noise, along with the railway and



highway noise, necessitate data collection on the weekend and preferably at nighttime; even so, trains and highway traffic noise invalidated a significant amount of data during the test period. The terrain within the Project is very flat with little to no vegetation. As can be seen on Figure 1-1, the microphone is located in the IEC Standard reference downwind position of $R_0 = 133.9$ m (where the IEC Standard specifies $130 \text{ m} \pm 20\%$), the permanent meteorological (met) tower was located alongside the turbine, approximately 250 m to the southeast.

The site bearings were measured using a Garmin Nuvi GPS (accuracy $\pm 1.5^\circ$) validated with a compass at several locations around the turbine, and distances were measured with a TruPulse 200 rangefinder (accuracy ± 0.3 m).




Figure 1-1. Test Site Topography and Measurement Locations (zoomed image below)



1.5 Site Conditions

The Project test site had a clear sky and no precipitation during the nighttime test period; the ranges of environmental conditions are displayed in Table 1-3, with a clear sky and no precipitation. The minimum and maximum values are taken from the 1-minute averaged 1 Hz data. There was no precipitation in the data set used for analysis.

Table 1-3. Meteorological Conditions during the Test Period of 01:52 to 06:12

| Variable | Average | Minimum | Maximum |
|---------------------------------------|---------|---------|---------|
| 80 m Height Measured Wind Speed (m/s) | 11.5 | 4.8 | 21.7 |
| Air Pressure (hPa) | 826.8 | 825.8 | 828.0 |
| Air Temperature (°C) | 9.4 | 8.0 | 11.0 |
| Air Density (kg/m ³)* | 1.020 | 1.014 | 1.025 |
| Relative Humidity (%) | 44.0 | 43.4 | 44.4 |

* Calculated from temperature and pressure according to the IEC Standard [1].



2 TECHNICAL APPROACH

2.1 Test Instrumentation

The IEC Standard requires that wind speed is determined for noise measurements when the turbine is operating by measuring the electrical output and determining wind speed, using a representative power curve, or from direct measurement with an anemometer. The former technique is mandatory for certification purposes, and was used for this test.

The 80 m permanent met tower was used for all meteorological data. For background noise measurements, measuring wind speed with an anemometer is required. For the wind direction encountered during this noise test, the 10 m temporary met mast could not be placed in an IEC-compliant location, due to a tall chain-link fence. Instead, DNV measured wind speeds using the primary anemometer mounted on the permanent 80 m height met tower, located 2.5 rotor diameters (250 m) southeast (108° with respect to true north) of the test turbine. DNV also measured temperature and barometric pressure using DNV-installed instrumentation on the met tower. Figure 2-1 shows the permanent met tower configuration at the site. In Appendix B, Figures B-1 and B-4 display the met tower and anemometers. The met tower instrumentation has been installed in anticipation of a power performance test.

DNV obtained the turbine power signal from IEC-compliant measurement equipment recently installed in the turbine by DNV for the power performance test.

All data were sampled at 1 Hz for the duration of this test, and later averaged in 1-minute periods.

The microphone was located at a distance of 133.9 m from the turbine tower center, and 47° true relative to the turbine (for a downwind location of 227°), and was mounted on a round 1 m diameter acoustically hard sound board made from 3/4-inch-thick plywood. In Appendix B, Figure B-2 shows the microphone and board relative to the turbine. The microphone power supply and measurement system were located near the microphone on the ground, in mild weather.

It has become industry accepted to utilize the yaw position of the turbine as the wind direction indicator, since the correlation to noise is better than with a wind direction transducer. Using a compass, DNV verified on site that the yaw position of the turbine was set to zero degrees at true North. There was no specified yaw position offset in the turbine controller. DNV utilized a GPS unit to verify compass readings at several locations around the turbine, and all were found to be in compliance within the IEC Standard's requirements.

Table 2-1 summarizes the instrumentation utilized, along with the calibration information. The instrument calibration sheets are attached as Appendix C.




Figure 2-1. Met Tower Top Instrumentation Drawing

**Table 2-1. Test Instrumentation and Calibration**

| Item | Manufacturer and Model | Serial Number | Calibration By, Date |
|---|--------------------------------------|---------------|--|
| Integrated Sound Level Meter, which includes Laptop, Data Acquisition Board, Cabling, Realtime Analyzer and Playback/Recorder, Microphone with Preamplifier | See below | 1546B35 | Scantek, January 21, 2011 |
| Data Acquisition System | National Instruments NI-9233 | 1546B35 | See Integrated Sound Level Meter line item |
| Real Time Analyzer, Playback/Recorder | Delta NoiseLab 3.0 | N/A | See Integrated Sound Level Meter line item |
| Microphone and Preamplifier | PCB 378B02 | 105577 | Scantek, January 2, 2011 |
| Laptop | D830 | F1PT3H1 | N/A |
| Windscreen | Open cell foam, Brüel & Kjær UA-0237 | N/A | N/A |
| Sound Board | 3/4"-thick particle board, N/A | N/A | N/A |
| Acoustic Calibrator | PCB Larson Davis CAL200 | 8053 | Scantek, January 21, 2011 |
| Wind Speed | Windsensor P2546A | 10573 | Svend Ole Hansen, December 5, 2010 |
| Wind Direction | Turbine Yaw Position | N/A | N/A |
| Barometric Pressure | Met One 090D | K14990 | February 14, 2011 |
| Air Temperature | Met One 083E-1-35 | K20290 | February 14, 2011 |
| Power Transducers | N/A | N/A | Logged and provided by Vestas |
| Data Logger | Campbell Scientific CR1000 | 38384 | SIMCO, January 17, 2011 |

2.2 Data Reduction Methodology

The following subsections describe DNV's general method for collecting and processing the test data.

Test data were collected between 01:52 and 06:12 on February 20, 2011. The integrated sound level meter measured and recorded sound pressure levels, sampled at 50 kHz. DNV collected meteorological and turbine signals using Campbell Scientific loggers at a sampling rate of 1 Hz, and were subsequently averaged in 1-minute periods. One-minute averages of overall sound pressure levels were processed in Delta NoiseLab after data collection was complete. One-minute energy averaged one-third octave spectra, from 0 to 20,000 Hz, were also generated in post processing. Data available in the files included the fields described in Table 2-2. After measured wind speed and wind speed derived from turbine power were converted to standardized wind speed (at standard roughness length of 0.05 m and 10 m height, " V_s ") for all the data, 1-minute records could be selected for tonality analysis at integer standardized wind speed (V_s) for the test period, after the field measurement was completed.

**Table 2-2. Recorded Data**

| Signal | Logged Measurement | Unit |
|----------------------|---|----------------------------------|
| Date and Time | Time at end of sample period | Julian day 24 hour clock |
| Wind Speed | Average | m/s |
| Yaw Position | Average | Degrees relative to wind turbine |
| Air Temperature | Average | °C |
| Barometric Pressure | Average | hPa |
| Turbine Output Power | Average | kW |
| Sound Pressure Level | Scaled signal representing time series sound pressure | dB |

2.2.1 Data Selection

Data corresponding to the following circumstances were removed from the valid data set:

1. Wind direction was outside the valid measurement sector of 212° to 242° relative to true north.
2. Interrupting noise sources such as a passing vehicle, train, or airplane that showed influence on the acoustic measurement.

The IEC Standard requires that a minimum of three one-minute averaged records be collected for each integer wind speed of V_S from 6 to 10 m/s; this requirement was not met for background noise during this test period; only a single one-minute record was collected at 8 m/s and none were collected at 9 or 10 m/s. As an alternative, the one-minute record at 8 m/s and the highest wind speed in the 7 m/s bin were utilized to background correct the one-third octave data and narrowband spectra used for tonality analysis. This is noted as a deviation in Section 3. Although this deviates from the IEC Standard, DNV believes that carrying out background correction in this manner on the data in these bins still provides useful information on the turbine's noise characteristics at these wind speeds; it can be expected that the one-third octave and tonality results at 8 through 10 m/s are somewhat more conservative, since background noise levels increase with increasing wind speed.

2.2.2 Wind Speed Correction

Consistent with the IEC Standard, for turbine operating acoustic measurements, DNV calculated the V_S at standard sea-level reference conditions, 10 m height, and 0.05 m roughness length using the 1-minute average measured electrical power and a measured sea-level density power curve. V_S is corrected for the reference conditions using Equation 1. Table 2-3 defines the variables for Equation 1. The power curve used to determine V_S is included as Appendix A. This curve is the sea-level-adjusted measured power curve published in the General Specification [3].



$$V_s = V_z \left[\frac{\ln \frac{z_{ref}}{z_o} \ln \frac{H}{z}}{\ln \frac{H}{z_{ref}} \ln \frac{z}{z_o}} \right]$$

Equation 1

Table 2-3. Variables for Standardizing Wind Speed

| Parameter | Description | Value | Unit |
|-----------|--|-------|------|
| V_s | Standardized wind speed | N/A | m/s |
| V_z | Wind speed measured at anemometer height z | N/A | m/s |
| z_{ref} | Reference roughness length | 0.05 | m |
| z_o | Roughness length | 0.05 | m |
| H | Rotor center height | 80 | m |
| z_{ref} | Reference height | 10 | m |
| z | Anemometer height (turbine rotor) | 80 | m |

DNV derived the linear relationship between wind speed derived from power and wind speed measured by the nacelle anemometer for power between 5% and 95% of rated power; the nacelle anemometer method is preferred over the kappa method by the IEC Standard. For background noise measurements, turbine power is unavailable for determining V_s ; so for background noise wind speeds the kappa method was utilized, which provided a better correlation than the logarithmic Equation 5 from the IEC Standard. For noise measurements when the turbine power is greater than 95% of rated power, calculating wind speed from power output is not accurate; this linear relationship between wind speed derived from power and nacelle anemometer wind speeds, shown in Figure E-1 of Appendix E, was then utilized for these periods to determine V_s .

2.2.3 A-Weighted Sound Power Level

DNV plotted the measured A-weighted sound pressure levels against wind speed data, and utilized the fourth-order polynomials to determine the average sound pressure level, L_{Aeq} , for both total and background noise at each integer wind speed V_s (6, 7, 8, 9, and 10 m/s) per the IEC Standard. DNV utilized background noise data at wind speeds up to 13 m/s, since there were insufficient data between 8 and 10 m/s, and the Pearson regression coefficients (R-squared) for the fourth-order fit had a very high correlation that still provides a high degree of confidence in the resulting “predicted” background noise levels for each V_s . Noncompliance with the minimum data collection requirements and use of background noise data at wind speeds higher than 10 m/s are both exceptions to the IEC Standard and are listed in Section 3. This analysis yields the background noise level at each integer V_s , which is used to correct the turbine operating data for background noise at all integer wind speeds 6 to 10 m/s.

As an alternative method of mitigating the risk of the lack of background data for 8 though 10 m/s, the background noise value found using the fourth-order regression analysis at 7 m/s was



utilized to correct the total noise levels determined by regression analysis to determine sound power levels; these are also included in the results in Table 4-2.

2.2.4 A-Weighted One-Third Octave Band Levels

The one-third octave band sound pressure levels of the noise signal at the microphones were obtained using spectrum analysis software Delta Noiselab, concurrent with the one-minute sound pressure level calculations. As in the L_{Aeq} analysis, the turbine operating data were background corrected; where insufficient background noise data were collected (at 8 through 10 m/s), DNV utilized background noise at 7 and 8 m/s to provide a background correction, as described in Section 2.2.1.

2.2.5 Tonality Analysis

To analyze the tonality of the turbine, valid noise data were selected at the wind speeds closest to each integer V_s , per the IEC Standard. DNV performed the tonality analysis at wind speeds between 4 and 10 m/s. Sufficient operating data were available for all wind speeds between 4 and 10 m/s. Insufficient background noise data were unavailable between 8 and 10 m/s; in these cases, DNV utilized background noise data at 7 and 8 m/s for the corrections. The same was done for one-third octave analysis. DNV analyzed each measurement using a fast Fourier transform (FFT) with a 3-Hz resolution Hanning window from 3 to 20 kHz. Consistent with the IEC Standard, twelve 10-second energy-averaged narrowband spectra from turbine-operational data were analyzed in order to compare any suspected tones with the masking level in the tone's critical band. Two 60-second background-noise spectra closest to the integer wind speed (or at the highest wind speeds available in the case of 8 through 10 m/s, as described in Section 2.2.1) were energy averaged to get one spectra that was analyzed for each integer V_s and used to correct the operating spectra. Although an exception to the IEC Standard, utilizing background noise data from lower wind speeds for correction is expected to yield conservative results, since background noise levels are typically lower at lower wind speeds.

Each line in the identified tone's critical band was then classified according to the following criteria:

1. Lines are classified as masking if their RMS-averaged levels are less than 6 dB above the $L_{70\%}$ sound pressure level. The $L_{70\%}$ sound pressure level is the energy average of the 70% of spectral lines in the critical band with the lowest levels.
2. Lines are classified as tones if their RMS-averaged levels are more than 6 dB above the $L_{pn,avg}$ sound pressure level. The $L_{pn,avg}$ sound pressure level is the energy average of the spectral lines classified as masking.
3. Where there are several adjacent lines classified as tones, the line with the greatest level is identified. Adjacent lines are then classified as tones only if their levels are within 10 dB of the highest level.



4. Lines are classified as neither tones nor masking if their RMS-averaged levels:
 - Are greater than 6 dB above the $L_{70\%}$ sound pressure level and
 - Are less than 6 dB above the $L_{pn,avg}$ sound pressure level
5. Individual tones from each of the 12 background-corrected operating spectra (or a substitute lower-wind speed spectra in the case of 8 to 10 m/s) were energy averaged to determine their audibility.

The wind turbine noise tonality and tonal audibility are then calculated from the processed and categorized narrow band spectra. The tonal audibility as defined in the IEC Standard is a frequency-dependent criteria that has been determined from listening tests. A summary of these results is provided in Table 2-4.

2.2.6 A-Weighted Apparent Sound Power Level

The category A uncertainty for the apparent sound power level, L_{WA} , is the standard error of the estimated A-weighted sound pressure level, L_{Aeq} , at each integer V_S (Equation 2), and is obtained from the linear regression analysis.

$$U_A = \sqrt{\frac{\sum(y - y_{est})^2}{N - 2}} \quad \text{Equation 2}$$

Where: U_A = Category A uncertainty for apparent sound power level,
 y = measured sound pressure level,
 y_{est} = estimated sound pressure level using linear regression,
 N = number of measurements used in the linear regression.

The category A apparent sound power level uncertainty analysis resulted in a calculated uncertainty value, U_A , of 0.83 dB. DNV calculated this value using 143 data points at integer V_S values of 4 through 11 m/s. Uncertainty on the nacelle anemometer correlation was found to be 0.83 using Equation 2 above for data between 5% and 95% of rated power.

The category B uncertainty is calculated using Equation 3. The category B components are listed in Table 2-4. Two different values of U_{B9} were used, a higher value for the 8 to 10 m/s bins.

Total uncertainty values, U_C , are included in Table 4-4.

Table 2-4. Category B Uncertainty Components

| Parameter | Description | Value | Unit | Source |
|-----------|---|-------------|------|---|
| U_B | Category B uncertainty for apparent sound power level | 0.9 | dB | Calculation |
| U_{B1} | Calibration of the instruments | 0.2 | dB | Calibrator calibration |
| U_{B2} | Tolerances on the measurement chain | 0.3 | dB | Estimate |
| U_{B3} | Sound board | 0.3 | dB | Estimate |
| U_{B4} | Distance from microphone to hub | 0.1 | dB | Estimate |
| U_{B5} | Acoustic impedance of air | 0.1 | dB | Estimate |
| U_{B6} | Turbulence | 0.5 | dB | Estimate |
| U_{B7} | Wind speed, measured Wind speed, derived | 0.83 0.2 | dB | Calculated using Equation 2 New anemometer install |
| U_{B8} | Wind direction | 0.3 | dB | Sensor calibration and mounting estimate |
| U_{B9} | Background correction, 4-7 m/s Background correction, 8-10 m/s | 0.25 1.3 | dB | Applied background correction Maximum correction assuming $3 < \text{SNR} < 6$ |

$$U_B = \sqrt{U_{B1}^2 + U_{B2}^2 + U_{B3}^2 + U_{B4}^2 + U_{B5}^2 + U_{B6}^2 + U_{B7}^2 + U_{B8}^2 + U_{B9}^2} \quad \text{Equation 3}$$

Category A and B uncertainties are combined into one standard uncertainty by Equation 4:

$$U_C = \sqrt{U_A^2 + U_B^2} \quad \text{Equation 4}$$

Where: U_C = Overall standard uncertainty for apparent sound power level.

2.2.7 One-Third Octave Spectra

For the one-third octave band, U_A for each band is the standard error on the averaged band level, computed as the standard deviation divided by $(N-1)^{1/2}$, where N is the number of measured spectra. The value for U_{B3} is considered much larger than for L_{WA} , and is estimated to be 1.7 dB for one-third octave bands. Uncertainties on the one-third octaves are included in Table 4-3.

2.2.8 Tonality

Per the IEC Standard, U_A for each tone is the standard error, defined above, on the averaged tone level. The values of U_{B1} , U_{B4} , and U_{B6} can be estimated to be smaller than for L_{WA} . The value of U_{B3} is estimated to be 1.7 dB. Uncertainties are provided along with the tonality results in Table 4-5. Because 1 minute of background noise at 7 m/s and 8 m/s were utilized to background correct the total noise at 8 through 10 m/s, the background noise portion of uncertainty calculation, U_{B9} , was raised to a maximum value of 0.8, which DNV views as very conservative.



3 EXCEPTIONS TO THE IEC STANDARD

1. Insufficient background noise was recorded at the standardized wind speeds (V_S) of 8 through 10 m/s; only 1 minute of background noise at 8 m/s was recorded, and none at 9 m/s or 10 m/s was recorded. Background noise recorded at lower wind speeds (7 and 8 m/s) were utilized as a substitute for background corrections for overall sound pressure levels. For one-third octave data between 4 and 7 m/s, sufficient background noise data were available to calculate uncertainties per the IEC Standard. For one-third octave data at 8 to 10 m/s, no uncertainties are reported because these values are merely indicative and not to be relied upon.
2. Due to insufficient background noise at 8 through 10 m/s, measured background noise up to 13 m/s was utilized to derive the fourth-order regression equation utilized for background correction of operating noise. Uncertainty on the resulting calculated sound power levels (L_{WA}) and one-third octave turbine sound pressure levels have therefore been increased to account for this.
3. The turbine's yaw position data were utilized for determining wind direction instead of a wind vane transducer; yaw position has been shown to provide better correlation to acoustic noise output.

4 RESULTS

4.1 Collected Data

Data collected from 01:52 to 06:12 on February 20, 2011, were utilized in the subsequent results. Table 4-1 details the amount of data collected and the data removed for the specified reasons. Figure 4-1 displays the distribution of the collected data.

Table 4-1. Summary of Collected Data

| Item | Number of 1 Minute Data Points |
|---|--------------------------------|
| Total collected data, $V_s = 4 - 13$ m/s | 261 |
| Removed data for invalid wind direction | 19 |
| Removed data for turbine operating outside normal parameters | 24 |
| Removed for spurious noises, turbine shutdown/startup periods | 51 |
| Valid data used, turbine operating | 114 |
| Valid data used, background | 53 |




Figure 4-1. Valid Collected Data



4.2 Results

4.2.1 Overall Sound Pressure and Power Levels

As described in Section 2, DNV processed data into a set of valid data for use in the final results. The measured valid sound pressure levels for background and total (turbine operating) noise is displayed graphically in Figure 4-2. The fourth-order polynomials of total and background noise were used, since the resulting correlation coefficients were greater than 0.8, according to the IEC Standard. Because only one data point existed in the 8 m/s bin, and none in the 9 and 10 m/s bins, background noise at 11 through 13 m/s was utilized to determine the fourth-order regression. Table 4-2 lists the measured sound pressure levels for background and total noise, the background corrected “turbine-only” noise, and the subsequent sound power level for each standardized wind speed.

Figure 4-2 displays the sound pressure levels for both turbine operating and background noise measurements. Table 4-2 lists the total noise (wind turbine plus background) and background noise levels for each wind speed using fourth-order regression analysis per the IEC Standard, along with the calculated apparent sound power levels and the corresponding total uncertainties for each standardized wind speed. Although there was insufficient background noise measured at 8 m/s and none at 9 m/s and 10 m/s, including background noise at 12 and 13 m/s provides a fourth-order polynomial with a very high correlation factor (R-squared); therefore, although an exception to the IEC Standard, DNV believes this to be an accurate prediction of the background noise at these wind speeds. DNV also applied additional uncertainty to these L_{WA} at 8 through 10 m/s to account for this.

Additionally, Figure 4-2 shows sound power levels calculated using the 7 m/s background noise correction, to remove the uncertainty that may exist with the method above (using the fourth-order polynomial prediction without having any measured background data in the bin). Since it is in any case expected that the background noise will be higher at 8 m/s through 10 m/s than at 7 m/s, these calculated sound power levels for 8 m/s through 10 m/s are meant to provide an additional level of confidence in the results.

Figure 4-3 shows the turbine operating sound pressure levels versus the measured wind speed (labeled “ V_{met} ” in the figure) at 10 m height. Figure 4-4 shows the turbine operating sound pressure levels versus turbine electrical power.




Figure 4-2. A-Weighted, Valid Measured Sound Pressure Levels versus Standardized Wind Speed, Operating and Background

Table 4-2. A-Weighted Sound Pressure and Power Level (L_{WA}) Summary, $V_s = 4 - 10$ m/s

| Standardized Wind Speed, V_s (m/s) | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|--|------|------|-------|-------|-------|-------|-------|
| Wind Turbine + Background Noise, $L_{Aeq,k}$ (dB) | 47.7 | 49.7 | 51.6 | 52.7 | 53.0 | 52.5 | 51.8 |
| Background Noise, $L_{Aeq,k}$ (dB) | 36.4 | 37.5 | 37.0 | 36.6 | 37.1 | 39.1 | 42.3 |
| Wind Turbine Noise, $L_{Aeq,c,k}$ (dB) | 47.4 | 49.5 | 51.4 | 52.6 | 52.9 | 52.3 | 51.2 |
| Wind Turbine Apparent Sound Power Level, $L_{WA,k}$ (dB) | 96.3 | 98.4 | 100.3 | 101.5 | 101.8 | 101.2 | 100.2 |
| Uncertainty (\pm dB) | 0.9 | 1.0 | 0.9 | 0.9 | 1.6 | 1.7 | 1.7 |
| Wind Turbine Noise using 7m/s Background Noise Correction of 36.6 dB, $L_{Aeq,c,k}$ (dB) | | | | | 52.9 | 52.4 | 51.6 |
| Apparent Sound Level using 7 m/s Background Correction (dB) | | | | | 101.8 | 101.4 | 100.7 |

Note: For 8 to 10 m/s bins, insufficient background noise exists; LWA were calculated using a fourth-order polynomial for background noise.




Figure 4-3. A-Weighted Sound Pressure Levels, Turbine Operating and Background Measurements versus Density-Corrected Measured Wind Speed at 80 m Height




Figure 4-4. A-Weighted Sound Pressure Levels, Turbine Operating Versus Measured Electrical Power



4.2.2 A-Weighted One-Third Octave Analysis

Results of A-weighted one-third octave spectra analysis for integer standardized wind speeds of 4 through 10 m/s, with background noise correction, are displayed in Table 4-3 and Table 4-4.

Because only 1 minute of background noise was available at 8 m/s and none was available at 9 or 10 m/s, the lower wind speed background noise available at 8 m/s was utilized for background corrections of the one-third octave data; this is a deviation from the IEC Standard and is listed in Section 3. Since background noise is expected to be lower at lower wind speeds, the one-third octave levels of background-corrected turbine noise can generally be considered a more conservative result. Note that for all integer wind speeds, the background noise influences the wind turbine noise above 6300 Hz.

**Table 4-3. A-Weighted One-Third Octave Sound Pressure Levels, $V_S = 4 - 10$ m/s**

| | | Standardized Wind Speed Bin (m/s) | | | | | | |
|---|--------------|-----------------------------------|-------|-------|------|-------|-------|-------|
| | | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| One-Third Octave Center Frequency (Hz) | 20 | 5.4 | 6.4* | 9.7 | 11.3 | 7.6* | 11# | 14.5# |
| | 25 | 9.4* | 10.9* | 12.4 | 14.8 | 11.4* | 14# | 17.2# |
| | 31.5 | 14.3 | 15.5 | 17.0 | 18.5 | 13.9 | 17# | 20.5# |
| | 40 | 18.3 | 19.5 | 21.8 | 22.3 | 18.8 | 20.7# | 23.8# |
| | 50 | 21.4 | 22.3 | 24.9 | 25.5 | 22.2 | 23.8# | 26.6# |
| | 63 | 27.7 | 28.3 | 29.6 | 29.9 | 28.1 | 28.4# | 30.4# |
| | 80 | 26.0 | 26.6 | 30.2 | 31.3 | 29.5 | 29.4# | 31.2# |
| | 100 | 27.3 | 28.8 | 32.3 | 33.2 | 31.7 | 31.1# | 32.7# |
| | 125 | 30.3 | 31.6 | 35.2 | 36.3 | 35.8 | 35.3# | 36.4# |
| | 160 | 30.6 | 32.5 | 35.8 | 36.9 | 35.9 | 34.2# | 34.4# |
| | 200 | 30.9 | 32.6 | 36.2 | 37.2 | 36.2 | 34.8# | 34.7# |
| | 250 | 32.6 | 34.0 | 37.5 | 40.4 | 40.4 | 38# | 37.7# |
| | 315 | 36.7 | 38.0 | 39.9 | 40.6 | 40.3 | 39.7# | 39.7# |
| | 400 | 36.1 | 38.0 | 40.3 | 41.4 | 41.4 | 41.1# | 41.4# |
| | 500 | 35.3 | 37.0 | 39.6 | 40.8 | 40.6 | 39.6# | 39.1# |
| | 630 | 36.9 | 39.0 | 41.5 | 43.4 | 43.4 | 43.2# | 42.4# |
| | 800 | 37.4 | 39.5 | 41.4 | 42.4 | 42.4 | 41.4# | 40.5# |
| | 1000 | 37.5 | 39.2 | 41.4 | 42.5 | 42.3 | 41.5# | 40.6# |
| | 1250 | 37.3 | 38.7 | 41.2 | 42.3 | 42.3 | 41.6# | 40.6# |
| | 1600 | 37.7 | 39.0 | 40.7 | 41.7 | 41.8 | 41# | 39.9# |
| | 2000 | 37.0 | 37.8 | 39.7 | 40.7 | 40.8 | 40.2# | 38.7# |
| | 2500 | 36.7 | 37.0 | 38.4 | 38.9 | 39.1 | 38.5# | 36.6# |
| | 3150 | 31.6 | 32.8 | 35.1 | 36.3 | 36.6 | 36# | 33.4# |
| | 4000 | 27.4 | 28.8 | 31.0 | 32.4 | 32.7 | 32.2# | 28.8# |
| | 5000 | + | 25.1# | 26.7# | 28.0 | 28.3 | 27.8# | 25# |
| | 6300 | + | + | + | + | + | + | + |
| | 8000 | + | + | + | + | + | + | + |
| | 10000 | + | + | + | + | + | + | + |
| | 12500 | + | + | + | + | + | + | + |
| | 16000 | + | + | + | + | + | + | + |

* Operating-to-background level less than 6 dB but more than 3 dB

+ Operating-to-background level less than 3 dB

Corrected with only available one-minute record of 8 m/s data

Table 4-4. Uncertainties U_C (\pm dB) for One-Third Octave Results, $V_S = 4 - 7$ m/s

| | | Standardized Wind Speed V_S (m/s) | | | |
|---|--------------|-------------------------------------|-----|-----|-----|
| | | 4 | 5 | 6 | 7 |
| One-Third Octave Center Frequency (dB) | 20 | 2.1 | 3.0 | 2.1 | 3.3 |
| | 25 | 2.2 | 3.9 | 2.3 | 3.2 |
| | 31.5 | 2.1 | 3.4 | 2.3 | 3.8 |
| | 40 | 2.1 | 3.2 | 2.2 | 3.5 |
| | 50 | 2.1 | 2.7 | 2.3 | 3.5 |
| | 63 | 1.9 | 2.1 | 2.0 | 2.6 |
| | 80 | 2.2 | 2.6 | 2.2 | 2.9 |
| | 100 | 2.1 | 2.4 | 2.1 | 2.5 |
| | 125 | 2.0 | 2.2 | 2.0 | 2.1 |
| | 160 | 2.0 | 2.2 | 2.0 | 2.1 |
| | 200 | 2.0 | 2.2 | 1.9 | 2.0 |
| | 250 | 2.0 | 2.1 | 1.9 | 2.1 |
| | 315 | 1.9 | 2.0 | 1.9 | 1.9 |
| | 400 | 2.0 | 2.1 | 1.9 | 1.9 |
| | 500 | 2.0 | 2.1 | 1.9 | 1.9 |
| | 630 | 2.0 | 2.3 | 1.9 | 1.9 |
| | 800 | 2.0 | 2.2 | 1.9 | 1.9 |
| | 1000 | 2.0 | 2.1 | 1.9 | 1.9 |
| | 1250 | 1.9 | 2.1 | 1.9 | 1.9 |
| | 1600 | 1.9 | 2.0 | 1.9 | 1.9 |
| | 2000 | 1.9 | 2.0 | 1.9 | 1.9 |
| | 2500 | 1.9 | 1.9 | 1.9 | 1.9 |
| | 3150 | 1.9 | 2.0 | 1.9 | 2.0 |
| | 4000 | 1.9 | 2.0 | 1.9 | 2.1 |
| | 5000 | 1.9 | 2.0 | 1.9 | 2.1 |
| | 6300 | 1.9 | 1.9 | 1.9 | 2.0 |
| | 8000 | 1.9 | 1.9 | 1.9 | 1.9 |
| | 10000 | 1.9 | 1.9 | 1.9 | 1.9 |
| | 12500 | 1.9 | 1.9 | 1.9 | 1.9 |
| | 16000 | 1.9 | 1.9 | 1.9 | 1.9 |

4.2.3 Tonality

A summary of the tonality analysis is provided in Table 4-5. Results of the tonality analysis at each standardized wind speed are provided in Table 4-6 through Table 4-12. Graphs of each tone determined to be reportable per Equation 17 of the IEC Standard are provided in Appendix E, as well as narrowband spectra of the total noise utilized in this analysis for all wind speeds. As per the IEC Standard, the average frequency within the critical bandwidths for the tones at 674 Hz and 2490 Hz were used for determining audibility, since the frequencies of these two tones varied in each spectra analyzed but stayed within 10% of the critical bandwidth. Tones at 300 Hz and 360 Hz, respectively, stayed constant at those frequencies.



Table 4-5. Tonality Analysis Summary

| Standardized Wind Speed, V _s (10 m height) | Frequency (Hz) | ΔL_k (dB) | ΔL_a (dB) | $\Delta L_{a,k}$ (dB) | Uncertainty on Tonality (\pm dB) | Reportable per IEC |
|--|----------------|-------------------|-------------------|-----------------------|---|-----------------------|
| 4 | 60 | -10.56 | -2.00 | -8.55 | 1.85 | No |
| 4 | 300 | -4.52 | -2.11 | -2.41 | 2.49 | Yes |
| 4 | 360 | -11.89 | -2.16 | -9.73 | 2.46 | No |
| 4 | 711 | -14.74 | -2.53 | -12.21 | 2.46 | No |
| 4 | 2490 | -3.67 | -3.75 | 0.08 | 3.42 | Yes |
| 4 | 3300 | -12.38 | -4.05 | -8.33 | 2.96 | No |
| 5 | 60 | -2.14 | -2.00 | -0.14 | 2.98 | Yes |
| 5 | 120 | -10.67 | -2.01 | -8.66 | 2.20 | No |
| 5 | 300 | -8.21 | -2.06 | -1.22 | 1.87 | Yes |
| 5 | 360 | -12.10 | -2.16 | -9.94 | 2.10 | No |
| 5 | 474 | -5.76 | -2.24 | -3.52 | 2.72 | No |
| 5 | 639 | -8.75 | -2.36 | -6.39 | 2.43 | No |
| 5 | 711 | -7.09 | -2.53 | -4.56 | 2.31 | No |
| 5 | 1549 | -12.67 | -3.25 | -9.42 | 2.36 | No |
| 5 | 2553 | -5.42 | -3.77 | -1.64 | 3.17 | Yes |
| 5 | 3129 | -17.91 | -3.99 | -13.92 | 2.17 | No |
| 5 | 4518 | -18.65 | -4.39 | -14.26 | 2.31 | No |
| 6 | 450 | -8.60 | -2.25 | -6.35 | 2.42 | No |
| 6 | 710 | -13.21 | -2.53 | -10.59 | 2.09 | No |
| 6 | 2451 | -19.35 | -3.73 | -15.62 | 1.93 | No |
| 7 | 237 | -8.21 | -2.06 | -6.15 | 2.48 | No |
| 7 | 357 | -11.38 | -2.15 | -9.22 | 2.16 | No |
| 7 | 474 | -10.08 | -2.27 | -7.81 | 2.24 | No |
| 7 | 639 | -10.42 | -2.45 | -7.97 | 2.34 | No |
| 7 | 711 | -13.05 | -2.53 | -10.52 | 2.10 | No |
| 8 | 120 | -6.82 | -2.01 | -4.81 | 2.38 | No |
| 8 | 359 | -5.32 | -2.16 | -3.16 | 2.34 | No |
| 8 | 474 | -14.33 | -2.27 | -12.06 | 2.44 | No |
| 8 | 658 | -6.46 | -2.47 | -3.99 | 3.16 | No |
| 9 | 120 | -6.42 | -2.01 | -4.41 | 2.24 | No |
| 9 | 237 | -15.97 | -2.06 | -13.91 | 2.04 | No |
| 9 | 359 | -2.97 | -2.16 | -0.82 | 2.24 | Yes |
| 9 | 474 | -6.70 | -2.27 | -4.43 | 3.07 | No |
| 9 | 674 | -3.18 | -2.49 | -0.69 | 3.00 | Yes |
| 10 | 120 | -6.94 | -2.01 | -4.93 | 2.49 | No |
| 10 | 237 | -14.23 | -2.06 | -12.17 | 2.17 | No |
| 10 | 294 | -12.38 | -2.10 | -10.28 | 2.36 | No |
| 10 | 359 | -5.85 | -2.16 | -3.69 | 2.87 | No |
| 10 | 470 | -12.51 | -2.27 | -10.24 | 2.59 | No |
| 10 | 564 | -16.72 | -2.37 | -14.35 | 2.26 | No |
| 10 | 665 | -6.05 | -2.48 | -3.57 | 3.34 | No |

Table 4-6. Tonality and Tonal Audibility Results, $V_S = 4$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,i,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k}$ (\pm dB) |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 60 | -11.25 | -11.25 | -11.25 | -11.25 | -10.56 | -8.55 | 1.85 |
| | -11.25 | -11.25 | -11.25 | -11.25 | | | |
| | -11.25 | -11.25 | -6.37 | -3.96 | | | |
| 300 | -5.02 | -18.24 | -5.82 | -3.31 | -4.52 | -2.41 | 2.49 |
| | -2.40 | -0.93 | -4.41 | -18.24 | | | |
| | -4.78 | -4.66 | -4.60 | -3.96 | | | |
| 360 | -5.88 | -6.91 | -7.04 | -19.03 | -11.89 | -9.73 | 2.46 |
| | -18.86 | -17.94 | -19.03 | -19.03 | | | |
| | -19.03 | -19.03 | -19.03 | -19.03 | | | |
| 711 | -21.99 | -21.99 | -21.99 | -21.99 | -14.75 | -12.21 | 2.46 |
| | -21.99 | -21.99 | -21.99 | -21.99 | | | |
| | -21.99 | -7.35 | -21.99 | -8.10 | | | |
| 2490 | -27.43 | -1.49 | -3.77 | -1.25 | -3.67 | 0.08 | 3.42 |
| | -3.73 | -1.27 | -3.86 | -3.93 | | | |
| | -17.43 | -2.62 | -10.50 | -1.86 | | | |
| 3300 | -28.65 | -28.65 | -28.65 | -28.65 | -12.38 | -8.33 | 2.96 |
| | -28.65 | -1.68 | -28.65 | -28.65 | | | |
| | -28.65 | -28.65 | -28.65 | -28.65 | | | |

Table 4-7. Tonality and Tonal Audibility Results, $V_S = 5$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,i,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|--|--------|--------|--------|-------------------------------------|---|---|
| 60 | -3.08 | -15.24 | -15.24 | -15.24 | -2.14 | -0.14 | 2.98 |
| | -15.24 | -15.24 | 0.68 | 1.16 | | | |
| | 0.19 | 0.39 | 0.446 | -0.17 | | | |
| 120 | -15.27 | -15.27 | -15.27 | -15.27 | -10.67 | -8.66 | 2.20 |
| | -15.27 | -15.27 | -5.66 | -5.99 | | | |
| | -15.27 | -15.27 | -6.25 | -15.27 | | | |
| 300 | -3.36 | -6.68 | -4.96 | -3.85 | -3.89 | -1.78 | 1.84 |
| | -5.41 | -4.47 | -2.82 | -2.30 | | | |
| | -3.66 | -4.99 | -4.06 | -2.25 | | | |
| 360 | -15.61 | -15.61 | -15.61 | -15.61 | -12.10 | -9.94 | 2.10 |
| | -15.61 | -15.61 | -15.61 | -15.61 | | | |
| | -15.61 | -15.61 | -6.53 | -6.15 | | | |
| 450 | -5.97 | -1.36 | 2.93 | -15.80 | -5.76 | -3.52 | 2.72 |
| | -15.80 | -15.80 | -15.80 | -15.80 | | | |
| | -15.80 | -15.80 | -15.80 | -15.80 | | | |
| 555 | -6.94 | -3.08 | -7.05 | -16.06 | -8.75 | -6.39 | 2.43 |
| | -16.06 | -16.06 | -5.71 | -16.06 | | | |
| | -5.72 | -16.06 | -16.06 | -16.06 | | | |
| 711 | -5.20 | -6.85 | -16.48 | -6.65 | -7.09 | -4.56 | 2.31 |
| | -7.06 | -6.54 | -5.47 | -4.80 | | | |
| | -6.75 | -16.48 | -16.48 | -5.12 | | | |
| 1549 | -18.89 | -18.89 | -18.89 | -18.89 | -12.67 | -9.42 | 2.36 |
| | -18.89 | -18.89 | -18.89 | -18.89 | | | |
| | -18.89 | -10.45 | -7.94 | -5.50 | | | |
| 2553 | -8.58 | -21.20 | -21.20 | -21.20 | -5.42 | -1.65 | 3.17 |
| | -12.89 | -21.20 | -2.39 | -0.38 | | | |
| | -6.15 | -3.46 | -2.41 | -3.35 | | | |
| 3129 | -22.26 | -22.26 | -22.26 | -22.26 | -17.91 | -13.92 | 2.17 |
| | -14.24 | -22.26 | -22.26 | -22.26 | | | |
| | -22.26 | -13.63 | -22.26 | -12.25 | | | |
| 4518 | -24.27 | -24.27 | -24.27 | -24.27 | -18.65 | -14.26 | 2.31 |
| | -24.27 | -24.27 | -14.13 | -13.11 | | | |
| | -24.27 | -24.27 | -24.27 | -13.71 | | | |

Table 4-8. Tonality and Tonal Audibility Results, $V_S = 6$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,j,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 450 | -5.26 | -3.83 | -15.80 | -7.32 | -8.60 | -6.35 | 2.42 |
| | -3.99 | -15.80 | -15.80 | -15.80 | | | |
| | -7.54 | -15.80 | -15.80 | -15.80 | | | |
| 711 | -16.48 | -16.48 | -16.48 | -16.48 | -13.12 | -10.59 | 2.09 |
| | -16.48 | -16.48 | -16.48 | -16.48 | | | |
| | -16.48 | -16.48 | -6.91 | -8.06 | | | |
| 2450 | -21.00 | -21.00 | -12.85 | -21.00 | -19.35 | -15.62 | 1.93 |
| | -21.00 | -21.00 | -21.00 | -21.00 | | | |
| | -21.00 | -21.00 | -21.00 | -21.00 | | | |

Table 4-9. Tonality and Tonal Audibility Results, $V_S = 7$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,j,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 237 | -3.50 | -2.77 | -15.40 | -15.40 | -8.21 | -6.15 | 2.48 |
| | -15.40 | -15.40 | -15.40 | -15.40 | | | |
| | -15.40 | -2.39 | -15.40 | -15.40 | | | |
| 357 | -15.60 | -15.60 | -7.22 | -15.60 | -11.38 | -9.22 | 2.16 |
| | -15.60 | -15.60 | -15.60 | -15.60 | | | |
| | -15.60 | -15.60 | -7.16 | -6.13 | | | |
| 474 | -15.86 | -15.86 | -15.86 | -15.86 | -10.10 | -7.81 | 2.24 |
| | -15.86 | -15.86 | -15.86 | -15.86 | | | |
| | -15.86 | -15.86 | -0.49 | -15.86 | | | |
| 639 | -16.28 | -16.28 | -16.28 | -16.28 | -10.42 | -7.97 | 2.34 |
| | -16.28 | -16.28 | -4.99 | -5.65 | | | |
| | -5.39 | -16.28 | -16.28 | -16.28 | | | |
| 711 | -7.30 | -7.37 | -16.48 | -16.48 | -13.05 | -10.52 | 2.10 |
| | -16.48 | -16.48 | -16.48 | -16.48 | | | |
| | -16.48 | -16.48 | -16.48 | -16.48 | | | |

Table 4-10. Tonality and Tonal Audibility Results, $V_s = 8$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,i,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 120 | -14.26 | -14.26 | -14.26 | -5.59 | -6.82 | -4.81 | 2.38 |
| | -14.26 | -6.56 | -4.18 | -4.01 | | | |
| | -10.42 | -4.88 | -4.42 | -5.35 | | | |
| 359 | -5.68 | -4.32 | -2.31 | -4.34 | -5.32 | -3.16 | 2.34 |
| | -19.01 | -5.50 | -2.89 | -6.85 | | | |
| | -7.42 | -7.32 | -5.49 | -5.79 | | | |
| 474 | -20.23 | -20.23 | -20.23 | -20.23 | -14.33 | -12.06 | 2.44 |
| | -20.23 | -20.23 | -20.23 | -20.23 | | | |
| | -20.23 | -7.59 | -19.43 | -7.66 | | | |
| 658 | -21.65 | -21.65 | -21.65 | -4.73 | -6.46 | -3.99 | 3.16 |
| | -4.37 | -21.65 | -3.48 | -1.66 | | | |
| | -7.72 | -7.59 | -5.42 | -6.59 | | | |

Table 4-11. Tonality and Tonal Audibility Results, $V_s = 9$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,i,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 120 | -9.81 | -6.44 | -14.26 | -5.40 | -6.42 | -4.41 | 2.24 |
| | -15.10 | -6.91 | -5.55 | -5.42 | | | |
| | -6.50 | -4.18 | -4.59 | -17.22 | | | |
| 237 | -17.22 | -17.22 | -17.22 | -17.22 | -15.97 | -13.91 | 2.04 |
| | -17.22 | -10.23 | -17.22 | -17.22 | | | |
| | -17.22 | -17.22 | -17.22 | -17.22 | | | |
| 359 | -6.75 | -2.85 | -3.28 | 0.38 | -2.97 | -0.82 | 2.24 |
| | -13.58 | -2.45 | -0.94 | -3.87 | | | |
| | -6.25 | -3.11 | -0.97 | -4.04 | | | |
| 474 | -1.74 | -1.42 | -20.23 | -11.35 | -6.70 | -4.43 | 3.07 |
| | -4.28 | -6.67 | -20.23 | -20.23 | | | |
| | -20.23 | -7.45 | -18.74 | -5.51 | | | |
| 674 | -0.86 | -21.75 | -4.40 | -0.57 | -3.18 | -0.69 | 3.00 |
| | -3.35 | -2.22 | -4.52 | -1.66 | | | |
| | -21.75 | -1.04 | -5.85 | -2.58 | | | |

Table 4-12. Tonality and Tonal Audibility Results, $V_S = 10$ m/s

| Frequency of Identified Tone (Hz) | Difference between Tone and Masking Noise Level in each 10-second Period $\Delta L_{tn,i,k}$ (dB) | | | | Energy Average ΔL_k (dB) | Tonal Audibility $\Delta L_{a,k}$ (dB) | Uncertainty $\Delta L_{a,k} (\pm \text{dB})$ |
|-----------------------------------|---|--------|--------|--------|----------------------------------|--|--|
| 120 | -7.01 | -14.26 | -14.26 | -14.26 | -6.94 | -4.93 | 2.49 |
| | -14.26 | -14.26 | -14.26 | -6.37 | | | |
| | -1.80 | -5.19 | -4.10 | -3.79 | | | |
| 237 | -17.22 | -17.22 | -17.22 | -17.22 | -14.23 | -12.17 | 2.17 |
| | -12.83 | -17.22 | -17.22 | -17.22 | | | |
| | -17.22 | -17.22 | -6.75 | -17.22 | | | |
| 294 | -18.15 | -18.15 | -18.15 | -18.15 | -12.38 | -10.28 | 2.36 |
| | -18.15 | -18.15 | -18.15 | -2.80 | | | |
| | -18.15 | -18.15 | -18.15 | -18.15 | | | |
| 359 | -19.02 | -19.02 | -6.40 | -2.61 | -5.85 | -3.69 | 2.87 |
| | -16.31 | -2.41 | -6.15 | -6.43 | | | |
| | -19.02 | -7.22 | -2.20 | -3.51 | | | |
| 470 | -20.19 | -20.19 | -20.19 | -20.19 | -12.51 | -2.27 | -10.24 |
| | -7.38 | -20.19 | -20.19 | -20.19 | | | |
| | -20.19 | -20.19 | -20.19 | -4.04 | | | |
| 564 | -20.98 | -20.98 | -20.98 | -20.98 | -16.72 | -14.35 | 2.26 |
| | -20.98 | -20.98 | -20.98 | -20.98 | | | |
| | -20.98 | -7.76 | -20.98 | -20.98 | | | |
| 665 | -21.70 | -21.70 | -21.70 | -5.83 | -6.05 | -3.57 | 3.34 |
| | -21.70 | -2.72 | -6.85 | -21.70 | | | |
| | -7.32 | -6.75 | -4.65 | -0.81 | | | |



5 REFERENCES

1. ANTP0102, *Draft Acoustic Noise Test Plan for the V100 1.8MW Wind Turbine in Pueblo, CO*, DNV document, January 21, 2011.
2. *Wind turbine generator systems - Part 11: Acoustic noise measurement techniques*. IEC 61400-11:2002 +A1:2006(E). International Electrotechnical Commission, Geneva, Switzerland.
3. 0004-3053 V07, *General Specification V100-1.8MW*, Vestas document, dated November 22, 2010.



APPENDIX A

POWER CURVE USED FOR WIND SPEED CALIBRATION [3]

Table A-1. Measured Electrical Power Output for “Mode 0” at 1.225 kg/m³ Air Density

| Normalized Hub-Height Wind Speed (m/s) | Power Output (kW) |
|--|----------------------|
| 3.0 | 13 |
| 3.5 | 53 |
| 4.0 | 112 |
| 4.5 | 181 |
| 5.0 | 260 |
| 5.5 | 353 |
| 6.0 | 462 |
| 6.5 | 581 |
| 7.0 | 736 |
| 7.5 | 911 |
| 8.0 | 1108 |
| 8.5 | 1321 |
| 9.0 | 1524 |
| 9.5 | 1679 |
| 10.0 | 1766 |
| 10.5 | 1800 |
| 11.0 | 1811 |
| 11.5 | 1815 |
| 12.0 | 1815 |
| 12.5 | 1815 |
| 13.0 | 1815 |
| 13.5 | 1815 |
| 14.0 | 1815 |
| 14.5 | 1815 |
| 15.0 | 1815 |
| 15.5 | 1815 |
| 16.5 | 1815 |
| 17.0 | 1815 |
| 17.5 | 1815 |
| 18.0 | 1815 |
| 18.5 | 1815 |
| 19.0 | 1815 |
| 19.5 | 1815 |
| 20.0 | 1815 |

APPENDIX B

SITE PHOTOS



Figure B-1. Met Tower



Figure B-2. Wind Turbine Under Measurement and Microphone



Figure B-3. Wind Turbine Under Measurement from Met Tower



Figure B-4. Met Tower Hub Height Anemometers



APPENDIX C

INSTRUMENTATION CALIBRATIONS



Blue - Pueblo

Svend Ole Hansen ApS

SCT. JØRGENSEN ALLÉ 7 · DK-1615 KØBENHAVN V · DENMARK
TEL: (+45) 33 25 38 38 · FAX: (+45) 33 25 38 39 · WWW.SOHANSEN.DK



Installed 2/15/11
LS OK
PO 1156
WIND
ENGINEERING
FLUID
DYNAMICS

CERTIFICATE FOR CALIBRATION OF CUP ANEMOMETER

Certificate number: 10.02.7183

Date of issue: December 6, 2010

Type: WindSensor P2546A Cup Anemometer

Serial number: 10573

Manufacturer: WindSensor, Søkrøgen 9, 4000 Roskilde, Denmark

Client: WindSensor, Søkrøgen 9, 4000 Roskilde, Denmark

Anemometer received: November 26, 2010

Anemometer calibrated: December 5, 2010

Calibrated by: asj

Calibration procedure: IEC 61400-12-1, MEASNET

Certificate prepared by: jsa

Approved by: Calibration engineer, soh

Calibration equation obtained: $v \text{ [m/s]} = 0.63038 \cdot f \text{ [Hz]} + 0.21284$

Svend Ole Hansen

Standard uncertainty, slope: 0.00089

Standard uncertainty, offset: 0.04502



Covariance: -0.0000050 (m/s)²/HzCoefficient of correlation: $\rho = 0.999996$

Absolute maximum deviation: -0.017 m/s at 15.379 m/s

Barometric pressure: 991.4 hPa

Relative humidity: 21.0%

| Succession | Velocity pressure, q. [Pa] | Temperature in wind tunnel [°C] | Temperature in control room [°C] | Wind velocity, v. [m/s] | Frequency, f. [Hz] | Deviation, d. [m/s] | Uncertainty u _c (k=2) [m/s] |
|------------|----------------------------------|---------------------------------------|--|-------------------------------|--------------------------|---------------------------|--|
| 2 | 9.89 | 25.7 | 20.2 | 4.141 | 6.2557 | -0.015 | 0.028 |
| 4 | 15.30 | 25.5 | 20.2 | 5.151 | 7.8559 | -0.014 | 0.032 |
| 6 | 21.80 | 25.4 | 20.2 | 6.147 | 9.4188 | -0.003 | 0.037 |
| 8 | 29.90 | 25.3 | 20.1 | 7.197 | 11.0563 | 0.015 | 0.043 |
| 10 | 39.17 | 25.2 | 20.1 | 8.237 | 12.7085 | 0.013 | 0.048 |
| 12 | 49.23 | 25.1 | 20.1 | 9.233 | 14.2904 | 0.012 | 0.054 |
| 13-last | 60.79 | 25.1 | 20.1 | 10.259 | 15.9383 | -0.001 | 0.060 |
| 11 | 73.68 | 25.2 | 20.1 | 11.296 | 17.5645 | 0.011 | 0.066 |
| 9 | 87.16 | 25.3 | 20.1 | 12.289 | 19.1631 | -0.004 | 0.072 |
| 7 | 102.53 | 25.4 | 20.2 | 13.331 | 20.8054 | 0.003 | 0.078 |
| 5 | 118.66 | 25.5 | 20.2 | 14.344 | 22.3960 | 0.013 | 0.084 |
| 3 | 136.36 | 25.6 | 20.2 | 15.379 | 24.0852 | -0.017 | 0.090 |
| 1-first | 155.19 | 25.9 | 20.2 | 16.415 | 25.7202 | -0.011 | 0.096 |





MANAGING RISK



simco
electronics

5764 PACIFIC CENTER BLVD.
SAN DIEGO, CA 92121

CERTIFICATE OF CALIBRATION
FOR
DNV RENEWABLES
1809 7TH AVE. STE. 900
SEATTLE, WA 98101

Certificate No. **5090107**

LS OK
Installed 2/15/11
PO 1155

Description: **MET ONE, 064-1, Temperature Sensor**

Serial No: **K20290**

Asset No:

Simco ID: **42492-695**

Dept: **NONE**

PO No: **11154**

| | | |
|---|--|---|
| Calibration Date: 02/14/11 | Calibration Interval: 24 Months | Recall Date: 02/14/13 |
| Arrival Condition: MEETS MANUFACTURER'S SPEC'S. | | Service: CALIBRATED & CLEANED |

Procedure: **635-0030 REV 3**

Temperature: **73°F**

Relative Humidity: **36%**

Standards Used:

| Type | Simco ID | Due Date | Intvl Mos | Acc/Unc | Trace No. |
|------------------------------|----------|----------|--------------|-----------------|---------------|
| TEMPERATURE/HUMIDITY CHAMBER | 1016*152 | 07/31/11 | 6 | +/-0.5 deg C | B0902021 |
| PRT | 1016*121 | 06/08/11 | 9 | -200to500 deg C | B0902021 |
| PRT | 1016*121 | 06/08/11 | 9 | +/-0.010 deg C | B0902021 |
| THERMOMETER READOUT | 1016*120 | 07/31/11 | 9 | +/-0.004 deg C | B0A26025 |
| MULTIMETER | 1006*523 | 06/30/11 | 6 | RES+/-0.011% | 817/277427-09 |

Detail Of Work Performed:

UPDATED MODEL NUMBER FROM 064-2.

Calibration Data:

| Parameter | Nominal | Measured Before | Measured After | Tolerance |
|-----------|----------|-----------------|----------------|-----------|
| SEE | ATTACHED | | | |

There are 1 Supplementary Data Sheet(s) attached.

Work performed by:

Jeremy Cooper

Calibration Technician B (17162)

Reviewed by:

SIMCO Electronics' quality management system conforms to ISO 9001:2008, ISO/IEC 17025:2005, and ANSI/NCSL Z540-1-1994. All calibrations are performed using internationally recognized standards traceable to the International System of Units (SI Units). Traceability is achieved through calibrations by the National Institute of Standards and Technology (NIST), other National Measurement Institutes (NMIs), or by using natural physical constants, intrinsic standards or ratio calibration techniques. Instruments are calibrated with a test uncertainty ratio of 4:1 or greater, otherwise measurement uncertainty analysis and/or guard bands are applied during the measurement process. The information shown on this certificate applies only to the instrument identified above and may not be reproduced, except in full, without prior written consent from SIMCO Electronics. There is no implied warranty that the instrument will maintain its specified tolerances during the calibration interval due to possible drift, environment, or other factors beyond our control. This is an A2LA Accredited calibration.

Dated: **02/14/11**

Page 1 of 1



| | | | |
|---|--|--|--|
| | | Certificate No. 5090106 Installed 2/15/11 LS OK PO 11154 | |
| 1178 BORDEAUX DRIVE SUNNYVALE, CA 94089 | | CERTIFICATE OF CALIBRATION FOR DNV RENEWABLES 1809 7TH AVE, STE. 900 SEATTLE, WA 98101 | |
| | | | |
| Description: MET ONE, 090D, Barometer | | | |
| Serial No: K14990 | Asset No: | Simco ID: 42492-696 | |
| Dept: NONE | PO No: 11154 | | |
| Calibration Date: 02/14/11 | Calibration Interval: 24 Months | Recall Date: 02/14/13 | |
| Arrival Condition: MEETS MANUFACTURER'S SPEC'S. | | Service: CALIBRATED TO MFR SPEC, & CLEAN | |
| Procedure: TO33K6-4-1425-1 6/02 Temperature: 71°F | | | |
| Relative Humidity: 40% | | | |
| Standards Used: Type | Simco ID | Due Date | Intvl Mos Acc/Unc |
| Pressure Calibrator | 35363*93 | 05/20/11 | 12 +/-0.012% RNG |
| Precision DMM | 35363*35 | 07/22/11 | 12 dcV +/-0.004% |
| | | | Trace No. REPORT#69683 817/276744-08 |
| There are 2 Supplementary Data Sheet(s) attached. | | | |
| Work performed by: | | Reviewed by: | |
| John Durr Calibration Technician D (317) | | | |
| SIMCO Electronics' quality management system conforms to ISO 9001:2008, ISO/IEC 17025:2005, and ANSI/NCSL Z540-1-1994. All calibrations are performed using internationally recognized standards traceable to the International System of Units (SI Units). Traceability is achieved through calibrations by the National Institute of Standards and Technology (NIST), other National Measurement Institutes (NMIs), or by using natural physical constants, intrinsic standards or ratio calibration techniques. Instruments are calibrated with a test uncertainty ratio of 4:1 or greater, otherwise measurement uncertainty analysis and/or guard bands are applied during the measurement process. The information shown on this certificate applies only to the instrument identified above and may not be reproduced, except in full, without prior written consent from SIMCO Electronics. There is no implied warranty that the instrument will maintain its specified tolerances during the calibration interval due to possible drift, environment, or other factors beyond our control. This is an A2LA Accredited calibration. | | | |
| Dated: 02/14/11 | | | |
| Page 1 of 1 | | | |


Scantek, Inc.
 CALIBRATION LABORATORY

 ISO 17025: 2005, ANSI/NCSL Z540:1994 Part 1
 ACCREDITED by NVLAP (an ILAC and APLAC
 signatory)


NVLAP Lab Code: 200625-0

Calibration Certificate No.23173

Instrument: Acoustical Calibrator
Model: CAL200
Manufacturer: Larson Davis
Serial number: 8056
Class (IEC 60942): 1
Barometer type:
Barometer s/n:

Date Calibrated: 1/21/2011 **Cal Due:**
Status:

| | |
|----------|------|
| Received | Sent |
| X | X |

In tolerance:

| | |
|---|--|
| X | |
|---|--|

Out of tolerance:

| | |
|--|--|
| | |
|--|--|

See comments:

| | |
|--|--|
| | |
|--|--|

Contains non-accredited tests: Yes X No

Customer: DNV Renewables (USA) Inc. **Address:** 1809 7th Ave. Suite #500
Tel/Fax: 1-206-387-4240 / -4201 **Seattle, WA 90181**

Tested in accordance with the following procedures and standards:
 Calibration of Acoustical Calibrators, Scantek Inc., 06/06/2005

Instrumentation used for calibration: Nor-1504 Norsonic Test System:

| Instrument - Manufacturer | Description | S/N | Cal. Date | Traceability evidence | Cal. Due |
|-----------------------------|------------------------------|------------|---------------------|--------------------------|--------------|
| | | | | Cal. Lab / Accreditation | |
| 483B-Norsonic | SME Cal Unit | 25747 | Jan 4, 2011 | Scantek, Inc./ NVLAP | Jan 4, 2012 |
| DS-360-SRS | Function Generator | 61646 | Nov 13, 2009 | ACR Env. / A2LA | Nov 13, 2011 |
| 34401A-Agilent Technologies | Digital Multimeter | MY41022043 | Nov 17, 2010 | ACR Env. / A2LA | Nov 17, 2011 |
| DPI 141-Druck | Pressure Indicator | 790/00-04 | Dec 13, 2010 | ACR Env. / A2LA | Dec 13, 2012 |
| 8903A-HP | Audio Analyzer | 2514A05691 | Dec 1, 2010 | ACR Env. / A2LA | Dec 1, 2013 |
| HMP233-Vaisala Oy] | Humidity & Temp. Transmitter | V3820001 | Nov 25, 2009 | ACR Env. / A2LA | May 25, 2011 |
| PC Program 1018 Norsonic | Calibration software | v.5.0 | Validated July 2009 | | |
| 1253-Norsonic | Calibrator | 28326 | Dec 6, 2010 | Scantek, Inc./ NVLAP | Dec 6, 2011 |
| 1203-Norsonic | Preamplifier | 14059 | Jan 5, 2011 | Scantek, Inc./ NVLAP | Jan 5, 2012 |
| 4180-Brüel&Kjær | Microphone | 2246115 | Dec 14, 2009 | NPL (UK) / UKAS | Dec 14, 2011 |

Instrumentation and test results are traceable to SI (International System of Units) through standards maintained by NIST (USA) and NPL (UK)

| | | | |
|----------------------|------------------|-------------------|-----------------|
| Calibrated by | Valentin Buzduga | Checked by | Mariana Buzduga |
| Signature | | Signature | |
| Date | 1/21/2011 | Date | 1/21/2011 |

Calibration Certificates or Test Reports shall not be reproduced, except in full, without written approval of the laboratory.
 This Calibration Certificate or Test Reports shall not be used to claim product certification, approval or endorsement by NVLAP, NIST, or any agency of the federal government.
 Document stored as: Z:\Calibration Lab\Cal 2011\NDCAL200_8056_M1.doc

Page 1 of 2



| Scantek, Inc. CALIBRATION LABORATORY | | NVLAP [®] | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|---------------------------|-------------------------|---|---|---------------------|---------------|-------------------------|-------|--------------|---------------------|--------------|------------|--------------------|-------|-------------|------------------|-------------|-----------------------------|-------------------|------------|-------------|-----------------|-------------|--------------|---------------|---------------|--------------|-----------------|--------------|--------------------------|----------------------|-------|------------------------|---|---|---------------|------------|-------|-------------|----------------------|-------------|---------------|--------------|-------|-------------|----------------------|-------------|------------------|------------|---------|--------------|-----------------|--------------|--|--|--|
| ISO 17025: 2005, ANSI/NCSL Z540:1994 Part 1 and relevant requirements of ISO 9002:1994 ACCREDITED by NVLAP (an ILAC and APLAC signatory) | | NVLAP Lab Code: 200625-0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <h2>Calibration Certificate No.23175</h2> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Instrument: Microphone Model: 377B02 Manufacturer: PCB Piezotronics Serial number: 119659 | Date Calibrated: 1/7/2011 Cal Due: Status: <table border="1"> <tr> <td>Received</td> <td>Sent</td> </tr> <tr> <td>X</td> <td>X</td> </tr> </table> In tolerance: Out of tolerance: See comments: Contains non-accredited tests: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | Received | Sent | X | X | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Received | Sent | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| X | X | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Customer: DNV Renewables (USA) Inc. Tel/Fax: 1-206-387-4240/1-206-387-4201 | Address: 1809 7th Ave. Suite #500 Seattle, WA 90181 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Tested in accordance with the following procedures and standards: Procedure for Calibration of Measurement Microphones, Scantek Inc., 06/15/2005 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Instrumentation used for calibration: N-1504 Norsonic Test System: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1"> <thead> <tr> <th>Instrument - Manufacturer</th> <th>Description</th> <th>S/N</th> <th>Cal. Date</th> <th>Traceability evidence Cal. Lab / Accreditation</th> <th>Cal. Due</th> </tr> </thead> <tbody> <tr> <td>483B-Norsonic</td> <td>SME Cal Unit</td> <td>31052</td> <td>Sep 10, 2010</td> <td>Scantek, Inc./NVLAP</td> <td>Sep 10, 2011</td> </tr> <tr> <td>DS-360-SRS</td> <td>Function Generator</td> <td>33584</td> <td>Oct 5, 2009</td> <td>ACR. Env. / A2LA</td> <td>Oct 5, 2011</td> </tr> <tr> <td>34401A-Agilent Technologies</td> <td>Digital Voltmeter</td> <td>US36120731</td> <td>Sep 3, 2010</td> <td>ACR Env. / A2LA</td> <td>Sep 3, 2011</td> </tr> <tr> <td>HM30-Thommen</td> <td>Meteo Station</td> <td>1040170/39633</td> <td>Jun 26, 2010</td> <td>ACR Env. / A2LA</td> <td>Dec 26, 2011</td> </tr> <tr> <td>PC Program 1017 Norsonic</td> <td>Calibration software</td> <td>v.5.0</td> <td>Validated July 2009</td> <td>-</td> <td>-</td> </tr> <tr> <td>1253-Norsonic</td> <td>Calibrator</td> <td>28326</td> <td>Dec 6, 2010</td> <td>Scantek, Inc./ NVLAP</td> <td>Dec 6, 2011</td> </tr> <tr> <td>1203-Norsonic</td> <td>Preamplifier</td> <td>92268</td> <td>Dec 6, 2010</td> <td>Scantek, Inc./ NVLAP</td> <td>Dec 6, 2011</td> </tr> <tr> <td>4180-Bruel&Kjaer</td> <td>Microphone</td> <td>2246115</td> <td>Dec 14, 2009</td> <td>NPL (UK) / UKAS</td> <td>Dec 14, 2011</td> </tr> </tbody> </table> | Instrument - Manufacturer | Description | S/N | Cal. Date | Traceability evidence Cal. Lab / Accreditation | Cal. Due | 483B-Norsonic | SME Cal Unit | 31052 | Sep 10, 2010 | Scantek, Inc./NVLAP | Sep 10, 2011 | DS-360-SRS | Function Generator | 33584 | Oct 5, 2009 | ACR. Env. / A2LA | Oct 5, 2011 | 34401A-Agilent Technologies | Digital Voltmeter | US36120731 | Sep 3, 2010 | ACR Env. / A2LA | Sep 3, 2011 | HM30-Thommen | Meteo Station | 1040170/39633 | Jun 26, 2010 | ACR Env. / A2LA | Dec 26, 2011 | PC Program 1017 Norsonic | Calibration software | v.5.0 | Validated July 2009 | - | - | 1253-Norsonic | Calibrator | 28326 | Dec 6, 2010 | Scantek, Inc./ NVLAP | Dec 6, 2011 | 1203-Norsonic | Preamplifier | 92268 | Dec 6, 2010 | Scantek, Inc./ NVLAP | Dec 6, 2011 | 4180-Bruel&Kjaer | Microphone | 2246115 | Dec 14, 2009 | NPL (UK) / UKAS | Dec 14, 2011 | | | |
| Instrument - Manufacturer | Description | S/N | Cal. Date | Traceability evidence Cal. Lab / Accreditation | Cal. Due | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 483B-Norsonic | SME Cal Unit | 31052 | Sep 10, 2010 | Scantek, Inc./NVLAP | Sep 10, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| DS-360-SRS | Function Generator | 33584 | Oct 5, 2009 | ACR. Env. / A2LA | Oct 5, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34401A-Agilent Technologies | Digital Voltmeter | US36120731 | Sep 3, 2010 | ACR Env. / A2LA | Sep 3, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HM30-Thommen | Meteo Station | 1040170/39633 | Jun 26, 2010 | ACR Env. / A2LA | Dec 26, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| PC Program 1017 Norsonic | Calibration software | v.5.0 | Validated July 2009 | - | - | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1253-Norsonic | Calibrator | 28326 | Dec 6, 2010 | Scantek, Inc./ NVLAP | Dec 6, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1203-Norsonic | Preamplifier | 92268 | Dec 6, 2010 | Scantek, Inc./ NVLAP | Dec 6, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4180-Bruel&Kjaer | Microphone | 2246115 | Dec 14, 2009 | NPL (UK) / UKAS | Dec 14, 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Instrumentation and test results are traceable to SI - BIPM through standards maintained by NPL (UK) and NIST (USA) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1"> <tr> <td>Calibrated by</td> <td>Alex Buzduga</td> <td>Checked by</td> <td>Valentin Buzduga</td> </tr> <tr> <td>Signature</td> <td><i>Alex Buzduga</i></td> <td>Signature</td> <td><i>Valentin Buzduga</i></td> </tr> <tr> <td>Date</td> <td>1/7/2011</td> <td>Date</td> <td>1/21/2011</td> </tr> </table> | Calibrated by | Alex Buzduga | Checked by | Valentin Buzduga | Signature | <i>Alex Buzduga</i> | Signature | <i>Valentin Buzduga</i> | Date | 1/7/2011 | Date | 1/21/2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Calibrated by | Alex Buzduga | Checked by | Valentin Buzduga | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Signature | <i>Alex Buzduga</i> | Signature | <i>Valentin Buzduga</i> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Date | 1/7/2011 | Date | 1/21/2011 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Calibration Certificates or Test Reports shall not be reproduced, except in full, without written approval of the laboratory. This Calibration Certificate or Test Reports shall not be used to claim product certification, approval or endorsement by NVLAP, NIST, or any agency of the federal government. Document stored as: Z:\Calibration Lab\Mic 2010\PCB377B02_119659_M1.doc | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Page 1 of 2 <i>OK Sarah Taubitz 1/26/11 PB 10117449</i> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |



Scantek, Inc.

CALIBRATION LABORATORY

ISO 17025: 2005, ANSI/NCSL Z540:1994 Part 1
ACCREDITED by NVLAP (an ILAC and APLAC signatory)

NVLAP[®]

NVLAP Lab Code: 200625-0

Calibration Certificate No.23176

Instrument: Sound Measuring System
Model: noiseLab3-NI-9233
Manufacturer: Delta
Serial number: 1546B35
Tested with: Mic. 377B02 s/n 119761 & 119659
Preamp. 426E01 s/n 017604 & 017614
150 ft extension cables, Belden type 1C20
Type (class): 1
Customer: DNV Renewables (USA) Inc.
Tel/Fax: 1-206-387-4240 / 1-206-387-4201

Date Calibrated: 1/21/2011 **Cal Due:**
Status:

| | |
|----------|------|
| Received | Sent |
| X | X |

In tolerance:

| | |
|---|--|
| X | |
|---|--|

Out of tolerance:

| | |
|--|--|
| | |
|--|--|

See comments: X
Contains non-accredited tests: Yes ☒ No
Calibration service: Basic ☒ Standard

Address: 1809 7th Ave. Suite #500
Seattle, WA 90181

Tested in accordance with the following procedures and standards:
Calibration of Sound Level Meters, Scantek Inc., 06/07/2005
SLM & Dosimeters – Acoustical Tests, Scantek Inc., 06/15/2005

Instrumentation used for calibration: Nor-1504 Norsonic Test System:

| Instrument - Manufacturer | Description | S/N | Cal. Date | Traceability evidence Cal. Lab / Accreditation | Cal. Due |
|-----------------------------|----------------------|---------------|---------------------|---|--------------|
| 483B-Norsonic | SME Cal Unit | 31071 | Jul 6, 2010 | Scantek, Inc./ NVLAP | Jul 6, 2011 |
| DS-360-SRS | Function Generator | 88077 | Aug 17, 2010 | ACR Env./ A2LA | Aug 17, 2012 |
| 34401A-Agilent Technologies | Digital Voltmeter | MY47011118 | Aug 17, 2010 | ACR Env./ A2LA | Aug 17, 2011 |
| HM30-Thommen | Meteo Station | 1040170/39633 | Jun 26, 2010 | ACR Env./ A2LA | Dec 26, 2011 |
| PC Program 1019 Norsonic | Calibration software | v.5.0 | Validated July 2009 | - | - |
| 1251-Norsonic | Calibrator | 30878 | Dec 7, 2010 | Scantek, Inc./ NVLAP | Dec 7, 2011 |

Instrumentation and test results are traceable to SI (International System of Units) through standards maintained by NIST (USA) and NPL (UK).

Environmental conditions:

| Temperature (°C) | Barometric pressure (kPa) | Relative Humidity (%) |
|------------------|---------------------------|-----------------------|
| 23.2 °C | 99.38 kPa | 48.5 %RH |

| Calibrated by | Mariana Buzduga | Checked by | Valentin Buzduga |
|---------------|-----------------|------------|------------------|
| Signature | | Signature | |
| Date | 11/21/2011 | Date | 11/21/2011 |

Calibration Certificates or Test Reports shall not be reproduced, except in full, without written approval of the laboratory.

This Calibration Certificate or Test Reports shall not be used to claim product certification, approval or endorsement by NVLAP, NIST, or any agency of the federal government.

Document stored as: Z:\Calibration Lab\SLM 2011\DeltaNoiseLab3-9233_1546B35_M1.doc

Page 1 of 2

OK Serial Transfer
11/26/11
10/11/11

APPENDIX D

OTHER TURBINE INFORMATION PROVIDED BY VESTAS




Figure D-1. Turbine Drawing Showing Rotor Plane Offset




Figure D-2. Plant Map

APPENDIX E

RESULTS GRAPHS




Figure E-1. Hub-Height Derived Wind Speed vs. Nacelle Wind Speed




Figure E-2. Measured Sound Pressure Levels (Operating) vs. Turbine Power, not Background Corrected




Figure E-3. Operating Sound Pressure Levels vs. Rotor Speed




Figure E-5. Tone at 300 Hz in the 4 m/s Bin (graphed data from 02:30, $V_s = 4.44$ m/s)




Figure E-6. Tone at 2490 Hz in the 4 m/s Bin (graphed data from 02:23, $V_s = 4.07$ m/s)




Figure E-7. Tone at 60 Hz in the 5 m/s Bin (graphed data from 04:06, $V_s = 5.04$ m/s)




Figure E-8. Tone at 300 Hz in the 5 m/s Bin (graphed data from 04:06, $V_s = 5.04$ m/s)




Figure E-9. Tone at 2553 Hz in the 5 m/s Bin (graphed data from 03:55, $V_s = 4.98$ m/s)




Figure E-10. Tone at 360 Hz in the 9 m/s Bin (graphed data from 05:59, $V_s = 8.99$ m/s)




Figure E-11. Tone at 645 Hz in the 9 m/s Bin (graphed data from 06:02, $V_s = 8.97$ m/s)




Figure E-12. Total Noise FFTs used for 4 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_S = 4.06$ and 4.07 m/s)




Figure E-13. Total Noise FFTs used for 5 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_s = 4.98$ and 5.04 m/s)




Figure E-14. Total Noise FFTs used for 6 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_s = 6.00$ and 6.01 m/s)




Figure E-15. Total Noise FFTs used for 7 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_s = 7.02$ and 7.04 m/s)




Figure E-16. Total Noise FFTs used for 8 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_s = 8.00$ and 8.02 m/s)




Figure E-17. Total Noise FFTs used for 9 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_s = 8.99$ and 8.97 m/s)




Figure E-18. Total Noise FFTs used for 10 m/s Tonality Analysis, Upper Spectra Shifted by 20 dB each ($V_S = 9.82$ and 10.04 m/s)

APPENDIX E: CALCULATION DETAILS

Summary of Calculations - Condensed Overall, dBA Format

| | | | | | | | | | | | | | | | | |
|---------------------------------|-------------|--------|---------|-------|-----|------|----|-----|------|------|------|------|-------|------|------|----|
| R001 Non-Participating Receptor | | 605650 | 4773240 | 209.5 | | | | | | | | | | | | |
| Src ID | Src Name | X | Y | Z | Lx | Adiv | K0 | Dc | Agnd | Abar | Aatm | Afol | Ahous | Cmet | Refl | Lr |
| WTG1 | Vestas V100 | 604718 | 4775553 | 295.0 | 105 | 78.9 | 0 | 0.0 | -0.5 | 0.0 | 7.1 | 0.0 | 0.0 | 0.0 | 0.0 | 19 |
| WTG2 | Vestas V100 | 604889 | 4775173 | 295.0 | 105 | 77.4 | 0 | 0.0 | -0.5 | 0.0 | 6.4 | 0.0 | 0.0 | 0.0 | 0.0 | 22 |
| WTG3 | Vestas V100 | 606291 | 4774905 | 290.0 | 105 | 76.0 | 0 | 0.0 | -0.5 | 0.0 | 5.8 | 0.0 | 0.0 | 0.0 | 0.0 | 24 |
| WTG4 | Vestas V100 | 604359 | 4774308 | 297.1 | 105 | 75.5 | 0 | 0.0 | -0.5 | 0.0 | 5.6 | 0.0 | 0.0 | 0.0 | 0.0 | 24 |
| WTG5 | Vestas V100 | 606233 | 4773420 | 296.5 | 105 | 66.8 | 0 | 0.0 | -0.7 | 0.0 | 3.0 | 0.0 | 0.0 | 0.0 | 0.0 | 36 |

| R060 Non-Participating Receptor | | 605060 | 4774364 | 204.5 | | | | | | | | | | | | |
|---------------------------------|-------------|--------|---------|-------|-----|------|----|-----|------|------|------|------|-------|------|------|----|
| Src ID | Src Name | X | Y | Z | Lx | Adiv | K0 | Dc | Agnd | Abar | Aatm | Afol | Ahous | Cmet | Refl | Lr |
| WTG1 | Vestas V100 | 604718 | 4775553 | 295.0 | 105 | 72.9 | 0 | 0.0 | -0.6 | 0.0 | 4.7 | 0.0 | 0.0 | 0.0 | 0.0 | 28 |
| WTG2 | Vestas V100 | 604889 | 4775173 | 295.0 | 105 | 69.4 | 0 | 0.0 | -0.6 | 0.0 | 3.7 | 0.0 | 0.0 | 0.0 | 0.0 | 33 |
| WTG3 | Vestas V100 | 606291 | 4774905 | 290.0 | 105 | 73.6 | 0 | 0.0 | -0.6 | 0.0 | 4.9 | 0.0 | 0.0 | 0.0 | 0.0 | 27 |
| WTG4 | Vestas V100 | 604359 | 4774308 | 297.1 | 105 | 68.0 | 0 | 0.0 | -0.7 | 0.0 | 3.3 | 0.0 | 0.0 | 0.0 | 0.0 | 34 |
| WTG5 | Vestas V100 | 606233 | 4773420 | 296.5 | 105 | 74.6 | 0 | 0.0 | -0.6 | 0.0 | 5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 26 |

| R120 Non-Participating Receptor | | 606031 | 4774379 | 202.8 | | | | | | | | | | | | | |
|---------------------------------|-------------|--------|---------|-------|-----|------|----|-----|------|------|------|------|-------|------|------|----|--|
| Src ID | Src Name | X | Y | Z | Lx | Adiv | K0 | Dc | Agnd | Abar | Aatm | Afol | Ahous | Cmet | Refl | Lr | |
| WTG1 | Vestas V100 | 604718 | 4775553 | 295.0 | 105 | 75.9 | 0 | 0.0 | -0.5 | 0.0 | 5.8 | 0.0 | 0.0 | 0.0 | 0.0 | 24 | |
| WTG2 | Vestas V100 | 604889 | 4775173 | 295.0 | 105 | 73.9 | 0 | 0.0 | -0.6 | 0.0 | 5.0 | 0.0 | 0.0 | 0.0 | 0.0 | 27 | |
| WTG3 | Vestas V100 | 606291 | 4774905 | 290.0 | 105 | 66.5 | 0 | 0.0 | -0.7 | 0.0 | 3.0 | 0.0 | 0.0 | 0.0 | 0.0 | 36 | |
| WTG4 | Vestas V100 | 604359 | 4774308 | 297.1 | 105 | 75.5 | 0 | 0.0 | -0.5 | 0.0 | 5.6 | 0.0 | 0.0 | 0.0 | 0.0 | 24 | |
| WTG5 | Vestas V100 | 606233 | 4773420 | 296.5 | 105 | 70.9 | 0 | 0.0 | -0.6 | 0.0 | 4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 31 | |

| | | | | | | | | | | | | | | | | |
|---------------------------------|-------------|--------|---------|-------|-----|------|----|-----|------|------|------|------|-------|------|------|----|
| R165 Non-Participating Receptor | | 604109 | 4775818 | 204.5 | | | | | | | | | | | | |
| Src ID | Src Name | X | Y | Z | Lx | Adiv | K0 | Dc | Agnd | Abar | Aatm | Afol | Ahous | Cmet | Refl | Lr |
| WTG1 | Vestas V100 | 604718 | 4775553 | 295.0 | 105 | 67.5 | 0 | 0.0 | -0.7 | 0.0 | 3.2 | 0.0 | 0.0 | 0.0 | 0.0 | 35 |
| WTG2 | Vestas V100 | 604889 | 4775173 | 295.0 | 105 | 71.1 | 0 | 0.0 | -0.6 | 0.0 | 4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 30 |
| WTG3 | Vestas V100 | 606291 | 4774905 | 290.0 | 105 | 78.5 | 0 | 0.0 | -0.5 | 0.0 | 6.9 | 0.0 | 0.0 | 0.0 | 0.0 | 20 |
| WTG4 | Vestas V100 | 604359 | 4774308 | 297.1 | 105 | 74.7 | 0 | 0.0 | -0.6 | 0.0 | 5.3 | 0.0 | 0.0 | 0.0 | 0.0 | 26 |
| WTG5 | Vestas V100 | 606233 | 4773420 | 296.5 | 105 | 81.1 | 0 | 0.0 | -0.5 | 0.0 | 8.1 | 0.0 | 0.0 | 0.0 | 0.0 | 16 |

Summary of Calculations - Octave Band Format

| R001 Non-Participating Receptor | | 605650 | 4773240 | 209.5 | | | | | | | | | | | | | | |
|---------------------------------|-------------|--------|---------|---------|-------|------|------|----|-----|------|------|-------|------|-------|------|------|------|------|
| Src ID | Src Name | Band | X | Y | Z | Lx | Adiv | K0 | Dc | Agnd | Abar | Aatm | Afol | Ahous | Cmet | Refl | Lr | Band |
| WTG1 | Vestas V100 | 63 | 604718 | 4775553 | 295.0 | 87.4 | 78.9 | 0 | 0.0 | -3.0 | 0.0 | 0.3 | 0.0 | 0.0 | 0.0 | 0.0 | 11.2 | 63 |
| WTG1 | Vestas V100 | 125 | 604718 | 4775553 | 295.0 | 92.0 | 78.9 | 0 | 0.0 | 1.8 | 0.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.3 | 125 |
| WTG1 | Vestas V100 | 250 | 604718 | 4775553 | 295.0 | 94.7 | 78.9 | 0 | 0.0 | 0.1 | 0.0 | 2.6 | 0.0 | 0.0 | 0.0 | 0.0 | 13.1 | 250 |
| WTG1 | Vestas V100 | 500 | 604718 | 4775553 | 295.0 | 97.1 | 78.9 | 0 | 0.0 | -0.9 | 0.0 | 4.8 | 0.0 | 0.0 | 0.0 | 0.0 | 14.3 | 500 |
| WTG1 | Vestas V100 | 1000 | 604718 | 4775553 | 295.0 | 99.7 | 78.9 | 0 | 0.0 | -0.9 | 0.0 | 9.1 | 0.0 | 0.0 | 0.0 | 0.0 | 12.5 | 1000 |
| WTG1 | Vestas V100 | 2000 | 604718 | 4775553 | 295.0 | 98.2 | 78.9 | 0 | 0.0 | -0.9 | 0.0 | 24.1 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 2000 |
| WTG1 | Vestas V100 | 4000 | 604718 | 4775553 | 295.0 | 96.6 | 78.9 | 0 | 0.0 | -0.9 | 0.0 | 81.8 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 4000 |
| WTG1 | Vestas V100 | 8000 | 604718 | 4775553 | 295.0 | 89.8 | 78.9 | 0 | 0.0 | -0.9 | 0.0 | 291.6 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 8000 |
| WTG2 | Vestas V100 | 63 | 604889 | 4775173 | 295.0 | 87.4 | 77.4 | 0 | 0.0 | -3.0 | 0.0 | 0.3 | 0.0 | 0.0 | 0.0 | 0.0 | 12.8 | 63 |
| WTG2 | Vestas V100 | 125 | 604889 | 4775173 | 295.0 | 92.0 | 77.4 | 0 | 0.0 | 1.8 | 0.0 | 0.9 | 0.0 | 0.0 | 0.0 | 0.0 | 12.0 | 125 |
| WTG2 | Vestas V100 | 250 | 604889 | 4775173 | 295.0 | 94.7 | 77.4 | 0 | 0.0 | 0.1 | 0.0 | 2.2 | 0.0 | 0.0 | 0.0 | 0.0 | 15.1 | 250 |
| WTG2 | Vestas V100 | 500 | 604889 | 4775173 | 295.0 | 97.1 | 77.4 | 0 | 0.0 | -0.9 | 0.0 | 4.0 | 0.0 | 0.0 | 0.0 | 0.0 | 16.6 | 500 |
| WTG2 | Vestas V100 | 1000 | 604889 | 4775173 | 295.0 | 99.7 | 77.4 | 0 | 0.0 | -0.9 | 0.0 | 7.6 | 0.0 | 0.0 | 0.0 | 0.0 | 15.6 | 1000 |
| WTG2 | Vestas V100 | 2000 | 604889 | 4775173 | 295.0 | 98.2 | 77.4 | 0 | 0.0 | -0.9 | 0.0 | 20.1 | 0.0 | 0.0 | 0.0 | 0.0 | 1.7 | 2000 |
| WTG2 | Vestas V100 | 4000 | 604889 | 4775173 | 295.0 | 96.6 | 77.4 | 0 | 0.0 | -0.9 | 0.0 | 68.1 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 4000 |
| WTG2 | Vestas V100 | 8000 | 604889 | 4775173 | 295.0 | 89.8 | 77.4 | 0 | 0.0 | -0.9 | 0.0 | 243.0 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 8000 |
| WTG3 | Vestas V100 | 63 | 606291 | 4774905 | 290.0 | 87.4 | 76.0 | 0 | 0.0 | -3.0 | 0.0 | 0.2 | 0.0 | 0.0 | 0.0 | 0.0 | 14.2 | 63 |
| WTG3 | Vestas V100 | 125 | 606291 | 4774905 | 290.0 | 92.0 | 76.0 | 0 | 0.0 | 1.8 | 0.0 | 0.7 | 0.0 | 0.0 | 0.0 | 0.0 | 13.5 | 125 |
| WTG3 | Vestas V100 | 250 | 606291 | 4774905 | 290.0 | 94.7 | 76.0 | 0 | 0.0 | 0.1 | 0.0 | 1.9 | 0.0 | 0.0 | 0.0 | 0.0 | 16.7 | 250 |
| WTG3 | Vestas V100 | 500 | 606291 | 4774905 | 290.0 | 97.1 | 76.0 | 0 | 0.0 | -0.9 | 0.0 | 3.4 | 0.0 | 0.0 | 0.0 | 0.0 | 18.5 | 500 |
| WTG3 | Vestas V100 | 1000 | 606291 | 4774905 | 290.0 | 99.7 | 76.0 | 0 | 0.0 | -0.9 | 0.0 | 6.5 | 0.0 | 0.0 | 0.0 | 0.0 | 18.0 | 1000 |
| WTG3 | Vestas V100 | 2000 | 606291 | 4774905 | 290.0 | 98.2 | 76.0 | 0 | 0.0 | -0.9 | 0.0 | 17.3 | 0.0 | 0.0 | 0.0 | 0.0 | 5.8 | 2000 |
| WTG3 | Vestas V100 | 4000 | 606291 | 4774905 | 290.0 | 96.6 | 76.0 | 0 | 0.0 | -0.9 | 0.0 | 58.5 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 4000 |
| WTG3 | Vestas V100 | 8000 | 606291 | 4774905 | 290.0 | 89.8 | 76.0 | 0 | 0.0 | -0.9 | 0.0 | 208.7 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 8000 |
| WTG4 | Vestas V100 | 63 | 604359 | 4774307 | 297.1 | 87.4 | 75.5 | 0 | 0.0 | -3.0 | 0.0 | 0.2 | 0.0 | 0.0 | 0.0 | 0.0 | 14.7 | 63 |
| WTG4 | Vestas V100 | 125 | 604359 | 4774307 | 297.1 | 92.0 | 75.5 | 0 | 0.0 | 1.8 | 0.0 | 0.7 | 0.0 | 0.0 | 0.0 | 0.0 | 14.0 | 125 |
| WTG4 | Vestas V100 | 250 | 604359 | 4774307 | 297.1 | 94.7 | 75.5 | 0 | 0.0 | 0.1 | 0.0 | 1.8 | 0.0 | 0.0 | 0.0 | 0.0 | 17.4 | 250 |
| WTG4 | Vestas V100 | 500 | 604359 | 4774307 | 297.1 | 97.1 | 75.5 | 0 | 0.0 | -0.9 | 0.0 | 3.2 | 0.0 | 0.0 | 0.0 | 0.0 | 19.3 | 500 |
| WTG4 | Vestas V100 | 1000 | 604359 | 4774307 | 297.1 | 99.7 | 75.5 | 0 | 0.0 | -0.9 | 0.0 | 6.1 | 0.0 | 0.0 | 0.0 | 0.0 | 19.0 | 1000 |
| WTG4 | Vestas V100 | 2000 | 604359 | 4774307 | 297.1 | 98.2 | 75.5 | 0 | 0.0 | -0.9 | 0.0 | 16.2 | 0.0 | 0.0 | 0.0 | 0.0 | 7.4 | 2000 |
| WTG4 | Vestas V100 | 4000 | 604359 | 4774307 | 297.1 | 96.6 | 75.5 | 0 | 0.0 | -0.9 | 0.0 | 55.0 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 4000 |
| WTG4 | Vestas V100 | 8000 | 604359 | 4774307 | 297.1 | 89.8 | 75.5 | 0 | 0.0 | -0.9 | 0.0 | 196.0 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 8000 |
| WTG5 | Vestas V100 | 63 | 606233 | 4773420 | 296.5 | 87.4 | 66.8 | 0 | 0.0 | -3.0 | 0.0 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | 23.5 | 63 |
| WTG5 | Vestas V100 | 125 | 606233 | 4773420 | 296.5 | 92.0 | 66.8 | 0 | 0.0 | 1.6 | 0.0 | 0.3 | 0.0 | 0.0 | 0.0 | 0.0 | 23.4 | 125 |
| WTG5 | Vestas V100 | 250 | 606233 | 4773420 | 296.5 | 94.7 | 66.8 | 0 | 0.0 | 0.1 | 0.0 | 0.6 | 0.0 | 0.0 | 0.0 | 0.0 | 27.2 | 250 |
| WTG5 | Vestas V100 | 500 | 606233 | 4773420 | 296.5 | 97.1 | 66.8 | 0 | 0.0 | -0.9 | 0.0 | 1.2 | 0.0 | 0.0 | 0.0 | 0.0 | 30.0 | 500 |
| WTG5 | Vestas V100 | 1000 | 606233 | 4773420 | 296.5 | 99.7 | 66.8 | 0 | 0.0 | -0.9 | 0.0 | 2.3 | 0.0 | 0.0 | 0.0 | 0.0 | 31.6 | 1000 |
| WTG5 | Vestas V100 | 2000 | 606233 | 4773420 | 296.5 | 98.2 | 66.8 | 0 | 0.0 | -0.9 | 0.0 | 6.0 | 0.0 | 0.0 | 0.0 | 0.0 | 26.4 | 2000 |
| WTG5 | Vestas V100 | 4000 | 606233 | 4773420 | 296.5 | 96.6 | 66.8 | 0 | 0.0 | -0.9 | 0.0 | 20.2 | 0.0 | 0.0 | 0.0 | 0.0 | 10.5 | 4000 |
| WTG5 | Vestas V100 | 8000 | 606233 | 4773420 | 296.5 | 89.8 | 66.8 | 0 | 0.0 | -0.9 | 0.0 | 72.0 | 0.0 | 0.0 | 0.0 | 0.0 | -- | 8000 |

**APPENDIX F:
WIND SHEAR COEFFICIENT SUMMARY**

Figure F1: Diurnal Wind Shear, HAF Wind Energy
Calculations based on Wind Speeds Measured Between August 26 and September 9, 2010
at 79 m, 57 m and 39 m Heights

